



The vision of the Lake Forest School District is to be the model of excellence in education.

July 8, 2023

Dear Lake Forest Community,

This letter is to inform you we were notified that the recent results of the water testing conducted at Lake Forest North and South Elementary Schools were updated this week by the vendor who conducted the testing. As we have often shared, lead testing is underway at all points of potential consumption in all Delaware schools as a follow-up to lead testing that was conducted in 2020 under a grant received by the Delaware Department of Education.

Water tests at Lake Forest North Elementary School found results that exceeded reporting limits on **(1) kitchen fixtures** not used for consumption or food preparation. Tests at Lake Forest South Elementary School also found results that exceeded reporting limits on **(1) kitchen fixtures** not used for consumption or food preparation and **(1) sink** in the teacher's lounge not used for consumption or food preparation. The results also show that a number of water fountains showed exceeding lead results but these fixtures have been shut-off and not in use for several years.

While the fixtures pose no immediate risk to students or staff, they have been turned off and the District is implementing remediation efforts. Detailed results as well as additional resources for families are posted on our website, www.lf.k12.de.us.

At this time we have received testing results for all Lake Forest Schools. Please contact Mr. Karl Stahre or me at any time if you need more information on this important topic. Thank you.

Sincerely

Steven Lucas, Superintendent

Superintendent
Steven V. Lucas, Ed.D.
Central Business Office
5423 Killens Pond Road
Felton, Delaware 19943-9801
Office: 302-284-3020 Ext. 104, Fax: 302-284-5831
Steven.Lucas@lf.k12.de.us

Board of Education
Earle Dempsey, President
James L. Rau, Vice President
Sarah Starkey
Jordan McCloskey
Betty A. Wyatt, Ed.D.

Central Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-1-1-KIT-KF-P-01	Kitchen Faucet	05/03/2023	0.0065		mg/L	0.0020	NA	NA
LAKE-1-1-KIT-KF-F-01	Kitchen Faucet	05/03/2023	0.0016	J	mg/L	0.0020	NA	NA
LAKE-1-1-KIT-KF-P-03L	Left Kitchen Faucet	05/03/2023	0.029		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
LAKE-1-1-KIT-KF-F-03L	Left Kitchen Faucet	05/03/2023	0.0050		mg/L	0.0020	NA	NA
LAKE-1-1-KIT-KF-P-04R	Right Kitchen Faucet	05/03/2023	0.0050		mg/L	0.0020	NA	NA
LAKE-1-1-KIT-KF-F-04R	Right Kitchen Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-C153-DWC-P-06L	Left Water Fountain w/Cooler by Room C153	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-C153-DWC-SS-06L	Left Water Fountain w/Cooler by Room C153	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-C153-DWC-F-06L	Left Water Fountain w/Cooler by Room C153	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-C153-DWC-P-07R	Right Water Fountain w/Cooler by Room C153	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-C153-DWC-SS-07R	Right Water Fountain w/Cooler by Room C153	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-C153-DWC-F-07R	Right Water Fountain w/Cooler by Room C153	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-C142-DWC-P-08L	Left Water Fountain w/Cooler by Room C142	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-C142-DWC-SS-08L	Left Water Fountain w/Cooler by Room C142	05/03/2023	0.00078	J	mg/L	0.0020	NA	NA
LAKE-1-1-C142-DWC-F-08L	Left Water Fountain w/Cooler by Room C142	05/03/2023	0.0011	J	mg/L	0.0020	NA	NA
LAKE-1-1-C142-DWC-P-09R	Right Water Fountain w/Cooler by Room C142	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-C142-DWC-SS-09R	Right Water Fountain w/Cooler by Room C142	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-C142-DWC-F-09R	Right Water Fountain w/Cooler by Room C142	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-DWC-P-10	Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-DWC-SS-10	Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-DWC-F-10	Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-WBF-P-11	Bottle Filler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-WBF-SS-11	Bottle Filler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-WBF-F-11	Bottle Filler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-DWC-P-12L	Left Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-DWC-SS-12L	Left Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-DWC-F-12L	Left Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA

Central Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-1-1-GYM-DWC-P-13R	Right Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-DWC-SS-13R	Right Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-GYM-DWC-F-13R	Right Water Fountain w/Cooler Gym	05/03/2023	0.00075	J	mg/L	0.0020	NA	NA
LAKE-1-1-A205-DWC-P-14L	Left Water Fountain w/Cooler by Room A205	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-A205-DWC-SS-14L	Left Water Fountain w/Cooler by Room A205	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-A205-DWC-F-14L	Left Water Fountain w/Cooler by Room A205	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-A205-WBF-P-15	Bottle Filler by Room A205	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-A205-WBF-SS-15	Bottle Filler by Room A205	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-A205-WBF-F-15	Bottle Filler by Room A205	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-A205-DWC-P-16R	Right Water Fountain w/Cooler by Room A205	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-A205-DWC-SS-16R	Right Water Fountain w/Cooler by Room A205	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-A205-DWC-F-16R	Right Water Fountain w/Cooler by Room A205	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-WRR-DWC-P-18R	Right Water Fountain w/Cooler by Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-WRR-DWC-SS-18R	Right Water Fountain w/Cooler by Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-WRR-DWC-F-18R	Right Water Fountain w/Cooler by Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-1-1-B191-CF-P-19	Room B191 Sink Faucet	05/03/2023	0.0017	J	mg/L	0.0020	NA	NA
LAKE-1-1-B191-CF-F-19	Room B191 Sink Faucet	05/03/2023	0.0020	U	mg/L	0.002	NA	NA

Delaware Early Childhood Center

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-2-1-HW-DWC-P-01	Hallway Water Fountain w/Cooler	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-2-1-HW-DWC-SS-01	Hallway Water Fountain w/Cooler	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-2-1-HW-DWC-F-01	Hallway Water Fountain w/Cooler	05/03/2023	0.0010	J	mg/L	0.0020	NA	NA
LAKE-2-1-SL-SINK-P-02	Staff Lounge Sink Faucet	05/03/2023	0.0067		mg/L	0.0020	NA	NA
LAKE-2-1-SL-SINK-F-02	Staff Lounge Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-2-1-RM1-SINK-P-03	Room 1 Sink Faucet	05/03/2023	0.00073	J	mg/L	0.0020	NA	NA
LAKE-2-1-RM1-SINK-F-03	Room 1 Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-2-1-RM2-SINK-P-04	Room 2 Sink Faucet	05/03/2023	0.0023		mg/L	0.0020	NA	NA
LAKE-2-1-RM2-SINK-F-04	Room 2 Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-2-1-RM3-SINK-P-05	Room 3 Sink Faucet	05/03/2023	0.0052		mg/L	0.0020	NA	NA
LAKE-2-1-RM3-SINK-F-05	Room 3 Sink Faucet	05/03/2023	0.0016	J	mg/L	0.0020	NA	NA
LAKE-2-1-RM4-SINK-P-06	Room 4 Sink Faucet	05/03/2023	0.0030		mg/L	0.0020	NA	NA
LAKE-2-1-RM4-SINK-F-06	Room 4 Sink Faucet	05/03/2023	0.0034		mg/L	0.0020	NA	NA
LAKE-2-1-RM5-SINK-P-07	Room 5 Sink Faucet	05/03/2023	0.0040		mg/L	0.0020	NA	NA
LAKE-2-1-RM5-SINK-F-07	Room 5 Sink Faucet	05/03/2023	0.0059		mg/L	0.0020	NA	NA

East Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-3-1-HW-DWC-P-01	Water Fountain w/Cooler in Hallway	05/03/2023	0.0029		mg/L	0.0020	NA	NA
LAKE-3-1-HW-DWC-SS-01	Water Fountain w/Cooler in Hallway	05/03/2023	0.0018	J	mg/L	0.0020	NA	NA
LAKE-3-1-HW-DWC-F-01	Water Fountain w/Cooler in Hallway	05/03/2023	0.0021		mg/L	0.0020	NA	NA
LAKE-3-1-NUR-SINK-P-02	Nurse's Office Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-NUR-SINK-F-02	Nurse's Office Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-DWC-P-03	Water Fountain w/Cooler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-DWC-SS-03	Water Fountain w/Cooler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-DWC-F-03	Water Fountain w/Cooler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-WBF-P-04	Water Bottle Filler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-WBF-SS-04	Water Bottle Filler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-WBF-F-04	Water Bottle Filler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-P-05	Kitchen Faucet	05/03/2023	0.0027		mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-F-05	Kitchen Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-P-06	Kitchen Faucet	05/03/2023	0.0041		mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-F-06	Kitchen Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-P-07	Kitchen Faucet	05/03/2023	0.0016	J	mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-F-07	Kitchen Faucet	05/03/2023	0.0027		mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-P-08	Kitchen Faucet	05/03/2023	0.035		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
LAKE-3-1-KIT-KF-F-08	Kitchen Faucet	05/03/2023	0.037		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
LAKE-3-1-KIT-ICE-P-09	Kitchen Ice Machine	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-DWC-P-10	Water Fountain w/Cooler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-DWC-SS-10	Water Fountain w/Cooler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-DWC-F-10	Water Fountain w/Cooler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-WBF-P-11	Bottle Filler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-WBF-SS-11	Bottle Filler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA

East Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-3-1-HW-SPEECH-WBF-F-11	Bottle Filler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-RM9-DWC-P-12	Water Fountain w/Cooler by Room 9	05/03/2023	0.0021		mg/L	0.0020	NA	NA
LAKE-3-1-HW-RM9-DWC-SS-12	Water Fountain w/Cooler by Room 9	05/03/2023	0.0024		mg/L	0.0020	NA	NA
LAKE-3-1-HW-RM9-DWC-F-12	Water Fountain w/Cooler by Room 9	05/03/2023	0.0026		mg/L	0.0020	NA	NA
LAKE-3-1-RM11-DWC-P-13	Water Fountain w/Cooler by Room 11	05/03/2023	0.0021		mg/L	0.0020	NA	NA
LAKE-3-1-RM11-DWC-SS-13	Water Fountain w/Cooler by Room 11	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM11-DWC-F-13	Water Fountain w/Cooler by Room 11	05/03/2023	0.00084	J	mg/L	0.0020	NA	NA
LAKE-3-1-RM12-DWC-P-14	Water Fountain w/Cooler by Room 12	05/03/2023	0.0031		mg/L	0.0020	NA	NA
LAKE-3-1-RM12-DWC-SS-14	Water Fountain w/Cooler by Room 12	05/03/2023	0.0013	J	mg/L	0.0020	NA	NA
LAKE-3-1-RM12-DWC-F-14	Water Fountain w/Cooler by Room 12	05/03/2023	0.0014	J	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-DWC-P-15	Water Fountain w/Cooler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-DWC-SS-15	Water Fountain w/Cooler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-DWC-F-15	Water Fountain w/Cooler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-WBF-P-16	Bottle Filler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-WBF-SS-16	Bottle Filler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-WBF-F-16	Bottle Filler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM14-DWC-P-17	Water Fountain w/Cooler by Room 14	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM14-DWC-SS-17	Water Fountain w/Cooler by Room 14	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM14-DWC-F-17	Water Fountain w/Cooler by Room 14	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM13-DWC-P-18	Water Fountain w/Cooler by Room 13	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM13-DWC-SS-18	Water Fountain w/Cooler by Room 13	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM13-DWC-F-18	Water Fountain w/Cooler by Room 13	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-DWC-P-19	Water Fountain w/Cooler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-DWC-SS-19	Water Fountain w/Cooler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA

East Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-3-1-HW-MR/WR-DWC-F-19	Water Fountain w/Cooler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-WBF-P-20	Bottle Filler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-WBF-SS-20	Bottle Filler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-WBF-F-20	Bottle Filler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM4-TL-SINK-P-21	Teacher's Lounge/Room 4 Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM4-TL-SINK-F-21	Teacher's Lounge/Room 4 Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA

Lake Forest High School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-4-1-KIT-KF-P-01	Kitchen Faucet	05/03/2023	0.0023		mg/L	0.0020	NA	NA
LAKE-4-1-KIT-KF-F-01	Kitchen Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-KIT-KF-P-02	Kitchen Faucet	05/03/2023	0.0028		mg/L	0.0020	NA	NA
LAKE-4-1-KIT-KF-F-02	Kitchen Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-KIT-KF-P-03	Kitchen Faucet	05/03/2023	0.0044		mg/L	0.0020	NA	NA
LAKE-4-1-KIT-KF-F-03	Kitchen Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-KIT-ICE-P-04	Kitchen Ice Machine	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-CAF-DWC-P-06	Water Fountain w/Cooler Cafeteria	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-CAF-DWC-SS-06	Water Fountain w/Cooler Cafeteria	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-CAF-DWC-F-06	Water Fountain w/Cooler Cafeteria	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-CAF-WBF-P-07	Bottle Filler Cafeteria	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-CAF-WBF-SS-07	Bottle Filler Cafeteria	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-CAF-WBF-F-07	Bottle Filler Cafeteria	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-607-DWC-P-08	Water Fountain w/Cooler by Room 607	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-607-DWC-SS-08	Water Fountain w/Cooler by Room 607	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-607-DWC-F-08	Water Fountain w/Cooler by Room 607	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-607-WBF-P-09	Bottle Filler by Room 607	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-607-WBF-SS-09	Bottle Filler by Room 607	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-607-WBF-F-09	Bottle Filler by Room 607	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-P-10	Room 605 Sink Faucet	05/03/2023	0.0010	J	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-F-10	Room 605 Sink Faucet	05/03/2023	0.0032		mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-P-11	Room 605 Sink Faucet	05/03/2023	0.00089	J	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-F-11	Room 605 Sink Faucet	05/03/2023	0.0035		mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-P-12	Room 605 Sink Faucet	05/03/2023	0.00084	J	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-F-12	Room 605 Sink Faucet	05/03/2023	0.0018	J	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-P-13	Room 605 Sink Faucet	05/03/2023	0.00073	J	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-F-13	Room 605 Sink Faucet	05/03/2023	0.0025		mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-P-14	Room 605 Sink Faucet	05/03/2023	0.0011	J	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-F-14	Room 605 Sink Faucet	05/03/2023	0.0011	J	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-P-15	Room 605 Sink Faucet	05/03/2023	0.00081	J	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-F-15	Room 605 Sink Faucet	05/03/2023	0.00083	J	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-P-16	Room 605 Sink Faucet	05/03/2023	0.0012	J	mg/L	0.0020	NA	NA
LAKE-4-1-605-CF-F-16	Room 605 Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-401-DWC-P-17	Water Fountain w/Cooler by Room 401	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-401-DWC-SS-17	Water Fountain w/Cooler by Room 401	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA

Lake Forest High School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-4-1-401-DWC-F-17	Water Fountain w/Cooler by Room 401	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-401-DWC-P-18	Water Fountain w/Cooler by Room 401	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-401-DWC-SS-18	Water Fountain w/Cooler by Room 401	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-401-DWC-F-18	Water Fountain w/Cooler by Room 401	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-302-DWC-P-19	Water Fountain w/Cooler by Room 302	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-302-DWC-SS-19	Water Fountain w/Cooler by Room 302	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-302-DWC-F-19	Water Fountain w/Cooler by Room 302	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-302-WBF-P-20	Bottle Filler by Room 302	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-302-WBF-SS-20	Bottle Filler by Room 302	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-302-WBF-F-20	Bottle Filler by Room 302	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-201-DWC-P-21	Water Fountain w/Cooler by Room 201	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-201-DWC-SS-21	Water Fountain w/Cooler by Room 201	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-201-DWC-F-21	Water Fountain w/Cooler by Room 201	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-201-DWC-P-22	Water Fountain w/Cooler by Room 201	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-201-DWC-SS-22	Water Fountain w/Cooler by Room 201	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-201-DWC-F-22	Water Fountain w/Cooler by Room 201	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-102-DWC-P-23	Water Fountain w/Cooler by Room 102	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-102-DWC-SS-23	Water Fountain w/Cooler by Room 102	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-102-DWC-F-23	Water Fountain w/Cooler by Room 102	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-102-WBF-P-24	Bottle Filler by Room 102	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-102-WBF-SS-24	Bottle Filler by Room 102	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-102-WBF-F-24	Bottle Filler by Room 102	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-TL-CF-P-25	Teacher's Lounge Sink Faucet	05/03/2023	0.00082	J	mg/L	0.0020	NA	NA
LAKE-4-1-TL-CF-F-25	Teacher's Lounge Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-NO-CF-P-26	Nurse's Office Sink Faucet	05/03/2023	0.0019	J	mg/L	0.0020	NA	NA
LAKE-4-1-NO-CF-F-26	Nurse's Office Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-GYM-DWC-P-27	Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-GYM-DWC-SS-27	Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-GYM-DWC-F-27	Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-GYM-DWC-P-28	Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA

Lake Forest High School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-4-1-GYM-DWC-SS-28	Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-GYM-DWC-F-28	Water Fountain w/Cooler Gym	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-WT-DWC-P-29	Water Fountain w/Cooler Weight Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-WT-DWC-SS-29	Water Fountain w/Cooler Weight Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-WT-DWC-F-29	Water Fountain w/Cooler Weight Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-WT-WBF-P-30	Bottle Filler Weight Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-WT-WBF-SS-30	Bottle Filler Weight Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-WT-WBF-F-30	Bottle Filler Weight Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-WT-DWC-P-31	Water Fountain w/Cooler Weight Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-WT-DWC-SS-31	Water Fountain w/Cooler Weight Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-4-1-WT-DWC-F-31	Water Fountain w/Cooler Weight Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA

North Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-5-1-KIT-KF-P-01	Kitchen Faucet	05/04/2023	0.013		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Outlet, Replace Pipe, Reconfigure Plumbing, Resample
LAKE-5-1-KIT-KF-F-01	Kitchen Faucet	05/04/2023	0.0077		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
LAKE-5-1-KIT-KF-P-02	Kitchen Faucet	05/04/2023	0.0054		mg/L	0.0020	NA	NA
LAKE-5-1-KIT-KF-F-02	Kitchen Faucet	05/04/2023	0.0024		mg/L	0.0020	NA	NA
LAKE-5-1-CAFE-DWC-P-03	Water Fountain w/Cooler Cafeteria	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-CAFE-DWC-SS-03	Water Fountain w/Cooler Cafeteria	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-CAFE-DWC-F-03	Water Fountain w/Cooler Cafeteria	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-DWC-P-04	First Floor Water Fountain w/Cooler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-DWC-SS-04	First Floor Water Fountain w/Cooler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-DWC-F-04	First Floor Water Fountain w/Cooler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-WBF-P-05	First Floor Bottle Filler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-WBF-SS-05	First Floor Bottle Filler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-WBF-F-05	First Floor Bottle Filler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-113-DWC-P-06	Water Fountain w/Cooler by Room 113	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-113-DWC-SS-06	Water Fountain w/Cooler by Room 113	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-113-DWC-F-06	Water Fountain w/Cooler by Room 113	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-113-WBF-P-07	Bottle Filler by Room 113	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-113-WBF-SS-07	Bottle Filler by Room 113	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-113-WBF-F-07	Bottle Filler by Room 113	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-GYM-DWC-P-08	Water Fountain w/Cooler in Hallway by Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-GYM-DWC-SS-08	Water Fountain w/Cooler in Hallway by Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA

North Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-5-1-HW-GYM-DWC-F-08	Water Fountain w/Cooler in Hallway by Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-GYM-WBF-P-09	Bottle Filler in Hallway by Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-GYM-WBF-SS-09	Bottle Filler in Hallway by Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-GYM-WBF-F-09	Bottle Filler in Hallway by Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-7-DWC-P-10	Water Fountain w/Cooler by Room 7	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-7-DWC-SS-10	Water Fountain w/Cooler by Room 7	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-7-DWC-F-10	Water Fountain w/Cooler by Room 7	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-7-WBF-P-11	Bottle Filler by Room 7	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-7-WBF-SS-11	Bottle Filler by Room 7	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-7-WBF-F-11	Bottle Filler by Room 7	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-SPRINK-DWC-P-12	Water Fountain w/Cooler by Sprinkler Room	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-SPRINK-DWC-SS-12	Water Fountain w/Cooler by Sprinkler Room	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-SPRINK-DWC-F-12	Water Fountain w/Cooler by Sprinkler Room	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-SPRINK-WBF-P-13	Bottle Filler by Sprinkler Room	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-SPRINK-WBF-SS-13	Bottle Filler by Sprinkler Room	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-SPRINK-WBF-F-13	Bottle Filler by Sprinkler Room	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-DWC-P-14	Water Fountain w/Cooler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-DWC-SS-14	Water Fountain w/Cooler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-DWC-F-14	Water Fountain w/Cooler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-WBF-P-15	Bottle Filler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-WBF-SS-15	Bottle Filler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-HW-WR-WBF-F-15	Bottle Filler in Hallway by Women's Restroom	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-KIT-ICE-P-16	Kitchen Ice Machine	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-5-1-NUR-SINK-P-17	Nurse's Office Sink Faucet	05/04/2023	0.00097	J	mg/L	0.0020	NA	NA
LAKE-5-1-NUR-SINK-F-17	Nurse's Office Sink Faucet	05/04/2023	0.00066	J	mg/L	0.0020	NA	NA

South Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
Lake-6-1-KIT-ICE-P-01	Kitchen Ice Machine	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-KIT-KF-P-02	Kitchen Faucet	05/04/2023	0.0076		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-KIT-KF-F-02	Kitchen Faucet	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-KIT-KF-P-03	Kitchen Faucet	05/04/2023	0.014		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-KIT-KF-F-03	Kitchen Faucet	05/04/2023	0.00085	J	mg/L	0.0020	NA	NA
Lake-6-1-CAFE-WBF-P-04	Bottle Filler Cafeteria	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-CAFE-WBF-SS-04	Bottle Filler Cafeteria	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-CAFE-WBF-F-04	Bottle Filler Cafeteria	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-CAFE-DWC-P-05	Water Fountain w/Cooler Cafeteria	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-CAFE-DWC-SS-05	Water Fountain w/Cooler Cafeteria	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-CAFE-DWC-F-05	Water Fountain w/Cooler Cafeteria	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-TL-CF-P-06	Teachers Lounge Sink Faucet	05/04/2023	0.059		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-TL-CF-F-06	Teachers Lounge Sink Faucet	05/04/2023	0.010		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-168-WBF-P-07	Bottle Filler by Room 168	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-168-WBF-SS-07	Bottle Filler by Room 168	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-168-WBF-F-07	Bottle Filler by Room 168	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-168-DWC-P-08	Water Fountain w/Cool by Room 168	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-168-DWC-SS-08	Water Fountain w/Cool by Room 168	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-168-DWC-F-08	Water Fountain w/Cool by Room 168	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA

South Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
Lake-6-1-201-DW-P-09	Water Fountain Room 201	05/04/2023	0.025		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-201-DW-SS-09	Water Fountain Room 201	05/04/2023	0.00093	J	mg/L	0.0020	NA	NA
Lake-6-1-201-DW-F-09	Water Fountain Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-209-DW-P-10	Water Fountain Room 209	05/04/2023	0.036		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-209-DW-SS-10	Water Fountain Room 209	05/04/2023	0.0087		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-209-DW-F-10	Water Fountain Room 209	05/04/2023	0.0021		mg/L	0.0020	NA	NA
Lake-6-1-211-DW-P-11	Water Fountain Room 211	05/04/2023	0.0053		mg/L	0.0020	NA	NA
Lake-6-1-211-DW-SS-11	Water Fountain Room 211	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-211-DW-F-11	Water Fountain Room 211	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-211-DW-P-12	Water Fountain Room 211	05/04/2023	0.028		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-211-DW-SS-12	Water Fountain Room 211	05/04/2023	0.0022		mg/L	0.0020	NA	NA
Lake-6-1-211-DW-F-12	Water Fountain Room 211	05/04/2023	0.0016	J	mg/L	0.0020	NA	NA
Lake-6-1-223-DW-P-13	Water Fountain Room 223	05/04/2023	0.013		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-223-DW-SS-13	Water Fountain Room 223	05/04/2023	0.00078	J	mg/L	0.0020	NA	NA
Lake-6-1-223-DW-F-13	Water Fountain Room 223	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-220-DW-P-14	Water Fountain Room 220	05/04/2023	0.037		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-220-DW-SS-14	Water Fountain Room 220	05/04/2023	0.0024		mg/L	0.0020	NA	NA
Lake-6-1-220-DW-F-14	Water Fountain Room 220	05/04/2023	0.0028		mg/L	0.0020	NA	NA

South Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
Lake-6-1-235-DW-P-15	Water Fountain Room 235	05/04/2023	0.016		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-235-DW-SS-15	Water Fountain Room 235	05/04/2023	0.0011	J	mg/L	0.0020	NA	NA
Lake-6-1-235-DW-F-15	Water Fountain Room 235	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-241-DW-P-16	Water Fountain Room 241	05/04/2023	0.014		mg/L	0.0010	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-241-DW-SS-16	Water Fountain Room 241	05/04/2023	0.00077	J	mg/L	0.0020	NA	NA
Lake-6-1-241-DW-F-16	Water Fountain Room 241	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-224-DW-P-17	Water Fountain Room 224	05/04/2023	0.0012	J	mg/L	0.0020	NA	NA
Lake-6-1-224-DW-SS-17	Water Fountain Room 224	05/04/2023	0.0016	J	mg/L	0.0020	NA	NA
Lake-6-1-224-DW-F-17	Water Fountain Room 224	05/04/2023	0.038		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-222-DW-P-18	Water Fountain Room 222	05/04/2023	0.049		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-222-DW-SS-18	Water Fountain Room 222	05/04/2023	0.0021		mg/L	0.0020	NA	NA
Lake-6-1-222-DW-F-18	Water Fountain Room 222	05/04/2023	0.0013	J	mg/L	0.0020	NA	NA
Lake-6-1-216-DW-P-19	Water Fountain Room 216	05/04/2023	0.050		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-216-DW-SS-19	Water Fountain Room 216	05/04/2023	0.0036		mg/L	0.0020	NA	NA
Lake-6-1-216-DW-F-19	Water Fountain Room 216	05/04/2023	0.0014	J	mg/L	0.0020	NA	NA
Lake-6-1-214-DW-P-20	Water Fountain Room 214	05/04/2023	0.035		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-214-DW-SS-20	Water Fountain Room 214	05/04/2023	0.0025		mg/L	0.0020	NA	NA
Lake-6-1-214-DW-F-20	Water Fountain Room 214	05/04/2023	0.0015	J	mg/L	0.0020	NA	NA

South Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
Lake-6-1-206-DW-P-21	Water Fountain Room 206	05/04/2023	0.026		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-206-DW-SS-21	Water Fountain Room 206	05/04/2023	0.0019	J	mg/L	0.0020	NA	NA
Lake-6-1-206-DW-F-21	Water Fountain Room 206	05/04/2023	0.00088	J	mg/L	0.0020	NA	NA
Lake-6-1-204-DW-P-22	Water Fountain Room 204	05/04/2023	0.029		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-204-DW-SS-22	Water Fountain Room 204	05/04/2023	0.0015	J	mg/L	0.0020	NA	NA
Lake-6-1-204-DW-F-22	Water Fountain Room 204	05/04/2023	0.0010	J	mg/L	0.0020	NA	NA
Lake-6-1-127-DW-P-23	Water Fountain Room 127	05/04/2023	0.0088		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-127-DW-SS-23	Water Fountain Room 127	05/04/2023	0.0012	J	mg/L	0.0020	NA	NA
Lake-6-1-127-DW-F-23	Water Fountain Room 127	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-129-DW-P-24	Water Fountain Room 129	05/04/2023	0.0037		mg/L	0.0020	NA	NA
Lake-6-1-129-DW-SS-24	Water Fountain Room 129	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-129-DW-F-24	Water Fountain Room 129	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-135-DW-P-25	Water Fountain Room 135	05/04/2023	0.0069		mg/L	0.0020	NA	NA
Lake-6-1-135-DW-SS-25	Water Fountain Room 135	05/04/2023	0.0015	J	mg/L	0.0020	NA	NA
Lake-6-1-135-DW-F-25	Water Fountain Room 135	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-137-DW-P-26	Water Fountain Room 137	05/04/2023	0.0022		mg/L	0.0020	NA	NA
Lake-6-1-137-DW-SS-26	Water Fountain Room 137	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-137-DW-F-26	Water Fountain Room 137	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-143-DW-P-27	Water Fountain Room 143	05/04/2023	0.0059		mg/L	0.0020	NA	NA
Lake-6-1-143-DW-SS-27	Water Fountain Room 143	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-143-DW-F-27	Water Fountain Room 143	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-A101-DW-P-28	Water Fountain Room A101	05/04/2023	0.0041		mg/L	0.0020	NA	NA
Lake-6-1-A101-DW-SS-28	Water Fountain Room A101	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-A101-DW-F-28	Water Fountain Room A101	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-A108-DW-P-29	Water Fountain Room A108	05/04/2023	0.0057		mg/L	0.0020	NA	NA
Lake-6-1-A108-DW-SS-29	Water Fountain Room A108	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-A108-DW-F-29	Water Fountain Room A108	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-A102-DW-P-30	Water Fountain Room A102	05/04/2023	0.0055		mg/L	0.0020	NA	NA
Lake-6-1-A102-DW-SS-30	Water Fountain Room A102	05/04/2023	0.0012	J	mg/L	0.0020	NA	NA
Lake-6-1-A102-DW-F-30	Water Fountain Room A102	05/04/2023	0.00092	J	mg/L	0.0020	NA	NA
Lake-6-1-144-DW-P-31	Water Fountain Room 144	05/04/2023	0.0067		mg/L	0.0020	NA	NA

South Elementary School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
Lake-6-1-144-DW-SS-31	Water Fountain Room 144	05/04/2023	0.0012	J	mg/L	0.0020	NA	NA
Lake-6-1-144-DW-F-31	Water Fountain Room 144	05/04/2023	0.0010	J	mg/L	0.0020	NA	NA
Lake-6-1-136-DW-P-32	Water Fountain Room 136	05/04/2023	0.0074		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Lake-6-1-136-DW-SS-32	Water Fountain Room 136	05/04/2023	0.0014	J	mg/L	0.0020	NA	NA
Lake-6-1-136-DW-F-32	Water Fountain Room 136	05/04/2023	0.0013	J	mg/L	0.0020	NA	NA
Lake-6-1-134-DW-P-33	Water Fountain Room 134	05/04/2023	0.0018	J	mg/L	0.0020	NA	NA
Lake-6-1-134-DW-SS-33	Water Fountain Room 134	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-134-DW-F-33	Water Fountain Room 134	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
Lake-6-1-124-DW-P-34	Water Fountain Room 124	05/04/2023	0.0050		mg/L	0.0020	NA	NA
Lake-6-1-124-DW-SS-34	Water Fountain Room 124	05/04/2023	0.0014	J	mg/L	0.0020	NA	NA
Lake-6-1-124-DW-F-34	Water Fountain Room 124	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA

W.T. Chipman Middle School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-7-1-KIT-KF-P-01	Kitchen Faucet	05/04/2023	0.0010	J	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-F-01	Kitchen Faucet	05/04/2023	0.00085	J	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-P-02	Kitchen Faucet	05/04/2023	0.0015	J	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-F-02	Kitchen Faucet	05/04/2023	0.00072	J	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-P-03	Kitchen Faucet	05/04/2023	0.00097	J	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-F-03	Kitchen Faucet	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-ICE-P-04	Kitchen Ice Machine	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-P-05	Kitchen Faucet	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-F-05	Kitchen Faucet	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-CAF-DWC-P-06	Water Fountain w/Cooler Cafeteria	05/04/2023	0.00078	J	mg/L	0.0020	NA	NA
LAKE-7-1-CAF-DWC-SS-06	Water Fountain w/Cooler Cafeteria	05/04/2023	0.0013	J	mg/L	0.0020	NA	NA
LAKE-7-1-CAF-DWC-F-06	Water Fountain w/Cooler Cafeteria	05/04/2023	0.0014	J	mg/L	0.0020	NA	NA
LAKE-7-1-TL-CF-P-07	Teacher's Lounge Sink Faucet	05/04/2023	0.022		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
LAKE-7-1-TL-CF-F-07	Teacher's Lounge Sink Faucet	05/04/2023	0.0027		mg/L	0.0020	NA	NA
LAKE-7-1-301-DWC-P-08	Water Fountain w/Cooler by Room 301	05/04/2023	0.0014	J	mg/L	0.0020	NA	NA
LAKE-7-1-301-DWC-SS-08	Water Fountain w/Cooler by Room 301	05/04/2023	0.0035		mg/L	0.0020	NA	NA
LAKE-7-1-301-DWC-F-08	Water Fountain w/Cooler by Room 301	05/04/2023	0.0074		mg/L	0.0020	NA	NA
LAKE-7-1-103-DWC-P-09	Water Fountain w/Cooler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-103-DWC-SS-09	Water Fountain w/Cooler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-103-DWC-F-09	Water Fountain w/Cooler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-103-WBF-P-10	Bottle Filler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-103-WBF-SS-10	Bottle Filler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-103-WBF-F-10	Bottle Filler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-102-DWC-P-11	Water Fountain w/Cooler by Room 102	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-102-DWC-SS-11	Water Fountain w/Cooler by Room 102	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-102-DWC-F-11	Water Fountain w/Cooler by Room 102	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-DWC-P-12	Water Fountain w/Cooler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA

W.T. Chipman Middle School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-7-1-105-DWC-SS-12	Water Fountain w/Cooler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-DWC-F-12	Water Fountain w/Cooler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-WBF-P-13	Bottle Filler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-WBF-SS-13	Bottle Filler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-WBF-F-13	Bottle Filler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-109-DWC-P-14	Water Fountain w/Cooler by Room 109	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-109-DWC-SS-14	Water Fountain w/Cooler by Room 109	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-109-DWC-F-14	Water Fountain w/Cooler by Room 109	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-DWC-P-15	Water Fountain w/Cooler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-DWC-SS-15	Water Fountain w/Cooler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-DWC-F-15	Water Fountain w/Cooler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-WBF-P-16	Bottle Filler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-WBF-SS-16	Bottle Filler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-WBF-F-16	Bottle Filler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-P-17	Room 117 Sink Faucet	05/04/2023	0.0035		mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-F-17	Room 117 Sink Faucet	05/04/2023	0.00068	J	mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-P-18	Room 117 Sink Faucet	05/04/2023	0.0034		mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-F-18	Room 117 Sink Faucet	05/04/2023	0.00084	J	mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-P-19	Room 117 Sink Faucet	05/04/2023	0.0041		mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-F-19	Room 117 Sink Faucet	05/04/2023	0.0010	J	mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-P-20	Room 117 Sink Faucet	05/04/2023	0.0017	J	mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-F-20	Room 117 Sink Faucet	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-203-DWC-P-22	Second Floor Water Fountain w/Cooler by Room 203	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-203-DWC-SS-22	Second Floor Water Fountain w/Cooler by Room 203	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-203-DWC-F-22	Second Floor Water Fountain w/Cooler by Room 203	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-DWC-P-23	Second Floor Water Fountain w/Cooler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-DWC-SS-23	Second Floor Water Fountain w/Cooler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-DWC-F-23	Second Floor Water Fountain w/Cooler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-WBF-P-24	Second Floor Bottle Filler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-WBF-SS-24	Second Floor Bottle Filler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA

W.T. Chipman Middle School

Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-7-2-201-WBF-F-24	Second Floor Bottle Filler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-209-WBF-P-26	Second Floor Bottle Filler by Room 209	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-209-WBF-SS-26	Second Floor Bottle Filler by Room 209	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-209-WBF-F-26	Second Floor Bottle Filler by Room 209	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-P-28	Water Fountain w/Cooler Gym	05/04/2023	0.0013	J	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-SS-28	Water Fountain w/Cooler Gym	5/4/2023	0.0018	J	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-F-28	Water Fountain w/Cooler Gym	05/04/2023	0.0018	J	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-P-29	Water Fountain w/Cooler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-SS-29	Water Fountain w/Cooler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-F-29	Water Fountain w/Cooler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-WBF-P-30	Bottle Filler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-WBF-SS-30	Bottle Filler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-WBF-F-30	Bottle Filler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-DWC-P-31	Water Fountain w/Cooler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-DWC-SS-31	Water Fountain w/Cooler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-DWC-F-31	Water Fountain w/Cooler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-WBF-P-32	Bottle Filler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-WBF-SS-32	Bottle Filler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-WBF-32	Bottle Filler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-313-DWC-P-33	Water Fountain w/Cooler by Room 313	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-313-DWC-SS-33	Water Fountain w/Cooler by Room 313	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-313-DWC-F-33	Water Fountain w/Cooler by Room 313	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA

Key - Sample Name		Key - Qualifier	
P	Primary Sample	U	Not Detected in Laboratory Analysis
SS	Sequential Sample	J	Result is Between Laboratory Detection Limit & Laboratory Reporting Limit
F	Flush Sample		