

A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210 Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Telstar Middle School 284 Walkers Mills Road Bethel, ME 04217 Date Printed: 06/10/2022
Work Order #: 2204-03659
Client Job #: 793
Date Received: 04/22/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:

Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:

Identified by NH in Analyst Column 22 Manchester Road, Derry, NH 03038 www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for
 each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample.
 These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

• The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche Laboratory Director

ZIILL



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED:

06/10/2022

CLIENT NAME: Telstar Middle School

CLIENT ADDRESS:

284 Walkers Mills Road

Bethel, ME 04217

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend

Lead Above 4 ppb Lead Above 15 ppb **⊕** ⊗

DATE AND TIME RECEIVED: 04/22/2022 03:00PM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 18° CELSIUS

CLIENT JOB #: 793

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2204-03659-001	room 101-by storage closet	F	KF	04/20/2022 06:05AM	2.7	ppb			DR-NH	06/02/2022 07:15PM
2204-03659-002	room 101-by hall door	F	KF	04/20/2022 06:05AM	6.9	ppb	1		DR-NH	06/02/2022 07:18PM
2204-03659-003	room 101-2nd sink from hall	F	KF	04/20/2022 06:07AM	3.1	ppb			DR-NH	06/02/2022 07:27PM
2204-03659-004	room 101-3rd sink from hall	F	KF	04/20/2022 06:06AM	1.7	ppb			DR-NH	06/02/2022 07:29PM
2204-03659-005	room 101-south wall-right hand sink	F	KF	04/20/2022 06:07AM	20.1	ppb	\otimes		DR-NH	06/02/2022 07:32PM
2204-03659-006	room 103-south wall-right hand sink	F	KF	04/20/2022 06:09AM	<1	ppb			DR-NH	06/02/2022 07:35PM
2204-03659-007	room 103-south wall-left hand sink	F	KF	04/20/2022 06:09AM	<1	ppb			DR-NH	06/02/2022 07:44PM
2204-03659-008	room 103-east wall-by hall door	F	KF	04/20/2022 06:09AM	1.6	ppb			DR-NH	06/02/2022 07:47PM
2204-03659-009	room 103-east wall-2nd from hall	F	KF	04/20/2022 06:10AM	1.3	ppb			DR-NH	06/02/2022 07:50PM
2204-03659-010	room 103-east wall-3rd from hall	F	KF	04/20/2022 06:11AM	1.2	ppb			DR-NH	06/02/2022 07:53PM
2204-03659-011	room 103-east wall-4th from hall	F	KF	04/20/2022 06:10AM	3.6	ppb			DR-NH	06/02/2022 08:05PM
2204-03659-012	room 104-north wall	F	KF	04/20/2022 06:14AM	<1	ppb			DR-NH	06/02/2022 08:08PM
2204-03659-013	room 104-east wall	F	KF	04/20/2022 06:14AM	1.4	ppb			DR-NH	06/02/2022 08:11PM
2204-03659-014	room 106-island	F	KF	04/20/2022 06:15AM	3.3	ppb			DR-NH	06/02/2022 08:13PM
2204-03659-015	room 108-north wall	F	KF	04/20/2022 06:17AM	17.7	ppb	\otimes		DR-NH	06/08/2022 06:34PM
2204-03659-016	room 217-right sink	F	KF	04/20/2022 06:30AM	<1	ppb			DR-NH	06/02/2022 08:16PM
2204-03659-017	kitchen kettle	F	KF	04/20/2022 06:34AM	2.7	ppb			DR-NH	06/02/2022 08:19PM

Rebecca L. Labranche Laboratory Director