



Alpha

Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

EDC (Environmental.com, LLC)
262 Rickenbacker Circle
Livermore, CA 94551

Project Manager: Robbie Phillips
Project: San Bruno Park School District
Project Number: District Office

Reported:
11/15/22 11:57

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | 925-828-6226 | ELAP# 2728
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | 916-686-5190 | ELAP# 2922
North Bay: 737 Southpoint Blvd Unit D | Petaluma, CA 94954 | 707-769-3128 | ELAP# 2303
San Diego: 2722 Loker Avenue West Suite A | Carlsbad, CA 92010 | 760-930-2555 | ELAP# 3055
Los Angeles: 1230 E. 223rd Street Suite 205 | Carson, CA 90745 | 424-267-5032 | Service Center

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Fountain Near 3H	22K0092-01	Water	10/28/22 08:11	10/31/22 22:20
Fountain Near Rm. 7H	22K0092-02	Water	10/28/22 08:28	10/31/22 22:20
Fountain Near Kitchen	22K0092-03	Water	10/28/22 08:26	10/31/22 22:20
Fountain Near Field 1	22K0097-01	Water	10/28/22 08:57	10/31/22 22:20
Fountain Near MPR	22K0097-02	Water	10/28/22 09:03	10/31/22 22:20
Fountain Near RM 21 (Lower Fountain)	22K0097-03	Water	10/28/22 08:54	10/31/22 22:20
Fountain Near RM 19	22K0106-01	Water	10/28/22 09:29	10/31/22 22:20
Fountain Near RM 5	22K0106-02	Water	10/28/22 09:41	10/31/22 22:20
Fountain Near RM 1	22K0106-03	Water	10/28/22 09:49	10/31/22 22:20
Fountain Near RM 16	22K0112-01	Water	10/28/22 10:20	10/31/22 22:20
Fountain Near MPR	22K0112-02	Water	10/28/22 10:20	10/31/22 22:20
Fountain Near Admin	22K0112-03	Water	10/28/22 10:15	10/31/22 22:20
Fountain Near P1 / P2 (Lower One)	22K0119-01	Water	10/28/22 10:56	10/31/22 22:20
Fountain Near MPR	22K0119-02	Water	10/28/22 11:02	10/31/22 22:20
Fountain Near Rm 5/6/7/8	22K0119-03	Water	10/28/22 11:00	10/31/22 22:20

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
 Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

EDC (Environmental.com, LLC) 262 Rickenbacker Circle Livermore, CA 94551	Project Manager: Robbie Phillips Project: San Bruno Park School District Project Number: Rollingwood Elementary	Reported: 11/15/22 11:57
--	---	-----------------------------

	Result	Units	Reporting Limit	Dilution	Batch	Prepared	Analyzed	ELAP#	Method	Note
Fountain Near 3H (22K0092-01)			Sample Type: Water		Sampled: 10/28/22 08:11					
Metals by EPA Method 200.8 ICP/MS										
Lead	1.7	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 21:45	1551	EPA 200.8	P-02
Fountain Near Rm. 7H (22K0092-02)			Sample Type: Water		Sampled: 10/28/22 08:28					
Metals by EPA Method 200.8 ICP/MS										
Lead	6.0	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 21:51	1551	EPA 200.8	P-02
Fountain Near Kitchen (22K0092-03)			Sample Type: Water		Sampled: 10/28/22 08:26					
Metals by EPA Method 200.8 ICP/MS										
Lead	4.1	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 21:57	1551	EPA 200.8	P-02
Fountain Near Field 1 (22K0097-01)			Sample Type: Water		Sampled: 10/28/22 08:57					
Metals by EPA Method 200.8 ICP/MS										
Lead	1.3	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 22:04	1551	EPA 200.8	P-02
Fountain Near MPR (22K0097-02)			Sample Type: Water		Sampled: 10/28/22 09:03					
Metals by EPA Method 200.8 ICP/MS										
Lead	ND	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 22:11	1551	EPA 200.8	P-02
Fountain Near RM 21 (Lower Fountain) (22K0097-03)			Sample Type: Water		Sampled: 10/28/22 08:54					
Metals by EPA Method 200.8 ICP/MS										
Lead	4.5	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 23:03	1551	EPA 200.8	P-02
Fountain Near RM 19 (22K0106-01)			Sample Type: Water		Sampled: 10/28/22 09:29					
Metals by EPA Method 200.8 ICP/MS										
Lead	0.72	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 23:09	1551	EPA 200.8	P-02
Fountain Near RM 5 (22K0106-02)			Sample Type: Water		Sampled: 10/28/22 09:41					
Metals by EPA Method 200.8 ICP/MS										
Lead	0.61	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 23:16	1551	EPA 200.8	P-02
Fountain Near RM 1 (22K0106-03)			Sample Type: Water		Sampled: 10/28/22 09:49					
Metals by EPA Method 200.8 ICP/MS										
Lead	1.1	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 23:22	1551	EPA 200.8	P-02
Fountain Near RM 16 (22K0112-01)			Sample Type: Water		Sampled: 10/28/22 10:20					
Metals by EPA Method 200.8 ICP/MS										
Lead	4.5	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 23:29	1551	EPA 200.8	P-02
Fountain Near MPR (22K0112-02)			Sample Type: Water		Sampled: 10/28/22 10:20					
Metals by EPA Method 200.8 ICP/MS										
Lead	1.2	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 23:35	1551	EPA 200.8	P-02
Fountain Near Admin (22K0112-03)			Sample Type: Water		Sampled: 10/28/22 10:15					
Metals by EPA Method 200.8 ICP/MS										
Lead	ND	ug/L	0.25	1	AK23398	11/04/22 08:03	11/04/22 20:13	1551	EPA 200.8	P-02
Fountain Near P1 / P2 (Lower One) (22K0119-01)			Sample Type: Water		Sampled: 10/28/22 10:56					
Metals by EPA Method 200.8 ICP/MS										
Lead	ND	ug/L	1.0	1	AK23630	11/08/22 09:28	11/08/22 10:59	1551	EPA 200.8	P-02
Fountain Near MPR (22K0119-02)			Sample Type: Water		Sampled: 10/28/22 11:02					
Metals by EPA Method 200.8 ICP/MS										

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
 Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

EDC (Environmental.com, LLC) 262 Rickenbacker Circle Livermore, CA 94551	Project Manager: Robbie Phillips Project: San Bruno Park School District Project Number: Rollingwood Elementary	Reported: 11/15/22 11:57
--	---	-----------------------------

	Result	Units	Reporting Limit	Dilution	Batch	Prepared	Analyzed	ELAP#	Method	Note
Fountain Near MPR (22K0119-02)			Sample Type: Water			Sampled: 10/28/22 11:02				
Metals by EPA Method 200.8 ICP/MS (cont'd)										P-02
Lead	ND	ug/L	1.0	1	AK23630	11/08/22 09:28	11/08/22 11:05	1551	EPA 200.8	
Fountain Near Rm 5/6/7/8 (22K0119-03)			Sample Type: Water			Sampled: 10/28/22 11:00				
Metals by EPA Method 200.8 ICP/MS										P-02
Lead	ND	ug/L	1.0	1	AK23630	11/08/22 09:28	11/08/22 11:11	1551	EPA 200.8	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

EDC (Environmental.com, LLC)
262 Rickenbacker Circle
Livermore, CA 94551

Project Manager: Robbie Phillips
Project: San Bruno Park School District
Project Number: Rollingwood Elementary

Reported:
11/15/22 11:57

Metals by EPA Method 200.8 ICP/MS - Quality Control

Analyte(s)	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Flag
Batch AK23398 - EPA 200 Series										
Blank (AK23398-BLK1)				Prepared & Analyzed: 11/04/22						
Lead	ND	0.25	ug/L							
LCS (AK23398-BS1)				Prepared & Analyzed: 11/04/22						
Lead	21.1	0.25	ug/L	20.0		105	85-115			
Duplicate (AK23398-DUP1)				Source: 22J3871-01 Prepared & Analyzed: 11/04/22						
Lead	1.56	0.25	ug/L		1.63			4.24	20	
Matrix Spike (AK23398-MS1)				Source: 22J3871-01 Prepared & Analyzed: 11/04/22						
Lead	20.0	0.25	ug/L	20.0	1.63	92.0	70-130			
Matrix Spike (AK23398-MS2)				Source: 22K0112-03 Prepared & Analyzed: 11/04/22						
Lead	18.9	0.25	ug/L	20.0	ND	94.6	70-130			
Matrix Spike Dup (AK23398-MSD1)				Source: 22J3871-01 Prepared & Analyzed: 11/04/22						
Lead	20.0	0.25	ug/L	20.0	1.63	91.9	70-130	0.180	20	
Batch AK23630 - EPA 200 Series										
Blank (AK23630-BLK1)				Prepared & Analyzed: 11/08/22						
Lead	ND	1.0	ug/L							
LCS (AK23630-BS1)				Prepared & Analyzed: 11/08/22						
Lead	20.7	1.0	ug/L	20.0		104	85-115			
Duplicate (AK23630-DUP1)				Source: 22K0119-01 Prepared & Analyzed: 11/08/22						
Lead	ND	1.0	ug/L		ND			7.15	20	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



alpha

Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

EDC (Environmental.com, LLC)
262 Rickenbacker Circle
Livermore, CA 94551

Project Manager: Robbie Phillips
Project: San Bruno Park School District
Project Number: Rollingwood Elementary

Reported:
11/15/22 11:57

Metals by EPA Method 200.8 ICP/MS - Quality Control

Analyte(s)	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Flag
Batch AK23630 - EPA 200 Series										
Matrix Spike (AK23630-MS1) Source: 22K0119-01 Prepared & Analyzed: 11/08/22										
Lead	21.2	1.0	ug/L	20.0	ND	106	70-130			
Matrix Spike (AK23630-MS2) Source: 22K0876-01 Prepared & Analyzed: 11/08/22										
Lead	20.4	1.0	ug/L	20.0	ND	100	70-130			
Matrix Spike Dup (AK23630-MSD1) Source: 22K0119-01 Prepared & Analyzed: 11/08/22										
Lead	21.1	1.0	ug/L	20.0	ND	105	70-130	0.472	20	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

EDC (Environmental.com, LLC)
262 Rickenbacker Circle
Livermore, CA 94551

Project Manager: Robbie Phillips
Project: San Bruno Park School District
Project Number: Rollingwood Elementary

Reported:
11/15/22 11:57

Notes and Definitions

- P-02 Sample acidified to pH <2 and allowed to sit 24 hours before further processing.
- ND Analyte NOT DETECTED at or above the reporting limit
- dry Sample results reported on a dry weight basis
- REC Recovery
- RPD Relative Percent Difference

Non-accredited analytes are reported only when ELAP accreditation for a requested analyte method pair is not available. For a list of accredited analytes, view our certificates at the Company link on our website at www.alpha-labs.com or contact your Project Manager directly.

Work Order Chain of Custody Record

Address:
262 Rickenbacker Circle,
Livermore, CA, 94551

Phone: 925-833-7810
Fax: 925-829-9101
Email: admin@environmental.com



Lab No. 22K0092 Page 4 of 4

Signature below authorizes work under terms stated on reverse side.

Company Name: environmental.com		Project ID: San Bruno Park School District		Analysis Request		Sample Notes		TAT																																																																		
Billing Address: 2 Rickenbacker Circle Livermore, CA 94551		Project No: Belle Air Elementary		<table border="1"> <tr> <th rowspan="2">Sample Collection</th> <th colspan="3">Container</th> <th colspan="3">Reagent</th> <th colspan="3">Matrix</th> </tr> <tr> <th>40ml Vial</th> <th>Polycarbonate</th> <th>Glass</th> <th>Sieve</th> <th>Other</th> <th>HCL</th> <th>NH4Cl</th> <th>Other</th> <th>Na2S2O3</th> <th>None</th> <th>Water</th> <th>Soil</th> <th>Other</th> </tr> <tr> <td>Lower fountain</td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td>X</td> <td></td> <td></td> </tr> <tr> <td>Kitchen Sink</td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td>X</td> <td></td> <td></td> </tr> <tr> <td>Room next to kitchen (faucet)</td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td>X</td> <td></td> <td></td> </tr> </table>		Sample Collection	Container			Reagent			Matrix			40ml Vial	Polycarbonate	Glass	Sieve	Other	HCL	NH4Cl	Other	Na2S2O3	None	Water	Soil	Other	Lower fountain	X								X		X			Kitchen Sink	X								X		X			Room next to kitchen (faucet)	X								X		X			<p>Pb Total 200 g</p> <p><i>Revised CoC Attached</i></p>			
Sample Collection	Container						Reagent			Matrix																																																																
	40ml Vial	Polycarbonate	Glass			Sieve	Other	HCL	NH4Cl	Other	Na2S2O3	None	Water	Soil	Other																																																											
Lower fountain	X										X		X																																																													
Kitchen Sink	X								X		X																																																															
Room next to kitchen (faucet)	X								X		X																																																															
Object Contact & Email (Hardcopy or PDF to): chelle Sim msim@environmental.com		Site Name: Belle Air Elementary																																																																								
Phone/Fax: 925-833-7810		Site Address or Contact:																																																																								
Relinquished by: <i>Chelle Sim</i>		Received by: JE																																																																								
Relinquished by:		Received by: JE		Date: 10/31		Time: 1930		Date: 10/31		Time: 2220																																																																
Relinquished by:		Received by:		Date:		Time:		Date:		Time:																																																																
Relinquished by:		Received by:		Date:		Time:		Date:		Time:																																																																
Relinquished by:		Received by:		Date:		Time:		Date:		Time:																																																																



245 New York Ranch Rd, Suite A, Jackson, CA 95642 (209) 418-3175
email: atranle@49erwaterlab.com / www.49erwaterlab.com

08/07/2022

Please find the attached report(s) for your water analysis for Order #9785. Your sample(s) were received on 08/06/2022 03:00pm. Your sample(s) were analyzed in accordance with EPA and/or approved ELAP methods. All Quality Control results are within acceptable limits except where noted as a case summary or notation.

We value your business and thank you for your business.


Please feel free to contact us if you have any questions regarding your report(s) or invoice.

Sincerely,

A. Tran-Le
Lab Manager

CA ELAP Certification #3036

Allen site



1160 Chess Dr. Suite- 5
Foster City, CA 94404
Ph. (650)372-9456
Fax (650) 372-9469
License # 801472

Items

Line Number: 1


Item: Project Documents

Copies: 1

Date: 8/9/2022

Reference No: ALL CAL DISINFECTANT Certification of Disinfection

Description: 2022-08-09 ALL CAL DISINFECTANT Certification of Disinfection



1160 Chess Dr. Suite- 5
 Foster City, CA 94404
 Ph. (650)372-9456
 Fax (650) 372-9469
 License # 801472

Release Transmittal

21-324 — Allen Elementary School LLB Subject : ALL CAL DISINFECTANT Certification of Disinfection

To Anthony Riley
 BHM Construction Inc
 Attn: Anthony Riley
 221 Gateway Road W, Suite 405
 Napa, CA 94558
 Phone No: 707-643-4580
 Mobile: 707-761-7271
 Fax No: 707- 643-4581
 AnthonyR@bhmconstruction.com

Contract No: 203
Transmittal Number : 21-324-16
 Spec Section No :
 Date Sent : 8/9/2022
 Type : Original Release
 Transmittal
 Method Sent : Email
 Reason For Sending : For Release
 Status : To Be Submitted
 PO No :
 Release No : 3

Return To Juan Zamora
 Dinelli Plumbing Incorporated
 Attn: JUAN ZAMORA
 1160 Chess Drive, Suite 5
 Foster City, CA 94404
 Phone No: 650-372-9456
 Fax No: 650-372-9469
 juanz@dinelliplumbing.com

Copy To

Details

Line No	Item	Copies	Date	Reference No	Description
001	Project Documents	1	8/9/2022	ALL CAL DISINFECTANT Certification of Disinfection	2022-08-09 ALL CAL DISINFECTANT Certification of Disinfection
002	Project Documents	1	8/9/2022	49ER Water Analysis Report Order #9785	2022-08-07 49ER Water Analysis Report Order #9785

Notes

ALL CAL DISINFECTANT Certification of Disinfection

Signed By: _____

Dated: 8/9/2022

ALL CAL

DISINFECTANT

1486 South Meridian Road, Meridian CA 95957

www.allcaldisinfectant.com

916-663-2916 OFFICE

Lic # 1001808 A, C-36 – Disinfection Cert # 9111-1 DPR Lic # 143998

DIR # 1000027450

Certification of Disinfection

Date: 08/09/22

Sample taken by: Karen Rutledge

Location: Allen Elementary School
875 West Angus Ave
San Bruno, CA

Disinfection has been completed per AWWA C651. We then collected samples at **(See lab #9785)** The samples have been delivered to a State Certified Lab and were analyzed using the **Colilert Test Method** for the presence of **Coliform Bacteria** by a State Certified Microbiologist. Please see attached lab result sheets. The samples test results were **ABSENT**.

For questions regarding the testing, please contact **49er Water (209) 418-3175**



Karen Rutledge
Licensed Plumbing Contractor / Applicators



1160 Chess Dr. Suite- 5
Foster City, CA 94404
Ph. (650)372-9456
Fax (650) 372-9469
License # 801472

Items

Line Number: 2

Item: Project Documents

Copies: 1

Date: 8/9/2022

Reference No: 49ER Water Analysis Report Order #9785

Description: 2022-08-07 49ER Water Analysis Report Order #9785