

**Lead and Copper - 90<sup>th</sup> PERCENTILE COMPLIANCE Report**

(For Systems Required to Collect 5 Samples)

**I. PWS INFORMATION:** Please refer to your MassDEP Lead & Copper sampling plan for approved sampling locations.PWS ID #: **1263003**City / Town: **SAVOY**PWS Name: **Savoy Elementary School**PWS Class: **COM** ☐ **NTNC** ☒Sampling  
Frequency:  
(choose one)☒ FIRST SEMI-ANNUAL SAMPLING PERIOD☐ REDUCED - EVERY THREE YEARS☐ SECOND SEMI-ANNUAL SAMPLING PERIOD☐ LEAD SERVICE LINE (LSL) REPLACEMENT PROGRAM☐ REDUCED - ANNUAL☐ DEMONSTRATION

**Step 1:** Place *lead* results in ascending order (from lowest to highest value) with lowest value at # 1, in the table below. Repeat for copper results. Please report results that are ND or less than (<) the laboratory's reported detection limit (MDL) as zero. Results at or above the laboratory's detection limit (MDL) but below 0.005 mg/L for lead or 0.05 mg/L for copper shall be reported as measured or may be reported as 0.0025 mg/L for lead or 0.025 mg/L for copper.

**Step 2:** Take the average of the 4<sup>th</sup> and 5<sup>th</sup> highest sample results. This is your 90<sup>th</sup> percentile sample value.

**Step 3:** Compare the 90th percentile value against the corresponding action level. If the 90th percentile value is higher than the action level, then you have an exceedance and are required to contact MassDEP as soon as possible for information on compliance actions.

Note: If you collected more than 5 samples you must use the 90<sup>th</sup> Percentile Compliance Report form for more than 5 samples (Form LCR-D). Remember, within 30 days of receipt, you must send individual results to the persons served at each sampled location as per 310 CMR 22.06B(6)(c)<sup>1</sup>.

LEAD RESULTS (mg/L)		COPPER RESULTS (mg/L)	
#	All results for sampling period	#	All results for sampling period
1*	0	1*	0.0296
2	0	2	0.0307
3	0	3	0.0318
4	0.0010	4	0.0379
5	0.0019	5	0.191

**\*Lowest Value**

My system was required to collect **five** lead and copper samples. My system collected 5 lead and copper samples.

Circle 4<sup>th</sup> and 5<sup>th</sup> highest sample results above, then average the 4<sup>th</sup> and 5<sup>th</sup> highest sample results as follows:

$$\frac{(\text{Value of 4th highest result} + \text{Value of the 5th highest result})}{2} = 90^{\text{th}} \text{ Percentile Value}$$

<b>0.00145</b> (Lead 90 <sup>th</sup> percentile value)	Compared to <b>0.015 mg/L</b> (The lead action level)	<b>0.11445</b> (Copper 90 <sup>th</sup> percentile value)	Compared to <b>1.3 mg/L</b> (The copper action level)
--	--	--	--

**II. CERTIFICATION:**

Check and complete the correct statement for lead as determined by the above results. If you have an exceedance and you are a community system you must comply with the Consumer Confidence Rule (CCR) reporting requirements in accordance with 310 CMR 22.16A(4)(i)6.

☒ My system was **at or below** the lead action level.

☐ My system **exceeded** the lead action level and \_\_\_\_\_ sampling sites **exceeded** the lead action level.

(Insert # of samples)

Check and complete the correct statement for copper as determined from the above results. If you have an exceedance and you are a community system you must comply with the Consumer Confidence Rule (CCR) reporting requirements in accordance with 310 CMR 22.16A(4)(i)6.

☒ My system was **at or below** the copper action level.

☐ My system **exceeded** the copper action level and \_\_\_\_\_ sampling sites **exceeded** the copper action level.

(Insert # of samples)

*My signature below indicates that all sampling sites on this report have been previously approved in writing by the DEP, and both the sites and sampling procedures used comply with 310 CMR 22.06B(7). I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.*

Operator

Title

Signature of PWS or Owner's Representative

4/27/2023

Date

Please submit Form LCR-C along with this form.

Rev.02- 2019

Page 1 of 1

<sup>1</sup> The Consumer notification form template is available at: [https://www.mass.gov/lists/lead-and-copper-forms-and-templates#lead-and-copper-rule-\(lcr\)-](https://www.mass.gov/lists/lead-and-copper-forms-and-templates#lead-and-copper-rule-(lcr)-)