

Alex Rodriguez
Director of Facilities III

September 20, 2022

Dear Parents, Guardians and Staff:

On September 6, 2016, Governor Cuomo signed new legislation requiring the testing of drinking water in New York Schools for lead levels. As a result of this legislation, we contacted the Oneida-Herkimer- Madison BOCES Safety Office and requested testing of applicable water fixtures for lead. The Safety Office is providing a full, comprehensive report of the sampling program, which includes a building survey of source locations, sampling, reporting, and follow-up assistance.

There were 43 water fixtures (drinking fountains, bubblers) tested at the Denti building on 7/12//2022. Of the 43 samples 1 showed lead levels at or above the allowable 15 ppb (parts per billion).

Sincerely,

A handwritten signature in blue ink, appearing to read 'Alex Rodriguez', with a long, sweeping flourish extending to the right.