

July 18, 2022

Patricia Cerio
Oneida-Herkimer-Madison BOCES
4747 Middle Settlement Road
Supervisor of Safety Services
New Hartford, NY 13413

RE: Project: ROME CSD - DENTI 7/7
Pace Project No.: 70221744

Dear Patricia Cerio:

Enclosed are the analytical results for sample(s) received by the laboratory on July 12, 2022. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Kimberley M. Mack
kimberley.mack@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Connor Utesch, Oneida-Herkimer-Madison BOCES



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: ROME CSD - DENTI 7/7

Pace Project No.: 70221744

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ROME CSD - DENTI 7/7
Pace Project No.: 70221744

Sample: DEN13	Lab ID: 70221744001	Collected: 07/07/22 07:24	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		07/15/22 22:13	7439-92-1	
Sample: DEN14	Lab ID: 70221744002	Collected: 07/07/22 07:28	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		07/15/22 22:17	7439-92-1	
Sample: DEN15	Lab ID: 70221744003	Collected: 07/07/22 07:29	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 22:18	7439-92-1	
Sample: DEN16	Lab ID: 70221744004	Collected: 07/07/22 07:30	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.4	ug/L	1.0	1		07/15/22 22:19	7439-92-1	
Sample: DEN17	Lab ID: 70221744005	Collected: 07/07/22 07:32	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 22:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ROME CSD - DENTI 7/7
Pace Project No.: 70221744

Sample: DEN18	Lab ID: 70221744006	Collected: 07/07/22 07:34	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		07/15/22 22:22	7439-92-1	
Sample: DEN14	Lab ID: 70221744007	Collected: 07/07/22 07:26	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		07/15/22 22:23	7439-92-1	
Sample: DEN04	Lab ID: 70221744008	Collected: 07/07/22 08:07	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		07/15/22 22:24	7439-92-1	
Sample: DEN39	Lab ID: 70221744009	Collected: 07/07/22 08:07	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 22:26	7439-92-1	
Sample: DEN22	Lab ID: 70221744010	Collected: 07/07/22 07:40	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 22:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ROME CSD - DENTI 7/7
Pace Project No.: 70221744

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN12		Lab ID: 70221744011	Collected: 07/07/22 07:22	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.1	ug/L	1.0	1		07/15/22 22:36	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN11		Lab ID: 70221744012	Collected: 07/07/22 07:20	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/15/22 22:40	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN10		Lab ID: 70221744013	Collected: 07/07/22 07:18	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		07/15/22 22:41	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN07		Lab ID: 70221744014	Collected: 07/07/22 07:44	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.3	ug/L	1.0	1		07/15/22 22:43	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN01		Lab ID: 70221744015	Collected: 07/07/22 07:02	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/15/22 22:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ROME CSD - DENTI 7/7

Pace Project No.: 70221744

Sample: DEN02	Lab ID: 70221744016	Collected: 07/07/22 07:04	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 22:48	7439-92-1	
Sample: DEN03	Lab ID: 70221744017	Collected: 07/07/22 07:06	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 22:49	7439-92-1	
Sample: DEN41	Lab ID: 70221744018	Collected: 07/07/22 08:13	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 22:51	7439-92-1	
Sample: DEN05	Lab ID: 70221744019	Collected: 07/07/22 07:12	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.6	ug/L	1.0	1		07/15/22 22:52	7439-92-1	
Sample: DEN06	Lab ID: 70221744020	Collected: 07/07/22 08:21	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.3	ug/L	1.0	1		07/15/22 22:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ROME CSD - DENTI 7/7
Pace Project No.: 70221744

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN40		Lab ID: 70221744021	Collected: 07/07/22 08:08	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.8	ug/L	1.0	1		07/15/22 22:55	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN09L		Lab ID: 70221744022	Collected: 07/07/22 07:17	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/15/22 22:56	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN42		Lab ID: 70221744023	Collected: 07/07/22 08:15	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/15/22 22:57	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN43		Lab ID: 70221744024	Collected: 07/07/22 08:16	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/15/22 22:59	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN37		Lab ID: 70221744025	Collected: 07/07/22 08:03	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/15/22 23:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ROME CSD - DENTI 7/7
Pace Project No.: 70221744

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN34		Lab ID: 70221744026	Collected: 07/07/22 07:58	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/15/22 23:04	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN33		Lab ID: 70221744027	Collected: 07/07/22 07:56	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		07/15/22 23:05	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN32		Lab ID: 70221744028	Collected: 07/07/22 07:55	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/15/22 23:07	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN31		Lab ID: 70221744029	Collected: 07/07/22 07:53	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	35.8	ug/L	1.0	1		07/15/22 23:08	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN30		Lab ID: 70221744030	Collected: 07/07/22 07:52	Received: 07/12/22 10:30	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.4	ug/L	1.0	1		07/15/22 23:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ROME CSD - DENTI 7/7

Pace Project No.: 70221744

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN26	Lab ID: 70221744031	Collected: 07/07/22 07:47	Received: 07/12/22 10:30	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:16	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN25	Lab ID: 70221744032	Collected: 07/07/22 07:46	Received: 07/12/22 10:30	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:22	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN24	Lab ID: 70221744033	Collected: 07/07/22 07:44	Received: 07/12/22 10:30	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		07/15/22 23:23	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN23	Lab ID: 70221744034	Collected: 07/07/22 07:42	Received: 07/12/22 10:30	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:25	7439-92-1	

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: DEN38	Lab ID: 70221744035	Collected: 07/07/22 08:04	Received: 07/12/22 10:30	Matrix: Drinking Water				
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.7	ug/L	1.0	1		07/15/22 23:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ROME CSD - DENTI 7/7

Pace Project No.: 70221744

Sample: DEN35	Lab ID: 70221744036	Collected: 07/07/22 08:00	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:27	7439-92-1	

Sample: DEN36	Lab ID: 70221744037	Collected: 07/07/22 08:01	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:29	7439-92-1	

Sample: DEN27	Lab ID: 70221744038	Collected: 07/07/22 07:49	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:30	7439-92-1	

Sample: DEN28	Lab ID: 70221744039	Collected: 07/07/22 07:50	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:31	7439-92-1	

Sample: DEN29	Lab ID: 70221744040	Collected: 07/07/22 07:51	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: ROME CSD - DENTI 7/7

Pace Project No.: 70221744

Sample: DEN20	Lab ID: 70221744041	Collected: 07/07/22 08:19	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:36	7439-92-1	

Sample: DEN21	Lab ID: 70221744042	Collected: 07/07/22 08:20	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:38	7439-92-1	

Sample: DEN08	Lab ID: 70221744043	Collected: 07/07/22 07:16	Received: 07/12/22 10:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/15/22 23:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ROME CSD - DENTI 7/7
Pace Project No.: 70221744

QC Batch: 265095 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70221744001, 70221744002, 70221744003, 70221744004, 70221744005, 70221744006, 70221744007, 70221744008, 70221744009

METHOD BLANK: 1339651 Matrix: Water
Associated Lab Samples: 70221744001, 70221744002, 70221744003, 70221744004, 70221744005, 70221744006, 70221744007, 70221744008, 70221744009

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	07/15/22 21:49	

LABORATORY CONTROL SAMPLE: 1339652

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	47.1	94	85-115	

MATRIX SPIKE SAMPLE: 1339654

Parameter	Units	70221742022 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.1	50	59.6	117	70-130	

MATRIX SPIKE SAMPLE: 1339656

Parameter	Units	70221742023 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	72.0	143	70-130	M1

SAMPLE DUPLICATE: 1339653

Parameter	Units	70221742022 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.1	1.0	9	

SAMPLE DUPLICATE: 1339655

Parameter	Units	70221742023 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ROME CSD - DENTI 7/7
Pace Project No.: 70221744

QC Batch:	265097	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70221744010, 70221744011, 70221744012, 70221744013, 70221744014, 70221744015, 70221744016, 70221744017, 70221744018, 70221744019, 70221744020, 70221744021, 70221744022, 70221744023, 70221744024, 70221744025, 70221744026, 70221744027, 70221744028, 70221744029

METHOD BLANK: 1339657 Matrix: Water
Associated Lab Samples: 70221744010, 70221744011, 70221744012, 70221744013, 70221744014, 70221744015, 70221744016, 70221744017, 70221744018, 70221744019, 70221744020, 70221744021, 70221744022, 70221744023, 70221744024, 70221744025, 70221744026, 70221744027, 70221744028, 70221744029

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	07/15/22 22:27	

LABORATORY CONTROL SAMPLE: 1339658

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.9	94	85-115	

MATRIX SPIKE SAMPLE: 1339660

Parameter	Units	70221744010 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	56.7	113	70-130	

MATRIX SPIKE SAMPLE: 1339662

Parameter	Units	70221744011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.1	50	58.3	110	70-130	

SAMPLE DUPLICATE: 1339659

Parameter	Units	70221744010 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1339661

Parameter	Units	70221744011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.1	3.0	4	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: ROME CSD - DENTI 7/7
Pace Project No.: 70221744

QC Batch: 265098 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70221744030, 70221744031, 70221744032, 70221744033, 70221744034, 70221744035, 70221744036, 70221744037, 70221744038, 70221744039, 70221744040, 70221744041, 70221744042, 70221744043

METHOD BLANK: 1339663 Matrix: Water
Associated Lab Samples: 70221744030, 70221744031, 70221744032, 70221744033, 70221744034, 70221744035, 70221744036, 70221744037, 70221744038, 70221744039, 70221744040, 70221744041, 70221744042, 70221744043

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	07/15/22 23:09	

LABORATORY CONTROL SAMPLE: 1339664

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.3	97	85-115	

MATRIX SPIKE SAMPLE: 1339666

Parameter	Units	70221744030 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.4	50	55.5	104	70-130	

MATRIX SPIKE SAMPLE: 1339668

Parameter	Units	70221744031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	64.6	128	70-130	

SAMPLE DUPLICATE: 1339665

Parameter	Units	70221744030 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.4	3.1	7	

SAMPLE DUPLICATE: 1339667

Parameter	Units	70221744031 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: ROME CSD - DENTI 7/7

Pace Project No.: 70221744

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ROME CSD - DENTI 7/7

Pace Project No.: 70221744

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70221744001	DEN13	EPA 200.8	265095		
70221744002	DEN14	EPA 200.8	265095		
70221744003	DEN15	EPA 200.8	265095		
70221744004	DEN16	EPA 200.8	265095		
70221744005	DEN17	EPA 200.8	265095		
70221744006	DEN18	EPA 200.8	265095		
70221744007	DEN14	EPA 200.8	265095		
70221744008	DEN04	EPA 200.8	265095		
70221744009	DEN39	EPA 200.8	265095		
70221744010	DEN22	EPA 200.8	265097		
70221744011	DEN12	EPA 200.8	265097		
70221744012	DEN11	EPA 200.8	265097		
70221744013	DEN10	EPA 200.8	265097		
70221744014	DEN07	EPA 200.8	265097		
70221744015	DEN01	EPA 200.8	265097		
70221744016	DEN02	EPA 200.8	265097		
70221744017	DEN03	EPA 200.8	265097		
70221744018	DEN41	EPA 200.8	265097		
70221744019	DEN05	EPA 200.8	265097		
70221744020	DEN06	EPA 200.8	265097		
70221744021	DEN40	EPA 200.8	265097		
70221744022	DEN09L	EPA 200.8	265097		
70221744023	DEN42	EPA 200.8	265097		
70221744024	DEN43	EPA 200.8	265097		
70221744025	DEN37	EPA 200.8	265097		
70221744026	DEN34	EPA 200.8	265097		
70221744027	DEN33	EPA 200.8	265097		
70221744028	DEN32	EPA 200.8	265097		
70221744029	DEN31	EPA 200.8	265097		
70221744030	DEN30	EPA 200.8	265098		
70221744031	DEN26	EPA 200.8	265098		
70221744032	DEN25	EPA 200.8	265098		
70221744033	DEN24	EPA 200.8	265098		
70221744034	DEN23	EPA 200.8	265098		
70221744035	DEN38	EPA 200.8	265098		
70221744036	DEN35	EPA 200.8	265098		
70221744037	DEN36	EPA 200.8	265098		
70221744038	DEN27	EPA 200.8	265098		
70221744039	DEN28	EPA 200.8	265098		
70221744040	DEN29	EPA 200.8	265098		
70221744041	DEN20	EPA 200.8	265098		
70221744042	DEN21	EPA 200.8	265098		
70221744043	DEN08	EPA 200.8	265098		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY / Analyt
The Chain-of-Custody is a LEGAL DOCUMENT

WO#: 70221744



Section A Required Client Information: Company: OHM BOCES Address: 4747 Middle Settlement Rd, New Hartford NY, 13413 Email: pcerio@omeida-boces.org Phone: 315/939693 Requested Due Date: regular processing

Section B Required Project Information: Report To: Patty Cerio Copy To: Company Name: OHM BOCES Address: 4747 Middle Settlement Rd, New Hartford, NY 13413 Pace Quote: Pace Project Manager: Kimberley.Mack@Pacelabs.com Pace Profile #: NY

Section C Invoice Information: Attention: Patty Cerio Company Name: OHM BOCES Address: 4747 Middle Settlement Rd, New Hartford, NY 13413 Pace Quote: Pace Project Manager: Kimberley.Mack@Pacelabs.com Pace Profile #: NY

Of 4

Regulatory Agency

State / Location NY

ITEM #	MATRIX	MATRIX CODE (see valid codes to left)	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	SAMPLER TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES										ANALYSES TEST Y/N	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)
			START DATE	END DATE				H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other						
1	Drinking Water	DW	7/7/2022	7:24	DW G				X											
2	Waste Water	WW	7/7/2022	7:28	DW G				X											
3	Product	P	7/7/2022	7:29	DW G				X											
4	Oil	OL	7/7/2022	7:30	DW G				X											
5	Wipe	WP	7/7/2022	7:32	DW G				X											
6	Air	AR	7/7/2022	7:34	DW G				X											
7	Other	OT	7/7/2022	7:26	DW G				X											
8	Tissue	TS	7/7/2022	7:10	DW G				X											
9			7/7/2022	8:07	DW G				X											
10			7/7/2022	7:40	DW G				X											
11			7/7/2022	7:22	DW G				X											
12			7/7/2022	7:20	DW G				X											

RELIQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
Lisa Shanoud	7/11/22	16:50	Patricia Cerio	7/11/22	10:50	
Pat	7/11/22	17:00	Patricia Cerio	7/11/22	15:30	

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: Patricia Cerio

SIGNATURE of SAMPLER: *Patricia Cerio*

DATE Signed: 7/7/2022

Received on: _____

TEMP in C: _____

Ice (Y/N): _____

Sealed (Y/N): _____

Cooler (Y/N): _____

Samples Intact (Y/N): _____



Sample Condition Upon Rec

WO#: 70221744
PM: KMM **Due Date: 07/20/22**
CLIENT: OHM

Client Name: PLS

Courier: Fed Ex UPS USPS Client Commercial Pace Other
 Tracking #: 773 5453 0678
 Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No N/A
 Packing Material: Bubble Wrap Bubble Bags Ziploc None Other
 Thermometer Used: ~~TH091~~ TH148 Correction Factor: + 0.1
 Cooler Temperature(°C): 2.7 Cooler Temperature Corrected(°C): 2.8
 Temp should be above freezing to 6.0°C
 USDA Regulated Soil N/A, water sample

Temperature Blank Present: Yes No
 Type of Ice: Wet Blue None
 Samples on ice, cooling process has begun
 Date/Time 5035A kits placed in freezer

Date and Initials of person examining contents: KW Pich

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No
 Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

				COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		7.
Sufficient Volume: (Triple volume provided for I)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		8.
Correct Containers Used:	<input type="checkbox"/> Yes	<input type="checkbox"/> No		9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		12.
-Includes date/time/ID, Matrix: SL <u>WT/OIL</u>				
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>HC281827</u>				Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis				
Samples checked for dechlorination: KI starch test strips Lot #	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #				
SM 4500 CN samples checked for sulfide? Lead Acetate Strips Lot #	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):				

Client Notification/ Resolution: _____ Field Data Required? Y / N
 Person Contacted: _____ Date/Time: _____
 Comments/ Resolution: _____

04M BOCES
 4747 Middle Settlement Rd
 New Hartford, CT

7/7/22

BLDG - DENTI

Date:	ROOM # / NAME	Sample ID	Time of Sampling	BUBBLER
	102	DEN13	7:24	X
	103	DEN14	7:28	X
	104	DEN15	7:29	X
	105	DEN16	7:30	X
	106	DEN17	7:32	X
	107	DEN18	7:34	X
	109	DEN14	7:26	X
	STAFF ROOM (SINK)	DEN04	7:10	SINK
	125/NURSE	DEN39	8:07	X
	CAFETERIA	DEN22	7:40	X
	130	DEN12	7:22	X
	131	DEN11	7:20	X
	132	DEN10	7:18	X
	133	DEN07	7:44	X
	134	DEN01	7:02	X
	135	DEN02	7:04	X
	136	DEN03	7:06	X
	137	DEN41	8:13	X
	138	DEN05	7:12	X
	139	DEN06	8:21	X
	149	DEN40	8:08	X
	ACROSS FROM 132	DEN08 - HIGH	7:16	X
	ACROSS FROM 132	DEN09L - LOW	7:17	X
	150 - SINK	DEN42 - HIGH	8:15	SINK
	150 - SINK	DEN43 - LOW	8:16	SINK
	151	DEN37	8:03	X
	152	DEN34	7:58	X
	153	DEN33	7:56	X
	154	DEN32	7:55	X
	155	DEN31	7:53	X
	156	DEN30	7:52	X

157	DEN26	7:47	X
158	DEN25	7:46	X
159	DEN24	7:44	X
160	DEN23	7:42	X
163	DEN38	8:04	X
ACROSS FROM 152	DEN35 - HIGH	8:00	X
ACROSS FROM 152	DEN36 - LOW	8:01	X
ACROSS FROM 157	DEN27 - HIGH	7:49	X
ACROSS FROM 157	DEN28 - LOW	7:50	X
ACROSS FROM 157	DEN29	7:51	BOT FILL
BY 110	DEN20	8:19	X
BY110	DEN21	8:20	X

Total

43