



Addendum 1

January 26, 2022

Solicitation #	2021-2022-11
Description	Multi-Purpose Retractable Partition Walls
Date Issued	January 12, 2022
Question Deadline	January 25, 2022
Response Deadline	January 26, 2022
Submit Proposal By	February 9, 2022

THE DISTRICT HAS DECIDED TO EXTEND THE PROPOSAL DUE DATE TO **FEBRUARY 9, 2022 @ 2:00 PM, EST** DUE TO ADDING ADDITIONAL OPTIONS.

Questions submitted and responses listed below as follows:

1. I've been looking over the bid information and I have one concern and question. You are requiring that the new partitions be put on the existing track. The existing track's manufactures are both out of business. Limestone-Central and Northwest both have Panelfold track and Grassy Pond have EMCO. We could possibly find the Panelfold trolleys as they have been out of business only a couple of years. The EMCO trolleys are no longer available as they as they have been out of business for over 20 years. It may be possible to put the old trolleys onto the new panels but I would really have to do more investigating and wouldn't advise to do that. In any case, we could not warranty the track or the trolleys.

Response: We would like for the new partition walls to be installed on the existing track, but we are open to additional options that include replacing the existing track. We have added two other options and revised the bidding schedule to reflect those additions. **VENDORS MUST USE THE ATTACHED BIDDING SCHEDULE TO SUBMIT THEIR BID.**

Heather Maples
Procurement Coordinator

These specifications are in addition to the original specifications.

Option 3:

- Installation of partition wall at Grassy Pond Elementary, Limestone Central Elementary, and Northwest Elementary.
- Opening not to exceed 63' 4 ½" W x 9' 4 ½" H
- Manually Operated individual panels
- A sound transmission class (STC) rating of 51
- Top and bottom retractable seals
- Unfinished panel faces *
- Install new aluminum track system *

- Removal and disposal of old partitions
- Remove, replace, and paint soffit around track (District to provide paint)
- Prime and paint new partitions (District to provide paint)

- Wall must meet or exceed fire retardant rating approved by the Office of School Facilities (OSF)

- Vendor must provide a detailed cut sheet to summarize the information and characteristics of the retractable partition wall with their signed bid. **The cut sheet MUST state the fire retardant rating.**

Option 4:

- Installation of partition wall at Grassy Pond Elementary, Limestone Central Elementary, and Northwest Elementary.
- Opening not to exceed 63' 4 ½" W x 9' 4 ½" H
- Manually Operated individual panels
- A sound transmission class (STC) rating of 51
- Top and bottom retractable seals
- 22ga steel face with a 21 oz. vinyl finish *
- Install new aluminum track system *

- Removal and disposal of old partitions
- Remove, replace, and paint soffit around track (District to provide paint)
- Prime and paint new partitions (District to provide paint)

- Wall must meet or exceed fire retardant rating approved by the Office of School Facilities (OSF)

- Vendor must provide a detailed cut sheet to summarize the information and characteristics of the retractable partition wall with their signed bid. **The cut sheet MUST state the fire retardant rating.**

CONTINUED ONTO NEXT PAGE

Grassy Pond Elementary	
Retractable Partition Wall – Option 1	\$
Retractable Partition Wall – Option 2	\$
Retractable Partition Wall – Option 3	\$
Retractable Partition Wall – Option 4	\$
PRICE MUST INCLUDE FREIGHT, REMOVAL AND DISPOSAL OF OLD PARTITION, AND INSTALLATION	

Limestone-Central Elementary	
Retractable Partition Wall – Option 1	\$
Retractable Partition Wall – Option 2	\$
Retractable Partition Wall – Option 3	\$
Retractable Partition Wall – Option 4	\$
PRICE MUST INCLUDE FREIGHT, REMOVAL AND DISPOSAL OF OLD PARTITION, AND INSTALLATION	

Northwest Elementary	
Retractable Partition Wall – Option 1	\$
Retractable Partition Wall – Option 2	\$
Retractable Partition Wall – Option 3	\$
Retractable Partition Wall – Option 4	\$
PRICE MUST INCLUDE FREIGHT, REMOVAL AND DISPOSAL OF OLD PARTITION, AND INSTALLATION	

Grand Total – Option 1	\$
Grand Total – Option 2	\$
Grand Total – Option 3	\$
Grand Total – Option 4	\$

Additional Options	
Adding a Pass Door to Partition Wall	\$

BIDDER’S STATEMENT OF ASSURANCES AND COMPLIANCES

The Undersigned, as a responsive bidder, certifies that the General and Special Conditions of this bid have been read and understood.

The Bidder hereby provides assurance that the firm represented in this bid as indicated below:

1. Will comply with all requirements, stipulations, terms, and conditions as stated in the bid document; and
2. Is not guilty of collusion with other vendors possibly interested in this bid, in arriving at or determining prices to be submitted; and
3. That such agent, as indicated below, is officially authorized to represent the firm in whose name the bid is submitted.

Name of Firm:	
Signature of Agent:	
Printed Name:	
Title:	
Date:	

VENDOR MUST PROVIDE A DETAILED CUT SHEET TO SUMMARIZE THE INFORMATION AND CHARACTERISTICS OF THE RETRACTABLE PARTITION WALL WITH THEIR SIGNED BID.

THE CUT SHEET MUST STATE THE FIRE RETARDANT RATING.