



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, New Jersey 07836
973-927-7303
973-927-4980 fax

www.radata.com

13 May 2016

John P Holland Charter School
Christine Scano
190 Oliver Street
Paterson NJ 07501

PROPERTY LOCATION:

190 Oliver Street
Patterson City, Passaic County, New Jersey

WATER ANALYSIS REPORT

*Enclosed please find the water analysis report from the lab for the above listed property. As indicated on the report all parameters tested **DO** comply to NJ DEP Drinking Water standards. Samples are drawn at established sample sizes noted in milliliters (ml) and compared by the lead content reported in parts per billion (ppb). Please review the reports carefully and feel free to contact our office if you have any questions.

The following parameters were tested for in the 2nd Quarter of 2016:

Sample location	Sample size	Action level	Result
1 st draw sinks	1000 ml	15 ppb	<4.00 ppb
1 st draw fountains	250 ml	15 ppb	< 4.00 – 7.89 ppb
2 nd Draw sample	250 ml	15 ppb	< 4.00 ppb
Source water sample	250 ml	5 ppb	< 4.00 ppb

NOTE: These sample results only represent the faucets from which water samples were collected. To know the lead risk from other faucets similar water samples should be collected and analyzed for lead from each faucet.

** Indicates parameters that **DO NOT** meet NJ-DEP Drinking water standards