


ADDENDUM #2

November 19, 2019

TRANSMITTED VIA EMAIL: 2 pages

TO: ALL PLAN HOLDERS AND POTENTIAL BIDDERS
FROM: TIFFANY McCANTS, PURCHASING OFFICER 
SUBJECT: C.D. OWEN HIGH SCHOOL MEDIA CENTER DEHUMIDIFICATION
(RFP# 34-19)

The following specifications and drawings are hereby made a part of the original documents. Bidders shall acknowledge receipt of this addendum by notation in the space provided on the Proposal Form.

Addendum includes: Request for high, insulated curb and new "bid due" date.

Addendum #2
RFP# 34-19

Sud Associates, P.A.

Consulting Engineers

Flat Iron Building, Suite 706, 20 Battery Park Avenue, Asheville, NC 28801
(828) 255-4691 • Fax: (828) 255-4949

Ish Sud, Ph.D., P.E., President
Fellow ASHRAE, LEED AP

Jerome C. Hay, P.E.
Vice President, LEED AP

**MEDIA CENTER DEHUMIDIFICATION
OWEN HIGH SCHOOL
BUNCOMBE COUNTY SCHOOLS**

ADDENDUM #2

November 19, 2019

1. Provide 16" high, insulated curb for the rooftop dehumidification unit.
2. The bid date has been postponed. Bids shall be received by December 4th at 4:00 PM.
3. All Contractors submitting proposals shall incorporate the items in this Addendum, and all other addenda into their proposals, and acknowledge receipt of the Addenda on their bid proposal forms.