


ADDENDUM #1

June 28, 2019

TRANSMITTED VIA EMAIL: 3 pages

TO: ALL PLAN HOLDERS AND POTENTIAL BIDDERS
FROM: TIFFANY McCANTS, PURCHASING OFFICER 
SUBJECT: NORTH BUNCOMBE ELEMENTARY SCHOOL BOILER REPLACEMENT
(RFP# 25-19)

The following specifications and drawings are hereby made a part of the original documents. Bidders shall acknowledge receipt of this addendum by notation in the space provided on the Proposal Form.

Addendum includes: New details from BCS Maintenance Department about project and sign-in sheet from Pre-Bid meeting on Wednesday, 6/26/19.

Addendum #1
RFP# 25-19



ADDENDUM to RFP# 25-19
Replace boiler at North Buncombe Elementary School

1. Relocate the expansion tank for the domestic Hot water back to the adjacent wall to allow for more clearance for the new boiler's water and vent piping.

End of Addendum

HVAC Contractor Sign in

Date: 6-26-2019

Buncombe County Schools Maintenance Dept.

Boiler Replacement

Name	Company	Phone	Email address
Hunter Owen	Hdm	776-5908	Hower@mbhaznes.com
Mitch Green	WWD	888-759-3874	MITCHELL.GREEN@WWDCLT.COM
CHRIS DILLINGER	PROTEC	273-4117	chris@protecindustrial.com CHRIS.DILLINGER@PROTECINDUSTRIAL.COM
Mike Rice	Bolton Const	253 3621 EX 6104	mikerice@webolton.com
Mike Halliger	Masters	273-2864	mastersmechinc@aol.com
Bill Kenstner	RYATT	925-1688	Email @ pyatt h clyde net

Addendum move Expansions TANK
Power PPE
w/oh