

ADDENDUM NUMBER FOUR

**T C ROBERSON HIGH SCHOOL CAFETERIA, PEP, AND POOL ROOF REPLACEMENTS
BUNCOMBE COUNTY SCHOOLS
RFP 12-16**

MLA PROJECT NUMBER: 16001

Mark Lusk Architecture, PLLC
120 Wedgewood Drive
Morganton, NC 28655
(843) 801-1775

DATE OF ISSUE: May 2, 2016

TO: ALL BIDDERS OF RECORD

This Addendum modifies the Contract Documents only in the manner and to the extent stated herein and shown on any accompanying drawings and will become a part of the Contract Documents. Except as specified or otherwise indicated by this Addendum, all work shall be in accordance with the basic requirements of the Contract Documents.

BIDDERS SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM ON BID FORM.

This Addendum consists of one page(s) and any enclosures noted:

I. ENCLOSURES:

1. None

II. GENERAL INFORMATION / CLARIFICATIONS:

1. A201 Roof Plan Legend and Addendum #2: CLARIFICATION: The scope of work for the mechanical unit and cooking exhaust hood marked "M" noted at Roof 19 at the Kitchen shall be bid by the mechanical contractors and is NOT included as an allowance

III. CHANGES TO PROJECT MANUAL:

1. 075423-2.4: Polyisocyanurate insulation shall be Type II in lieu of Type VII with coated glass mat facers. There shall be no cellulose content. Maximum board size shall be 4' x 4' for adhered boards and 4' x 8' boards for mechanically attached boards.

IV. CHANGES TO DRAWINGS:

1. None

END OF ADDENDUM