

ADDENDUM NO. 3

BUNCOMBE COUNTY SCHOOLS
ERWIN HIGH SCHOOL E-WING ROOF REPLACEMENT
ASHEVILLE, NORTH CAROLINA

Cort Architectural Group, P. A.
239 Haywood Street
Asheville, North Carolina 28801

March 1, 2012

ITEMS WHICH AFFECT THE PROVISIONS OF THE CONTRACT ARE AS FOLLOWS:

The following changes, additions and/or clarifications to the Advertisement, Plans and/or Specifications are hereby made a part of the original documents. All Contractors (Bidders) shall acknowledge receipt of this Addendum by notation in the space provided on the Form of Proposal.

Item 1: Refer to General Note No. 1 on Sheet 103 of the Drawings. Add the following:

All electrical conduits, refrigerant lines, condensate pipes, and all other piping shall be supported using "MIFAB CE-Extension Series" supports or an approved equal. Wood supports are not acceptable.

END OF ADDENDUM NO. 3