

Oregon Health Authority
District Lead Testing Fixture Report 2016

November 22, 2016

School District Name: Helix School District
Dist ID: 2201

Building Name:	Fixture Location/Description	Fixture Use	Date of Test	Sample Result mg/L
Griswold HS	Main Gym Fountain	Drinking	6/30/2016	ND
Griswold HS	HS 1st Floor Fountain	Drinking	6/30/2016	ND
Helix MS	MS Hall Fountain	Drinking	6/30/2016	ND
Griswold HS	Weight Room Fountain	Drinking	6/30/2016	ND
Griswold HS	Main Gym Foyer Fountain	Drinking	6/30/2016	ND
Griswold HS	HS 2nd Floor Fountain	Drinking	6/30/2016	ND
Griswold HS	Kitchen Sink	Food Prep	6/30/2016	0.00628
Griswold HS	Band Room Fountain	Drinking	8/31/2016	0.00148
Griswold HS	Woodshop Fountain	Drinking	8/31/2016	0.00739
Helix Elem	Elementary Hall Fountain	Drinking	8/31/2016	ND
Helix Elem	Kindergarten Fountain	Drinking	10/5/2016	0.00108
Helix Elem	1st Grade Fountain	Drinking	10/5/2016	ND
Helix Elem	2nd Grade Fountain	Drinking	10/5/2016	ND
Helix Elem	3rd Grade Fountain	Drinking	10/5/2016	0.00119
Helix Elem	4th Grade Fountain	Drinking	10/5/2016	ND
Helix Elem	5th Grade Fountain	Drinking	10/5/2016	ND
Helix Elem	6th Grade Fountain	Drinking	10/5/2016	ND
Helix Elem	7th Grade Fountain	Drinking	10/5/2016	ND
Helix Elem	8th Grade Fountain	Drinking	10/5/2016	0.0014
Helix Elem	Faculty Rm Sink	Other Human Consumption	10/5/2016	ND

MCL (Maximum Contaminant Level) for Lead is 0.020 mg/L
MDL (Method Detection Limit) is 0.001 mg/L for Lead
ND = Analyte Not Detected
 All results in mg/L unless otherwise noted

