

Fair Lawn Public Schools

37-01 Fair Lawn Avenue, Fair Lawn, NJ

(201) 794-5500 x7090

Email: nnorcia@fairlawnschools.org

Nicholas J. Norcia
Superintendent of Schools

January 25, 2022

Warren Point Elementary School
30-07 Broadway
Fair Lawn, NJ 07410

Dear Warren Point Elementary School Community:

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Fair Lawn Public Schools tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Warren Point Elementary School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 $\mu\text{g/l}$ (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted and remediation measures have immediately been taken.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the twenty-six (26) samples taken, all but two (2) tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 $\mu\text{g/l}$ [ppb]).

The table below identifies the drinking water outlets that tested above the 15 $\mu\text{g/l}$ for lead, the actual lead level, and what temporary remedial action Fair Lawn Public Schools has taken to reduce the levels of lead at these locations.

<u>Sample Location</u>	<u>First Draw Result in $\mu\text{g/l}$ (ppb)</u>	<u>Remedial Action</u>
Room 30A ID # WPES-1-B-03A	24.0	Outlet immediately taken out of service.
Hall by 108 ID# WPES-1-WF-03A	16.0	Outlet immediately taken out of service.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under six years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

"THE LEADERS OF TOMORROW ATTEND FAIR LAWN SCHOOLS TODAY"

Fair Lawn Public Schools

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of six. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at https://fairlawnschools.org/apps/pages/index.jsp?uREC_ID=404232&type=d. For more information about water quality in our schools, contact **Harolina Menchon** at the **Fair Lawn Board of Education, 201-794-5500, Ext. 7001**.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at **www.epa.gov/lead**, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,



Nicholas J. Norcia
Superintendent of Schools

CERTIFICATE OF ANALYSIS

Client: Garden State Environmental, Inc.
555 S Broad St. Ste. K
Glen Rock NJ 07452

Report Date: 1/14/2022
Report No.: 650478 - Lead Water
Project: Fair Lawn: Warren Point ES
Project No.: 8345

Client: GAR373

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7342199 Location: Faculty Rm Result(ppb): <1.00
Client No.: WPES-0-S-01A * Sample acidified to pH <2.

Lab No.: 7342200 Location: Main Entrance (R) Result(ppb): 2.60
Client No.: WPES-1-WF-01A * Sample acidified to pH <2.

Lab No.: 7342201 Location: Main Entrance (L) Result(ppb): <1.00
Client No.: WPES-1-WF-02A * Sample acidified to pH <2.

Lab No.: 7342202 Location: Rm 114 Result(ppb): 2.90
Client No.: WPES-1-S-02A * Sample acidified to pH <2.

Lab No.: 7342203 Location: Hall By 116 Result(ppb): <1.00
Client No.: WPES-1-WC-01A * Sample acidified to pH <2.

Lab No.: 7342204 Location: Rm 116 Result(ppb): 11.8
Client No.: WPES-1-S-03A * Sample acidified to pH <2.


Lab No.: 7342205 Location: Rm 118 Result(ppb): 8.30
Client No.: WPES-1-S-04A * Sample acidified to pH <2.


Lab No.: 7342206 Location: Rm 109 Result(ppb): 2.60
Client No.: WPES-1-S-05A * Sample acidified to pH <2.

Lab No.: 7342207 Location: Rm 110 Result(ppb): 5.10
Client No.: WPES-1-S-06A * Sample acidified to pH <2.

Lab No.: 7342208 Location: Rm 107 Result(ppb): 12.0
Client No.: WPES-1-S-07A * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 1/12/2022
Date Analyzed: 01/14/2022
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Garden State Environmental, Inc.
555 S Broad St. Ste. K
Glen Rock NJ 07452

Report Date: 1/14/2022
Report No.: 650478 - Lead Water
Project: Fair Lawn: Warren Point ES
Project No.: 8345

Client: GAR373

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7342209 Location: Rm 108 Result(ppb): 7.80
Client No.: WPES-1-S-08A * Sample acidified to pH <2.

Lab No.: 7342210 Location: Rm 105 Result(ppb): 7.10
Client No.: WPES-1-S-09A * Sample acidified to pH <2.

Lab No.: 7342211 Location: Hall By 108 Result(ppb): 16.0
Client No.: WPES-1-WF-03A * Sample acidified to pH <2.

Lab No.: 7342212 Location: Hall By 108 Result(ppb): <1.00
Client No.: WPES-1-WC-02A * Sample acidified to pH <2.

Lab No.: 7342213 Location: Rm 106 Result(ppb): 1.50
Client No.: WPES-1-S-10A * Sample acidified to pH <2.

Lab No.: 7342214 Location: Rm 103 Result(ppb): 5.90
Client No.: WPES-1-S-11A * Sample acidified to pH <2.


Lab No.: 7342215 Location: Rm 104 Result(ppb): 1.90
Client No.: WPES-1-S-12A * Sample acidified to pH <2.


Lab No.: 7342216 Location: Rm 101 Kindergarten Result(ppb): <1.00
Client No.: WPES-1-B-01A * Sample acidified to pH <2.

Lab No.: 7342217 Location: Rm 103 Kindergarten Result(ppb): 2.10
Client No.: WPES-1-B-02A * Sample acidified to pH <2.

Lab No.: 7342218 Location: Rm 30A Result(ppb): 24.0
Client No.: WPES-1-B-03A * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 1/12/2022
Date Analyzed: 01/14/2022
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Garden State Environmental, Inc.
555 S Broad St. Ste. K
Glen Rock NJ 07452

Report Date: 1/14/2022
Report No.: 650478 - Lead Water
Project: Fair Lawn: Warren Point ES
Project No.: 8345

Client: GAR373

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7342219 Client No.: WPES-1-WF-04A	Location: Hall By 20A * Sample acidified to pH <2.	Result(ppb): 6.00
Lab No.: 7342220 Client No.: WPES-1-S-13A	Location: Rm 20A * Sample acidified to pH <2.	Result(ppb): 5.40
Lab No.: 7342221 Client No.: WPES-1-WF-05A	Location: Gym * Sample acidified to pH <2.	Result(ppb): 9.60
Lab No.: 7342222 Client No.: WPES-1-B-04A	Location: Rm 10A * Sample acidified to pH <2.	Result(ppb): 5.50
Lab No.: 7342223 Client No.: WPES-2-S-14A	Location: Rm 204 * Sample acidified to pH <2.	Result(ppb): 8.00
Lab No.: 7342224 Client No.: WPES-2-S-15A	Location: Rm 202 * Sample acidified to pH <2.	Result(ppb): 14.8
Lab No.: 7342225 Client No.: WPES-2021-FBA	Location: Field Blank * Sample acidified to pH <2.	Result(ppb): <1.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 1/12/2022
Date Analyzed: 01/14/2022
Signature:
Analyst: Mark Stewart

Approved By:
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Garden State Environmental, Inc.
555 S Broad St. Ste. K
Glen Rock NJ 07452

Client: GAR373

Report Date: 1/14/2022
Report No.: 650478 - Lead Water
Project: Fair Lawn: Warren Point ES
Project No.: 8345

Appendix to Analytical Report:

Customer Contact: Send ALL Lab Reports
Analysis: AAS-GF - ASTM D3559-08D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: wchampion@iatl.com
iATL Account Representative: Kelly Klippel
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B

- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB

CERTIFICATE OF ANALYSIS

Client: Garden State Environmental, Inc.
555 S Broad St. Ste. K
Glen Rock NJ 07452

Report Date: 1/14/2022
Report No.: 650478 - Lead Water
Project: Fair Lawn: Warren Point ES
Project No.: 8345

Client: GAR373

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.



9000 Commerce Parkway, Suite B • Mount Laurel, NJ 08054
 Phone: 877-428-4285/856-231-9449 • Fax: 856-231-9818

Chain of Custody

– Environmental Lead –

Contact Information	
Client Company: <u>Garden State Environmental, Inc.</u>	Project Number: <u>8345</u>
Office Address: <u>555 South Broad Street</u>	Project Name: <u>Fair lawn: Warren Point ES</u>
City, State, Zip: <u>Glen Rock, NJ 07452</u>	Primary Contact: <u>Kaitlynn Pifero</u>
Fax Number: <u>201-652-0612</u>	Office Phone: <u>201-652-1119</u>
Email Address: <u>labreports@gseconsultants.com</u>	Cell Phone: _____

iATL is accredited by the National Lead Laboratory Accreditation Program (NLLAP) to perform analytical testing of environmental samples for lead (Pb). The accreditation is through AIHA-LAP, LLC and several other nationally recognized state programs.

Matrix/Method:

Paint by AAS: ASTM D3335-85a, 2009

Wipe/Dust by AAS: SW 846: 3050B: 700B, 2010

Air by AAS: NIOSH 7082, 1994

Soil by AAS: EPA SW 846 (Soil)

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

Other Metals (Cd, Zn, Cr) by AAS

Toxicity Characteristic Leaching Procedure (TCLP) by AAS: US EPA 1311

Other _____

Special Instructions:

Turnaround Time

Preliminary Results Requested Date: _____ Verbal Email Fax

Specific date / time

10 Day 5 Day 3 Day 2 Day 1 Day* 12 Hour** 6 Hour** RUSH**

* End of next business day unless otherwise specified. ** Matrix Dependent. ***Please notify the lab before shipping***

Chain of Custody	
Relinquished (Name/Organization): <u>Kaitlynn P. (GSE, inc)</u>	Date: <u>1-10-22</u> Time: <u>2:41 pm</u>
Received (Name / iATL): _____	Date: _____ Time: _____
Sample Login (Name / iATL): _____	Date: _____ Time: _____
Analysis(Name(s) / iATL): <u>MS</u>	Date: <u>1/14/22</u> Time: <u>JAN 12 2022</u>
QA/QC Review (Name / iATL): <u>L</u>	Date: _____ Time: _____
Archived / Released: _____ QA/QC InterLAB Use: _____	Date: _____ Time: _____

Sample Log

—Environmental Lead—

Client: Garden State Environmental, inc. Project: 8345: Fair lawn, Warren Point ES

Sampling Date/Time: 12.30.21 10:29 am

Client Sample #	iATL #	Location/ Description	Flow Rate	Start End	Sampling time (min)	Area (ft2) Volume (L)	Results ()
WPES-0-S-01A	7342209	faculty Rm		10:29 am	initial		
WPES-1-WF-01A	7342200	main Entrance (R)		10:35 am	initial		
WPES-1-WF-02A	7342201	main Entrance (L)		10:37 am	initial		
WPES-1-S-02A	7342202	Rm 114		10:41 am	initial		
WPES-1-WC-01A	7342203	Hall by 116		10:47 am	initial		
WPES-1-S-03A	7342204	Rm 116		10:49 am	initial		
WPES-1-S-04A	7342205	Rm 118		10:51 am	initial		
WPES-1-S-05A	7342206	Rm 109		10:56 am	initial		
WPES-1-S-06A	7342207	Rm 110		11:01 am	initial		
WPES-1-S-07A	7342208	Rm 107		11:09 am	initial		
WPES-1-S-08A	7342209	Rm 108		11:14 am	initial		
WPES-1-S-09A	7342210	Rm 105		11:17 am	initial		
WPES-1-WF-08A	7342211	Hall by 108		11:24 am	initial		
WPES-1-WC-02A	7342212	Hall by 108		11:26 am	initial		
WPES-1-S-10A	7342213	Rm 106		11:30 am	initial		

* = Insufficient Sample Provided to Perform QC Reanalysis (<200mg)

** = Insufficient Sample Provided to Analyze (<50mg) *** = Matrix / Substrate Interference Possible

FB = Method Requires the submittal of blank(s). ML = Multi Layered Sample. May result in inconsistent results.

These preliminary results are issued by iATL to expedite procedures by clients based upon the above data. iATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificate of Analysis will follow these preliminary results. The signed COA is to be considered the official results. All EPA, HUD, and NJDEP conditions apply.

Sample Log

-Environmental Lead-

Client: Garden State Environmental, Inc. Project: 8345: Fair lawn, Warren Point ES

Sampling Date/Time: 12-30-21 10:29 am

Client Sample #	iATL #	Location/Description	Flow Rate	Start End	Sampling time (min)	Area (ft ²) Volume (L)	Results ()
WPES-1-S-11A	73400014	Rm 103		11:36 am	initial		
WPES-1-S-12A	73400015	Rm 104		11:38 am	initial		
WPES-1-B-01A	73400016	Rm 101 kindergarten		11:45 am	initial		
WPES-1-B-02A	73400017	Rm 103 kindergarten		11:49 am	initial		
WPES-1-B-03A		Rm 30A		11:55 am	initial		
WPES-1-WF-04A	73400018 73400019	Hall by 20A		11:59 am	initial		
WPES-1-S-13A	73400020	Rm 20A		12:06 pm	initial		
WPES-1-WF-05A	73400021	Gym		12:09 pm	initial		
WPES-1-B-04A	73400022	Rm 10A		12:14 pm	initial		
WPES-2-S-14A	73400023	Rm 20A		12:22 pm	initial		
WPES-2-S-15A	73400024	Rm 202		12:25 pm	initial		
WPES-2021-FBA	73400025	field Blank		/	initial		
	Acidified MS						
	1/12/22 18:30						

* = Insufficient Sample Provided to Perform QC Reanalysis (<200mg)

** = Insufficient Sample Provided to Analyze (<50mg) *** = Matrix / Substrate Interference Possible

FB = Method Requires the submittal of blank(s). ML = Multi Layered Sample. May result in inconsistent results.

These preliminary results are issued by iATL to expedite procedures by clients based upon the above data. iATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificate of Analysis will follow these preliminary results. The signed COA is to be considered the official results. All EPA, HUD, and NJDEP conditions apply.

Quality Assurance Project Plan (QAPP)
For
Drinking Water Sampling
of Lead Concentrations in School Drinking Water
Outlets
Fair Lawn Public Schools

Approvals

School District Representatives:

Program Manager: _____
Print Name Signature Date

Project Manager(s): _____
Print Name Signature Date

Individual School Project Officer(s) (See page iii)

Third Party Sampling Firm: Garden State Environmental, Inc.
(Note N/A if Third Party not involved) Name of Firm

Richard M. Lester _____
Print Name Signature Date

Laboratory: International Asbestos Testing Laboratories (IATL)
Name of Laboratory

Laboratory Manager: Frank Ehrenfeld _____ Frank Ehrenfeld _____ 1/17/22
Print Name Signature Date

Laboratory QA Officer: Tiffany Lowe _____ T. Lowe _____ 1-17-22
Print Name Signature Date