



CAPE ENVIRONMENTAL LABORATORY, L.L.C.

102 North Main • Cape May Court House, NJ 08210

email address: capelab2@gmail.com

Phone: 609-463-0077

Fax: 609-463-8977

D.E.P. Cert. #05679

Client: West Cape May Elementary

Address: 301 Moore Street, Cape May, NJ 08204

LEAD

Analyzed by: Jason Delp

Analyzed Date: 6/9/22

Analyzed Time: 1:57 pm

Analysis Method: SM-3113B

<u>Field Sampled ID #</u>	<u>Sample</u>		<u>Sample Date:</u>	<u>Sample Time</u>	<u>Sample Received:</u>	<u>Sampled By:</u>	<u>Lead</u>	<u>Action Level</u>
	<u>#</u>	<u>Sample Location</u>					<u>Result(ug/L)</u>	<u>(ug/L)-Lead</u>
66264	1	#3 Pre K/K Sink	6/2/2022	7:34 AM	6/2/2022	Tim Delp	6.70	15
	2	#4 Girl's Bath Left	6/2/2022	7:35 AM	6/2/2022	Tim Delp	7.13	15
	3	#4 Girl's Bath Right	6/2/2022	7:35 AM	6/2/2022	Tim Delp	9.18	15
	4	#8 Boy's Bath Left	6/2/2022	7:36 AM	6/2/2022	Tim Delp	***15.6	15
	5	#8 Boy's Bath Right	6/2/2022	7:36 AM	6/2/2022	Tim Delp	12.6	15
	6	#9 Staff Kitchen	6/2/2022	7:37 AM	6/2/2022	Tim Delp	7.55	15
	7	Bottle Filler	6/2/2022	7:38 AM	6/2/2022	Tim Delp	<2.0	15
	8	#15 Nurse's Sink	6/2/2022	7:39 AM	6/2/2022	Tim Delp	***92.3	15
	9	#15 Nurse's Bath	6/2/2022	7:39 AM	6/2/2022	Tim Delp	***134	15
	10	#16 Library Bath	6/2/2022	7:41 AM	6/2/2022	Tim Delp	2.48	15
	11	#20 Boy's Bath Add.	6/2/2022	7:42 AM	6/2/2022	Tim Delp	4.78	15
	12	#21 Men's Bath Add.	6/2/2022	7:43 AM	6/2/2022	Tim Delp	***67.8	15
		#23 Women's Bath						
	13	Add.	6/2/2022	7:44 AM	6/2/2022	Tim Delp	13.3	15
	14	#24 Girl's Bath Add.	6/2/2022	7:44 AM	6/2/2022	Tim Delp	5.01	15
	15	#25 Service Kitchen	6/2/2022	7:45 AM	6/2/2022	Tim Delp	3.94	15

Tim Delp, Lab Director