



PO Box 279
River Edge, NJ 07661

March 27, 2017

Kyle Barnes
Cove School District #15
803 Main St.
PO Box 68
Cove, OR 97824


Dear Kyle:

I have enclosed results for radon testing for school district. As you can see, the results are below the EPA action level of 4.0 pCi/L. Based on these results, re-testing should take place again in 10 years.

All rooms tested were done under closed conditions, with all windows shut and the HVAC system running under normal school use conditions in accordance with EPA and OR State guidelines.

Please call if you have questions. Thank you for using Environmental Transactions, Inc.

Sincerely,



Louis G. Esposito



RADIATION DATA
P.O. BOX 150
SKILLMAN, NJ 08558
(609) 466-4300
FAX (609) 466-4302

NJDEP Radon Laboratory License 11912
NJDEP Radon Measurement Business License MEB 90016

Radon Test Result:

Cove Charter School
803 Main St.
Cove, OR 97824

Test Dates: 03/06/17-03/09/17

Test ID/T#	Location	Radon(pCi/L)
1016964	Principals Office	0.6
1016965	Library	0.3
1016966	Tec Rom	0.2
1016967	Music Room	0.6
1016968	Music Room Office	0.3
1016969	Practice Room	0.0
1016970	History Room	1.7
1016971	Math Room	0.9
1016972	Wood Shop	1.1
1016973	Wood Shop Office	0.6
1016974	Metal Shop	1.4
1016975	Metal Shop/Dup	1.4
1016976	Multipurpose Room	0.2
1016977	Multipurpose Room/Blank	0.1
1016978	Multipurpose Room Office	0.6
1016979	Mechanical Room	0.0
1016980	Gym Front Right	0.8
1016981 (0=Basement)	Gym Rear Right	0.3
1016982 (1=First Floor)	Gym Rear Left	1.0
1016983 (2=Higher)	Gym Front Left	0.6
1016984	Weight Room	0.8

MES10128

MES13199

J. Keith Baicker

K. Baicker-McKee

This notice is provided to you by an organization or individual certified by NJDEP to perform radon gas or radon progeny testing measurements. NJSA 26:2D-73 requires that no certified person disclose to anyone except the DEP or the Dept. of Health the address or owners of a nonpublic building that the person has tested or treated for the presence of radon gas or radon progeny, unless the owner of the building waives in writing this right of confidentiality. In the case of a prospective sale of a building that has been tested for radon gas or progeny, the seller shall provide the buyer, at the time the contract of sale is entered into, with a copy of the results of that test and evidence of any subsequent mitigation or treatment. Any prospective buyer who contracts for the testing shall have the right to receive the results of that testing. Any questions, comments or complaints regarding the persons performing these measurements, or related mitigation, or safeguarding services, should be directed to the NJDEP, Attn: Radon Section, Bureau of Environmental Radiation, at 1-800-648-0394.

LIMITATION OF LIABILITY: While we at Radiation Data, and all of our licensed professional technicians, make every effort to maintain quality control (including duplicate canister tests, blanks, and "spiked" detectors, we make no warranty of any kind, either express or implied, for the consequences of false test results. Before any remediation action is taken, it is important that follow-up tests be conducted in accordance with USEPA protocols and NJDEP regulations. It is well known that radon concentrations fluctuate greatly under changing weather conditions. Furthermore, radon tests cannot be CERTIFIED, since there is no chain of custody of the test kit, and the "closed-house" conditions cannot be monitored continuously.



RADIATION DATA
P.O. BOX 150
SKILLMAN, NJ 08558
(609) 466-4300
FAX (609) 466-4302

NJDEP Radon Laboratory License 11912
NJDEP Radon Measurement Business License MEB 90016

Radon Test Result: **Cove Charter School**
803 Main St.
Cove, OR 97824

Test Dates: 03/06/17-03/09/17

Test ID/T#	Location	Radon(pCi/L)
1016985	Boys Coach Room	0.6
1016986	Girls Coach Room	0.4
1016987	Girls Coach Room/Dup	0.6
1016988	Laundry Room	0.6
1016989	English Room	0.4
1016990	Alternative ED Room	0.1
1016991	Old Gym Front	0.5
1016992	Old Gym Front/Blank	0.5
1016993	Old Gym Rear	0.4
1016994	Old Gym Office	0.8
1016995	Art Room	1.5
1016996	Special Aid Annex	1.8
1016997	7 th Grade Annex	1.2
1016998	Science Annex	3.7
1016999	Science Annex/Dup	3.4
1017000	Paper Annex	3.4
1017001	6 th Grade Room	1.3
1017002	Kitchen Office	1.0
1017003	Kitchen Office/Blank	0.0
1017004	Cafeteria	0.8
1017005	Kindergarden	0.3

(0=Basement)
(1=First Floor)
(2=Higher)

MES10128

MES13199

J. Keith Baicker

K. Baicker-McKee

This notice is provided to you by an organization or individual certified by NJDEP to perform radon gas or radon progeny testing measurements. NJSA 26:2D-73 requires that no certified person disclose to anyone except the DEP or the Dept. of Health the address or owners of a nonpublic building that the person has tested or treated for the presence of radon gas or radon progeny, unless the owner of the building waives in writing this right of confidentiality. In the case of a prospective sale of a building that has been tested for radon gas or progeny, the seller shall provide the buyer, at the time the contract of sale is entered into, with a copy of the results of that test and evidence of any subsequent mitigation or treatment. Any prospective buyer who contracts for the testing shall have the right to receive the results of that testing. Any questions, comments or complaints regarding the persons performing these measurements, or related mitigation, or safeguarding services, should be directed to the NJDEP, Attn: Radon Section, Bureau of Environmental Radiation, at 1-800-648-0394.

LIMITATION OF LIABILITY: While we at Radiation Data, and all of our licensed professional technicians, make every effort to maintain quality control (including duplicate canister tests, blanks, and "spiked" detectors, we make no warranty of any kind, either express or implied, for the consequences of false test results. Before any remediation action is taken, it is important that follow-up tests be conducted in accordance with USEPA protocols and NJDEP regulations. It is well known that radon concentrations fluctuate greatly under changing weather conditions. Furthermore, radon tests cannot be CERTIFIED, since there is no chain of custody of the test kit, and the "closed-house" conditions cannot be monitored continuously.



RADIATION DATA
P.O. BOX 150
SKILLMAN, NJ 08558
(609) 466-4300
FAX (609) 466-4302

NJDEP Radon Laboratory License 11912
NJDEP Radon Measurement Business License MEB 90016

Radon Test Result:

Cove Charter School
803 Main St.
Cove, OR 97824

Test Dates: 03/06/17-03/09/17

Test ID/T#	Location	Radon(pCi/L)
1017006	1 st Grade Room	0.5
1017007	2 nd Grade Room	0.7
1017008	HR Room	0.5
1017009	Secretary Office	0.6
1017010	Sick Bay	1.1
1017011	4 th Grade Room	0.5
1017012	4 th Grade Room/Dup	0.3
1017013	3 rd Grade Room	0.7
1017014	Grade School Library	0.8
1017015	Teachers Lounge	1.0
1017016	5 th Grade Room	0.5
1017017	6 th Grade Room	3.0
1017018	6 th Grade Room/Blank	0.2
1017019	1 Room	0.1
1017020	1 Room/Dup	0.4
1017021	Art Room	0.8
1017022	Kyle's Room	0.4
1017023	Randy's Room	0.6
1017024	Super's Room	0.4
1017025	Athletic Director	0.8

(0=Basement)
(1=First Floor)
(2=Higher)

MES10128

MES13199

J. Keith Baicker

K. Baicker-McKee

This notice is provided to you by an organization or individual certified by NJDEP to perform radon gas or radon progeny testing measurements. NJSA 26:2D-73 requires that no certified person disclose to anyone except the DEP or the Dept. of Health the address or owners of a nonpublic building that the person has tested or treated for the presence of radon gas or radon progeny, unless the owner of the building waives in writing this right of confidentiality. In the case of a prospective sale of a building that has been tested for radon gas or progeny, the seller shall provide the buyer, at the time the contract of sale is entered into, with a copy of the results of that test and evidence of any subsequent mitigation or treatment. Any prospective buyer who contracts for the testing shall have the right to receive the results of that testing. Any questions, comments or complaints regarding the persons performing these measurements, or related mitigation, or safeguarding services, should be directed to the NJDEP, Attn: Radon Section, Bureau of Environmental Radiation, at 1-800-648-0394.

LIMITATION OF LIABILITY: While we at Radiation Data, and all of our licensed professional technicians, make every effort to maintain quality control (including duplicate canister tests, blanks, and "spiked" detectors, we make no warranty of any kind, either express or implied, for the consequences of false test results. Before any remediation action is taken, it is important that follow-up tests be conducted in accordance with USEPA protocols and NJDEP regulations. It is well known that radon concentrations fluctuate greatly under changing weather conditions. Furthermore, radon tests cannot be CERTIFIED, since there is no chain of custody of the test kit, and the "closed-house" conditions cannot be monitored continuously.