



Box R Water Analysis Laboratory

567 NW Second Street
Prineville, Oregon 97754
541-447-4911

Mr. Bruce Neil

October 18, 2016

c/o Cove School District #15

PO Box 68

Cove, OR 97824

Sample Nbr: X023925


Dear Mr. Neil,

Attached is a copy of your drinking water – Lead – test result, sampled on October 3, 2016, at Cove Elementary School, Cove, OR. Your analysis was performed by Neilson Research Corp. in Medford, OR. Please do not hesitate to call Box R Water Analysis Laboratory with any questions you may have in regards to your water testing.

Thank you for using Box R Water Analysis Laboratory, we appreciate your business.

Sincerely,

Sherri K. Miyazaki – Box R Water Analysis Laboratory Director



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

10/13/2016

Sherri Miyazaki
Box R Waterlab
567 NW Second Street
Prineville, OR 97754

TEL: (541) 447-4911

FAX (541) 447-4917

RE: X023925 Cove School District

Order No.: 1610316

Dear Sherri Miyazaki:

Neilson Research Corporation received 1 sample(s) on 10/10/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

245 S Grape St • Medford, OR 97501 • (541) 770-5678
400 SE G St, Suite B • Grants Pass, OR 97526 • (541) 479-4053

www.nrclabs.com

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Box R Waterlab
Project: X023925 Cove School District
Lab Order: 1610316

Date: 13-Oct-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1610316
NRC Sample ID: 1610316-01A
Collection Date: 10/3/2016 12:10:00 PM
Received Date: 10/10/2016 9:12:00 AM
Reported Date: 10/13/2016 10:12:09 AM

Sample Information:

X023925 Cove School District

Client Sample ID: Cove School District
Collectors Name: CGM
Sample Location: Kindergarten Sink
Source: Well

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000576		0.0001	mg/L	0.020 AL	10/11/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

Date: 13-Oct-16

CLIENT: Box R Waterlab
Work Order: 1610316
Project: X023925 Cove School District

ANALYTICAL QC SUMMARY REPORT
TestCode: ICPMS_200.8_SCHOOL

Sample ID	MB-36753	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 10/10/2016	RunNo: 90550						
Client ID:	ZZZZZ	Batch ID: 36753	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 10/11/2016	SeqNo: 1371468						
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		ND	0.000100									

Sample ID	LCS-36753	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 10/10/2016	RunNo: 90550						
Client ID:	ZZZZZ	Batch ID: 36753	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 10/11/2016	SeqNo: 1371469						
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09921	0.000100	0.1	0	99.2	85	115				

Sample ID	1610268-03AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 10/10/2016	RunNo: 90550						
Client ID:	ZZZZZ	Batch ID: 36753	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 10/11/2016	SeqNo: 1371478						
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.1505	0.000100	0.1	0.05628	94.2	70	130				

Sample ID	1610268-03AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 10/10/2016	RunNo: 90550						
Client ID:	ZZZZZ	Batch ID: 36753	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 10/11/2016	SeqNo: 1371479						
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.1536	0.000100	0.1	0.05628	97.3	70	130	0.1505	2.04	20	

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits