

Collins Architectural Group, PS
960 12th Avenue, Suite 200
Longview, WA 98632

Addendum No. 1

Page No. 1 of 4

Date: August 12, 2019

Project: Kelso School District
Schroeder Field Audio System Replacement
Project Number 2019-23A

Notice to Contractor:

The following changes in the Contract Documents, including the Drawings and Specifications, constitute this Addendum. All changes included in Addenda shall become a part of the Contract Documents for this Project. Any changes herein offset only the specific Drawings or Notes on Drawings or words or paragraphs in Specifications referenced to and the balance of the Drawings shall remain in full force.

ARCHITECTURAL SPECIFICATION

<u>ITEM</u>	<u>SHEET NO./</u> <u>SECTION NO.</u>	<u>DESCRIPTION</u>
1.0	Pre-bid Walk	For attendees at the pre-bid walkthrough held on August 8, 2019 see attached sign-in sheet.
1.1	Prevailing Wages	All businesses are required to have training on prevailing wage rates before bidding and/or performing work on public works projects in the State of Washington. Contractors may be exempt from this requirement if they have been in business with an active Unified Business Identifier (UBI) number for 3 or more years AND have performed work on 3 or more public works projects.
1.2	27 4116	Add paragraph 1.01.D to read: D. Demolition of existing equipment located on the grandstand or in the press box that is not included or required for integration into the new sound system.
1.3	27 4116	Change paragraph 2.02.A.3 to read: 3. Locking Wall Box (Track Side): Provide one GaiTronics 255-001 NEMA 4 enclosure for field input plates. Provide the RDL Net microphone & line input/output panels with two microphones, one stereo line audio inputs and two line outputs per plate. Mount at track level on front of grandstand.
1.4	27 4116	Change paragraph 2.02.A.13 to read: 13. Monitor Speakers: JBL Pro STX815P. Provide two with XLR line level speaker cables.
1.5	Detail	See attached detail sheet.

APPROVED SUBSTITUTIONS

Specified Product

Approved Substitution

JBL STX 815M

RCF ST15 SMA

END OF ADDENDUM 1



STADIUM SOUND SYSTEM PRE-BID CONTRACTOR MEETING

KELSO SCHOOL DISTRICT
DISTRICT BOND MODERNIZATION

THURSDAY AUG 8, 2019 - 3:00 PM

YOUR NAME		COMPANY NAME	CONTACT INFORMATION	
1	CHRIS COLLINS	COLLINS APERTH TECHNICAL GROUP	Email	
			Phone	
2	GARY CATHMART	KEND	Email	
			Phone	
3	RICHARD STEBBEL	CSG	Email	
			Phone	
4	JOHN E. HARRIS	MGE AVA	Email	John @ mge.ava.com
			Phone	206-714-4003
5	KURT MOYER	Pacific Tech Const.	Email	Kmoyer @ pacific tech . info
			Phone	360-564-414-8084
6	DEGAS CONCRETE	THREE RIVERS AUDIO VISUAL	Email	
			Phone	
7			Email	
			Phone	
8			Email	
			Phone	

Owner's Acknowledgement: _____

