

Collins Architectural Group, p.s.
950 12th Avenue, Suite 200
Longview, WA 98632

Addendum No. 3

Page No. 1 of 2

Date: May 4th, 2019

Project: Kelso School District No. 458
Kelso High School Boiler Replacements
Kelso, WA

Notice to Contractor:

The following changes in the Contract Documents, including the Drawings and Specifications, constitute this Addendum. All changes included in Addenda shall become a part of the Contract Documents for this Project. Any changes herein offset only the specific Drawings or Notes on Drawings or words or paragraphs in Specifications referenced to and the balance of the Drawings shall remain in full force.

ARCHITECTURAL SPECIFICATION:

<u>ITEM</u>	<u>SHEET NO./</u> <u>SECTION NO.</u>	<u>DESCRIPTION</u>
3.0		See attached revised hot water boiler schedule on sheet M1.1.

End of addendum 3

HOT WATER BOILER

SYMBOL MARK	DESCRIPTION	SERVICE	FUEL	INPUT (MBH)	OUTPUT (MBH)	GPM	SUPPLY TEMP (°F)	RETURN TEMP (°F)	DOE AFUE (%)	RELIEF SETTING (PSIG)	FLUE SIZE (IN)	AIR INLET (IN)	GAS CONN. (IN)	VOLTAGE	PH.	BURNER MOTOR HP	MCA	FLA	OPERATING WEIGHT (LBS)	COMMENTS
B-1	CONDENSING FIRE-CAST IRON	SECTOR B RM 213	NATURAL GAS	1,000	900	45.0	140	120	90	50	4	8	1 1/2	120	1			13.1	1,600	1
B-2	CONDENSING FIRE-CAST IRON	SECTOR B RM 213	NATURAL GAS	600	556	45.0	140	120	90	50	4	8	1 1/2	120	1			13.1	1,600	2
B-3	CONDENSING FIRE-CAST IRON	SECTOR A RM 368	NATURAL GAS	600	556	45.0	140	120	90	50	4	8	1 1/2	120	1			13.1	1,600	2
B-4	CONDENSING FIRE-CAST IRON	SECTOR A RM 368	NATURAL GAS	1,000	900	45.0	140	120	90	50	4	8	1 1/2	120	1			13.1	1,600	1
B-5	CONDENSING FIRE-CAST IRON	SECTOR C RM383	NATURAL GAS	1,000	900	45.0	140	120	90	50	4	8	1 1/2	120	1			13.1	1,600	1
B-6	CONDENSING FIRE-CAST IRON	SECTOR C RM 383	NATURAL GAS	1,000	900	45.0	140	120	90	50	4	8	1 1/2	120	1			13.1	1,600	1
B-7	CONDENSING FIRE-CAST IRON	SECTOR E RM 432	NATURAL GAS	1,000	900	45.0	140	120	90	50	4	8	1 1/2	120	1			13.1	1,600	1
B-15	CONDENSING FIRE-CAST IRON	SECTOR E RM 432	NATURAL GAS	1,000	900	45.0	140	120	90	50	4	8	1 1/2	120	1			13.1	1,600	1
B-16	CONDENSING FIRE-CAST IRON	SECTOR B RM 330	NATURAL GAS	600	556	45.0	140	120	90	50	4	8	1 1/2	120	1			13.1	1,600	2

NOTES:

- 1 DESIGN BASIS: KN SERIES CONDENSING BOILER KN10.
- 2 DESIGN BASIS: KN SERIES CONDENSING BOILER KN6.

KELSO SCHOOL DISTRICT

KELSO HIGH SCHOOL
1904 ALLEN STREET
KELSO, WASHINGTON 98626

ISSUE DATE:
04/30/2019

SET TYPE:
ADDENDUM 1

DRAWN BY:
KENDAL P.

DESIGNED BY:
RICK DUSA

CHECKED BY:
RICK DUSA

MKE JOB #:
CA-5150

SCHEDULES
HVAC

M1.1