

## ANALYTICAL REPORT

Job Number: 420-111137-1

SDG Number: Tuxedo UFSD - George F Baker

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Attention: Jack DeGraw

*Meredith Ruthven*

---

Meredith W Ruthven  
Customer Service Manager  
mruthven@envirotestlaboratories.com  
11/07/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

**Job Narrative**  
420-J111137-1

**Comments**

Results are compared to NYSDOH drinking water standards other federal regulations may apply.

No additional comments.

**Receipt**

All samples were received in good condition within temperature requirements.

**Metals**

No analytical or quality issues were noted.

## METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-111137-1  
SDG Number: Tuxedo UFSD - George F Baker

Description	Lab Location	Method	Preparation Method
<b>Matrix: Water</b>			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

### Lab References:

EnvTest = EnviroTest

### Method References:

EPA = US Environmental Protection Agency

## METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-111137-1  
SDG Number: Tuxedo UFSD - George F Baker

<b>Method</b>	<b>Analyst</b>	<b>Analyst ID</b>
EPA 200.8 Rev.5.4	Sirico, Derek	DS

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-111137-1  
SDG Number: Tuxedo UFSD - George F Baker

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111137-1	GFB Ground Floor Faculty Men's BR Sink	Drinking Water	09/27/2016 0521	09/30/2016 1048
420-111137-2	GFB Ground Floor Faculty BR Sink	Drinking Water	09/27/2016 0522	09/30/2016 1048
420-111137-3	GFB Ground Floor Men's BR Across from Kitchen	Drinking Water	09/27/2016 0523	09/30/2016 1048
420-111137-4	GFB Ground Floor Women's BR Across from Kitchen	Drinking Water	09/27/2016 0524	09/30/2016 1048
420-111137-5	GFB Kitchen Sprayer Sink	Drinking Water	09/27/2016 0526	09/30/2016 1048
420-111137-6	GFB Kitchen Sprayer in dishwasher room	Drinking Water	09/27/2016 0527	09/30/2016 1048
420-111137-7	GFB Kitchen handwash Sink	Drinking Water	09/27/2016 0528	09/30/2016 1048
420-111137-8	GFB Handwash Sink in Dishwashing Room	Drinking Water	09/27/2016 0529	09/30/2016 1048
420-111137-9	GFB Staff Cafeteria (002) Men's BR Sink	Drinking Water	09/27/2016 0532	09/30/2016 1048
420-111137-10	GFB Staff Cafeteria (002) Women's BR Sink	Drinking Water	09/27/2016 0532	09/30/2016 1048
420-111137-11	GFB Art Classroom Sink Left	Drinking Water	09/27/2016 0534	09/30/2016 1048
420-111137-12	GFB Art Classroom Sink Right	Drinking Water	09/27/2016 0535	09/30/2016 1048
420-111137-13	GFB Art Storage Room Sink	Drinking Water	09/27/2016 0535	09/30/2016 1048
420-111137-14	GFB Shop Behind (017) Left Sink	Drinking Water	09/27/2016 0537	09/30/2016 1048
420-111137-15	GFB Shop Behind (017) Right Sink	Drinking Water	09/27/2016 0537	09/30/2016 1048
420-111137-16	GFB 1st Floor Faculty men's BR Sink	Drinking Water	09/27/2016 0540	09/30/2016 1048
420-111137-17	GFB 1st Floor Faculty Women's BR Sink	Drinking Water	09/27/2016 0540	09/30/2016 1048
420-111137-18	GFB 1st Floor Boys BR Left Sink	Drinking Water	09/27/2016 0541	09/30/2016 1048
420-111137-19	GFB 1st Floor Boys BR Right Sink	Drinking Water	09/27/2016 0542	09/30/2016 1048
420-111137-20	GFB Main Office Sink	Drinking Water	09/27/2016 0544	09/30/2016 1048
420-111137-21	GFB Classroom 123 Bathroom Sink	Drinking Water	09/27/2016 0545	09/30/2016 1048
420-111137-22	GFB 1st Floor Girl's BR Right Sink	Drinking Water	09/27/2016 0546	09/30/2016 1048
420-111137-23	GFB 1st Floor Girl's BR Left Sink	Drinking Water	09/27/2016 0546	09/30/2016 1048
420-111137-24	GFB Science 213 Left Sink by Door #1	Drinking Water	09/27/2016 0550	09/30/2016 1048
420-111137-25	GFB Science 213 2nd Sink to left	Drinking Water	09/27/2016 0551	09/30/2016 1048
420-111137-26	GFB Science 213 3rd sink	Drinking Water	09/27/2016 0552	09/30/2016 1048
420-111137-27	GFB Science 213 4th sink	Drinking Water	09/27/2016 0552	09/30/2016 1048
420-111137-28	GFB Science 213 5th sink	Drinking Water	09/27/2016 0553	09/30/2016 1048
420-111137-29	GFB Science 213 6th sink	Drinking Water	09/27/2016 0553	09/30/2016 1048

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-111137-1  
SDG Number: Tuxedo UFSD - George F Baker

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111137-30	GFB Science 213 sink by teacher's desk	Drinking Water	09/27/2016 0554	09/30/2016 1048
420-111137-31	GFB Science 213 Back storage Room Sink	Drinking Water	09/27/2016 0556	09/30/2016 1048
420-111137-32	GFB Science 214 1st sink on Left #3	Drinking Water	09/27/2016 0559	09/30/2016 1048
420-111137-33	GFB Science 214 3rd sink on Left	Drinking Water	09/27/2016 0600	09/30/2016 1048
420-111137-34	GFB Science 214 Sink #4	Drinking Water	09/27/2016 0600	09/30/2016 1048
420-111137-35	GFB Science 214 Sink #5	Drinking Water	09/27/2016 0601	09/30/2016 1048
420-111137-36	GFB Science 214 Sink #6	Drinking Water	09/27/2016 0601	09/30/2016 1048
420-111137-37	GFB Science 214 Sink by teacher's Desk (Island)	Drinking Water	09/27/2016 0602	09/30/2016 1048
420-111137-38	GFB Science chemical Storage Sink 215	Drinking Water	09/27/2016 0604	09/30/2016 1048
420-111137-39	GFB Science 216 1st Sink to left (in Back)	Drinking Water	09/27/2016 0608	09/30/2016 1048
420-111137-40	GFB Science 216 2nd Sink in back to left	Drinking Water	09/27/2016 0608	09/30/2016 1048
420-111137-41	GFB Science 216 3rd Sink in back	Drinking Water	09/27/2016 0609	09/30/2016 1048
420-111137-42	GFB Science 216 4th sink	Drinking Water	09/27/2016 0609	09/30/2016 1048
420-111137-43	GFB Science 216 5th sink	Drinking Water	09/27/2016 0610	09/30/2016 1048
420-111137-44	GFB Science 216 6th sink	Drinking Water	09/27/2016 0611	09/30/2016 1048
420-111137-45	GFB Science 217 Island Sink Teacher's desk	Drinking Water	09/27/2016 0614	09/30/2016 1048
420-111137-46	GFB Science 217 2nd Sink in from left (Back)	Drinking Water	09/27/2016 0615	09/30/2016 1048
420-111137-47	GFB Science 217 3rd Sink in from left (Back)	Drinking Water	09/27/2016 0616	09/30/2016 1048
420-111137-48	GFB Science 217 Sink #5	Drinking Water	09/27/2016 0616	09/30/2016 1048
420-111137-49	GFB Science 217 Sink #6 (right)	Drinking Water	09/27/2016 0617	09/30/2016 1048
420-111137-50	GFB Top Floor Faculty Men's BR	Drinking Water	09/27/2016 0620	09/30/2016 1048
420-111137-51	GFB Top Floor Faculty Women's BR	Drinking Water	09/27/2016 0620	09/30/2016 1048
420-111137-52	GFB Classroom 220 Left sink	Drinking Water	09/27/2016 0622	09/30/2016 1048
420-111137-53	GFB Classroom 220 Right sink	Drinking Water	09/27/2016 0622	09/30/2016 1048
420-111137-54	GFB Top Floor Girl's BR Right Sink	Drinking Water	09/27/2016 0623	09/30/2016 1048
420-111137-55	GFB Top Floor Girl's BR Left Sink	Drinking Water	09/27/2016 0623	09/30/2016 1048
420-111137-56	GFB Rm 202 Sink	Drinking Water	09/27/2016 0625	09/30/2016 1048
420-111137-57	GFB Top Floor Boy's BR Left Sink	Drinking Water	09/27/2016 0626	09/30/2016 1048
420-111137-58	GFB Top Floor Boy's BR Right Sink	Drinking Water	09/27/2016 0627	09/30/2016 1048
420-111137-59	GFB Outside Room 17 hose bib	Drinking Water	09/27/2016 0634	09/30/2016 1048

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-111137-1  
SDG Number: Tuxedo UFSD - George F Baker

<b>Lab Sample ID</b>	<b>Client Sample ID</b>	<b>Client Matrix</b>	<b>Date/Time Sampled</b>	<b>Date/Time Received</b>
420-111137-60	GFB Outside Boiler Room hose bib	Drinking Water	09/27/2016 0639	09/30/2016 1048

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Ground Floor Faculty Men's BR Sink  
Lab Sample ID: 420-111137-1

Date Sampled: 09/27/2016 0521  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1517		
Prep Method: 200			Date Prepared: 10/28/2016 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Ground Floor Faculty BR Sink  
Lab Sample ID: 420-111137-2

Date Sampled: 09/27/2016 0522  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1518	
Prep Method: 200			Date Prepared:	10/28/2016 1000	
Pb	9.73	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Ground Floor Men's BR Across from  
Lab Sample ID: 420-111137-3

Date Sampled: 09/27/2016 0523  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1519		
Prep Method: 200			Date Prepared: 10/28/2016 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Ground Floor Women's BR Across from  
Lab Sample ID: 420-111137-4

Date Sampled: 09/27/2016 0524  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1520		
Prep Method: 200			Date Prepared: 10/28/2016 1000		
Pb	1.95	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Kitchen Sprayer Sink  
Lab Sample ID: 420-111137-5

Date Sampled: 09/27/2016 0526  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1520		
Prep Method: 200			Date Prepared: 10/28/2016 1000		
Pb	1.71	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Kitchen Sprayer in dishwasher room  
Lab Sample ID: 420-111137-6

Date Sampled: 09/27/2016 0527  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1521	
Prep Method: 200			Date Prepared:	10/28/2016 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Kitchen handwash Sink  
Lab Sample ID: 420-111137-7

Date Sampled: 09/27/2016 0528  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1522	
Prep Method: 200			Date Prepared:	10/28/2016 1030	
Pb	1.65	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Handwash Sink in Dishwashing Room  
Lab Sample ID: 420-111137-8

Date Sampled: 09/27/2016 0529  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1527		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	27.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Staff Cafeteria (002) Men's BR Sink  
Lab Sample ID: 420-111137-9

Date Sampled: 09/27/2016 0532  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1528		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Staff Cafeteria (002) Women's BR Sink  
Lab Sample ID: 420-111137-10

Date Sampled: 09/27/2016 0532  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1528		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Art Classroom Sink Left  
Lab Sample ID: 420-111137-11

Date Sampled: 09/27/2016 0534  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1529	
Prep Method: 200			Date Prepared:	10/28/2016 1030	
Pb	2.95	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Art Classroom Sink Right  
Lab Sample ID: 420-111137-12

Date Sampled: 09/27/2016 0535  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1530	
Prep Method: 200			Date Prepared:	10/28/2016 1030	
Pb	1.22	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Art Storage Room Sink  
Lab Sample ID: 420-111137-13

Date Sampled: 09/27/2016 0535  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1531		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	1.29	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Shop Behind (017) Left Sink  
Lab Sample ID: 420-111137-14

Date Sampled: 09/27/2016 0537  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1532	
Prep Method: 200			Date Prepared:	10/28/2016 1030	
Pb	1.20	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Shop Behind (017) Right Sink  
Lab Sample ID: 420-111137-15

Date Sampled: 09/27/2016 0537  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1532	
Prep Method: 200			Date Prepared:	10/28/2016 1030	
Pb	512	g	ug/L	32.0	32

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB 1st Floor Faculty men's BR Sink  
Lab Sample ID: 420-111137-16

Date Sampled: 09/27/2016 0540  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1533		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	1.44	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB 1st Floor Faculty Women's BR Sink  
Lab Sample ID: 420-111137-17

Date Sampled: 09/27/2016 0540  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1534		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB 1st Floor Boys BR Left Sink  
Lab Sample ID: 420-111137-18

Date Sampled: 09/27/2016 0541  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1536		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	1.75	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB 1st Floor Boys BR Right Sink  
Lab Sample ID: 420-111137-19

Date Sampled: 09/27/2016 0542  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1537		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Main Office Sink  
Lab Sample ID: 420-111137-20

Date Sampled: 09/27/2016 0544  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1538	
Prep Method: 200			Date Prepared:	10/28/2016 1030	
Pb	5.49	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Classroom 123 Bathroom Sink  
Lab Sample ID: 420-111137-21

Date Sampled: 09/27/2016 0545  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1539		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	15.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB 1st Floor Girl's BR Right Sink  
Lab Sample ID: 420-111137-22

Date Sampled: 09/27/2016 0546  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1540		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	3.04	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB 1st Floor Girl's BR Left Sink  
Lab Sample ID: 420-111137-23

Date Sampled: 09/27/2016 0546  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1540		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	3.55	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 213 Left Sink by Door #1  
Lab Sample ID: 420-111137-24

Date Sampled: 09/27/2016 0550  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1541		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	2.89	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 213 2nd Sink to left  
Lab Sample ID: 420-111137-25

Date Sampled: 09/27/2016 0551  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1542		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	3.52	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 213 3rd sink  
Lab Sample ID: 420-111137-26

Date Sampled: 09/27/2016 0552  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1543		
Prep Method: 200			Date Prepared: 10/28/2016 1030		
Pb	3.77	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 213 4th sink  
Lab Sample ID: 420-111137-27

Date Sampled: 09/27/2016 0552  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1544		
Prep Method: 200			Date Prepared: 10/28/2016 1100		
Pb	3.87	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 213 5th sink  
Lab Sample ID: 420-111137-28

Date Sampled: 09/27/2016 0553  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1548	
Prep Method: 200			Date Prepared:	10/28/2016 1100	
Pb	3.68	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 213 6th sink  
Lab Sample ID: 420-111137-29

Date Sampled: 09/27/2016 0553  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1549		
Prep Method: 200			Date Prepared: 10/28/2016 1100		
Pb	3.39	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 213 sink by teacher's desk  
Lab Sample ID: 420-111137-30

Date Sampled: 09/27/2016 0554  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1550		
Prep Method: 200			Date Prepared: 10/28/2016 1100		
Pb	22.1 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 213 Back storage Room Sink  
Lab Sample ID: 420-111137-31

Date Sampled: 09/27/2016 0556  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/01/2016 1320		
Prep Method: 200			Date Prepared: 10/31/2016 1000		
Pb	1390 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 214 1st sink on Left #3  
Lab Sample ID: 420-111137-32

Date Sampled: 09/27/2016 0559  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1551	
Prep Method: 200			Date Prepared:	10/28/2016 1100	
Pb	6.94	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 214 3rd sink on Left  
Lab Sample ID: 420-111137-33

Date Sampled: 09/27/2016 0600  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1552	
Prep Method: 200			Date Prepared:	10/28/2016 1100	
Pb	9.64	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 214 Sink #4  
Lab Sample ID: 420-111137-34

Date Sampled: 09/27/2016 0600  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1552	
Prep Method: 200			Date Prepared:	10/28/2016 1100	
Pb	13.9	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 214 Sink #5  
Lab Sample ID: 420-111137-35

Date Sampled: 09/27/2016 0601  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1553		
Prep Method: 200			Date Prepared: 10/28/2016 1100		
Pb	8.44	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 214 Sink #6  
Lab Sample ID: 420-111137-36

Date Sampled: 09/27/2016 0601  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1556		
Prep Method: 200			Date Prepared: 10/28/2016 1100		
Pb	4.59	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 214 Sink by teacher's Desk  
Lab Sample ID: 420-111137-37

Date Sampled: 09/27/2016 0602  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1556		
Prep Method: 200			Date Prepared: 10/28/2016 1100		
Pb	48.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science chemical Storage Sink 215  
Lab Sample ID: 420-111137-38

Date Sampled: 09/27/2016 0604  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1557	
Prep Method: 200			Date Prepared:	10/28/2016 1100	
Pb	16.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 216 1st Sink to left (in Back)  
Lab Sample ID: 420-111137-39

Date Sampled: 09/27/2016 0608  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1558	
Prep Method: 200			Date Prepared:	10/28/2016 1100	
Pb	3.73	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 216 2nd Sink in back to left  
Lab Sample ID: 420-111137-40

Date Sampled: 09/27/2016 0608  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1559		
Prep Method: 200			Date Prepared: 10/28/2016 1100		
Pb	3.64	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 216 3rd Sink in back  
Lab Sample ID: 420-111137-41

Date Sampled: 09/27/2016 0609  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1600	
Prep Method: 200			Date Prepared:	10/28/2016 1100	
Pb	4.12	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 216 4th sink  
Lab Sample ID: 420-111137-42

Date Sampled: 09/27/2016 0609  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1600		
Prep Method: 200			Date Prepared: 10/28/2016 1100		
Pb	4.39	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 216 5th sink  
Lab Sample ID: 420-111137-43

Date Sampled: 09/27/2016 0610  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1601		
Prep Method: 200			Date Prepared: 10/28/2016 1100		
Pb	5.18	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 216 6th sink  
Lab Sample ID: 420-111137-44

Date Sampled: 09/27/2016 0611  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016	1602	
Prep Method: 200			Date Prepared: 10/28/2016	1100	
Pb	4.86	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 217 Island Sink Teacher's desk  
Lab Sample ID: 420-111137-45

Date Sampled: 09/27/2016 0614  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1603	
Prep Method: 200			Date Prepared:	10/28/2016 1100	
Pb	6.02	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 217 2nd Sink in from left (Back)  
Lab Sample ID: 420-111137-46

Date Sampled: 09/27/2016 0615  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1605	
Prep Method: 200			Date Prepared:	10/28/2016 1100	
Pb	14.2	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 217 3rd Sink in from left (Back)  
Lab Sample ID: 420-111137-47

Date Sampled: 09/27/2016 0616  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1606		
Prep Method: 200			Date Prepared: 10/28/2016 1100		
Pb	6.00	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 217 Sink #5  
Lab Sample ID: 420-111137-48

Date Sampled: 09/27/2016 0616  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1607		
Prep Method: 200			Date Prepared: 10/28/2016 1200		
Pb	6.21	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Science 217 Sink #6 (right)  
Lab Sample ID: 420-111137-49

Date Sampled: 09/27/2016 0617  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1610	
Prep Method: 200			Date Prepared:	10/28/2016 1200	
Pb	3.54	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Top Floor Faculty Men's BR  
Lab Sample ID: 420-111137-50

Date Sampled: 09/27/2016 0620  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1611	
Prep Method: 200			Date Prepared:	10/28/2016 1200	
Pb	1.51	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Top Floor Faculty Women's BR  
Lab Sample ID: 420-111137-51

Date Sampled: 09/27/2016 0620  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1612	
Prep Method: 200			Date Prepared:	10/28/2016 1200	
Pb	3.42	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Classroom 220 Left sink  
Lab Sample ID: 420-111137-52

Date Sampled: 09/27/2016 0622  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/28/2016 1612	
Prep Method: 200			Date Prepared:	10/28/2016 1200	
Pb	3.71	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Classroom 220 Right sink  
Lab Sample ID: 420-111137-53

Date Sampled: 09/27/2016 0622  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1615		
Prep Method: 200			Date Prepared: 10/28/2016 1200		
Pb	5.48	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Top Floor Girl's BR Right Sink  
Lab Sample ID: 420-111137-54

Date Sampled: 09/27/2016 0623  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1616		
Prep Method: 200			Date Prepared: 10/28/2016 1200		
Pb	3.36	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Top Floor Girl's BR Left Sink  
Lab Sample ID: 420-111137-55

Date Sampled: 09/27/2016 0623  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1616		
Prep Method: 200			Date Prepared: 10/28/2016 1200		
Pb	2.07	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Rm 202 Sink  
Lab Sample ID: 420-111137-56

Date Sampled: 09/27/2016 0625  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1617		
Prep Method: 200			Date Prepared: 10/28/2016 1200		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Top Floor Boy's BR Left Sink  
Lab Sample ID: 420-111137-57

Date Sampled: 09/27/2016 0626  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1618		
Prep Method: 200			Date Prepared: 10/28/2016 1200		
Pb	1.14	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Top Floor Boy's BR Right Sink  
Lab Sample ID: 420-111137-58

Date Sampled: 09/27/2016 0627  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1619		
Prep Method: 200			Date Prepared: 10/28/2016 1200		
Pb	8.77	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Outside Room 17 hose bib  
Lab Sample ID: 420-111137-59

Date Sampled: 09/27/2016 0634  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1620		
Prep Method: 200			Date Prepared: 10/28/2016 1200		
Pb	1190 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-111137-1  
Sdg Number: Tuxedo UFSD - George F Baker

Client Sample ID: GFB Outside Boiler Room hose bib  
Lab Sample ID: 420-111137-60

Date Sampled: 09/27/2016 0639  
Date Received: 09/30/2016 1048  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/28/2016 1620		
Prep Method: 200			Date Prepared: 10/28/2016 1200		
Pb	7.76	ug/L	1.00	1.00	1.0

## DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:  
Sdg Number: Tuxedo UFSD - George F Baker

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

## Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Tuxedo UFSD - George F Baker

---

**The following analytes are Not Part of the ELAP scope of accreditation:**

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

**The following analytes are Not Part of ELAP Potable Water scope of accreditation:**

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

**The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:**

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

**The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:**

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

## Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Tuxedo UFSD - George F Baker

---

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.