

Written Program Indoor Air Quality Standard - PEOSH  
Indoor Air Quality Survey & Testing for Sick Building Syndrome  
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings  
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel  
Asbestos Surveys and AHERA Management Plans  
AHERA 2 Hour Awareness Training  
"Non-Friable" Asbestos Final Air Clearance Sampling  
Right to Know Survey, Compliance & PEOSHA Training  
Written Hazard Communication Program (PEOSHA HCS)

**RAMM Environmental Services, Inc.**

*Commitment, Excellence, Integrity*

---

77 Nottingham Road, PO Box 308  
Fair Lawn, New Jersey 07410  
Phone: (201) 475-9880  
Fax: (201) 475-9881

**FOLLOW-UP LEAD IN DRINKING WATER ANALYSIS  
FOR  
PALMYRA BOARD OF EDUCATION  
CHARLES STREET SCHOOL  
PALMYRA, NEW JERSEY  
JULY 11, 2016**

**Prepared for:  
Palmyra Board of Education  
311 West Fifth Street  
Palmyra, NJ 08065  
Attn.: Mr. Ron Holt  
Operations Supervisor  
Tel: (856) 786-9300  
Fax: (856) 829-9638**

**Prepared by:  
RAMM Environmental Services, Inc.  
77 Nottingham Road, PO Box 308  
Fair Lawn, NJ 07410  
Mr. Rodger Headrick  
President  
Tel: (201) 475-9880  
Fax: (201) 475-9881**

**July 25, 2016**

**REPORT CONTENTS**

<b>INTRODUCTION</b>	<b>1</b>
<b>WATER QUALITY MONITORING RESULTS</b>	<b>2</b>
<b>APPENDIX</b>	
<b>Lead in Drinking Water Certificate of Analysis</b>	

**INTRODUCTION**

RAMM Environmental Services, Inc. was requested by the Palmyra Board of Education to perform water sampling for lead content in the Charles Street School located in Palmyra, New Jersey.

Water quality sampling functions were performed by RAMM at the Palmyra Board of Education Charles Street School located in Palmyra, New Jersey on July 11, 2016, to determine the quality of drinking water for lead content.

# RAMM

---

## WATER QUALITY MONITORING RESULTS LEAD IN DRINKING WATER ANALYSIS

Lead in drinking water sampling was performed during RAMM's July 11, 2016 site visit. The (E.P.A.) Environmental Protection Agency has established an enforceable lead concentration action level for public water supplies. The lead action level is 15 micrograms per liter (mg/L) = parts per billion (ppb), which is equivalent to 0.015 milligrams per liter (mg/L) = parts per million (ppm).

### Charles Street School

Lead in drinking water measurements were collected in two (2) different locations of the building.

<i>Sample #</i>	<i>Location</i>	<i>Lead Concentration</i>
16-0711-01	Classroom 03	5.24 ppb
16-0711-02	Classroom 04	<3.00 ppb

All results report less than the United States Environmental Protection Agency (U.S.E.P.A.) Guidelines and the New Jersey Department of Environmental Protection (N.J.D.E.P.) for safe drinking water (15 ppb). Currently the drinking water is safe and poses no health hazard to building occupants.