

January 1, 2020

To: Grayson County Board of Education (New) Central Office

Every building owned or used by your board of education has recently been inspected for friable and nonfriable asbestos containing material. This was conducted by an inspector fully accredited by the State of Kentucky and the Environmental Protection Agency (EPA).

Your board of education has adopted a management plan for each building; these plans are located in the superintendent's office and may be reviewed during normal working hours. Copies may be obtained for a small fee if prior notice is given to the office staff. A copy of this report is also available in the Superintendent's office.

Upon inspection and analysis of samples taken, it has been determined that your building contains no asbestos containing building material.

Sincerely,

Doug Robinson, Superintendent
Grayson County Schools