

Lead Testing Results Summary

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008

Arlington School District #3

Page 1 of 1

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter	EPA School # mg/liter***
7/1/16	20160708-43	SWDF	0.0121	0.020
7/1/16	20160708-44	Room 1	0.0660	0.020
7/1/16	20160708-45	Room 3	0.0276	0.020
7/1/16	20160708-46	Room 6	0.0148	0.020
7/1/16	20160708-47	Staff Room	0.0462	0.020
7/1/16	20160708-48	Central drinking fountain	0.0011	0.020
7/1/16	20160708-49	Kitchen sink	0.0020	0.020
7/1/16	20160708-50	WDF	ND @ 0.001	0.020
7/1/16	20160708-51	AHSE	ND @ 0.001	0.020
7/1/16	20160708-52	AHSW	ND @ 0.001	0.020

ND means No Detection at specified level

Sampling Size: 250 mls

WATERLAB CORP.

2603 12th Street SE
Salem, OR 97302

Date/Time: _____
Correct Container _____
Correct Volume _____
Hold Time _____

0/1 N
0/1 N
0/1 N

Rec'd By: RO

Relinquished

By: [Signature] Kevin Hunking Printed Name

ATTN: Kevin Hunking

SEND RESULTS TO:

Co. Name: ARLINGTON Senior Dist #3
Address: 1200 Main St P.O. Box 10
City: ARLINGTON State: OR
Zip Code: 97812 Phone: (541) 454-2632

SEND BILL TO:

Name: _____
Address: SAME
City: _____ State: _____
Zip Code: _____ Phone: _____

PROJECT: _____

Lead & Copper

COLLECTED BY: Mark Davidson

TEST	Pb, Cu	Pb, Cu	Pb, Cu	Pb, Cu
DATE	7/1/2016	7/1/2016	7/1/2016	7/1/2016
TIME	7:00 AM	7:05 AM	7:10 AM	7:15 AM
SOURCE	SWDF	Room 1	Room 3	Room 6
LAB #	20160708-043	20160708-044	20160708-045	20160708-046
				20160708-047

TEST	Pb, Cu	Pb, Cu	Pb, Cu	Pb, Cu
DATE	7/1/2016	7/1/2016	7/1/2016	7/1/2016
TIME	7:25 AM	7:30 AM	7:35 AM	7:50 AM
SOURCE	Central front	Kitchen sink	M.D.F	AHS W
LAB #	20160708-048	20160708-049	20160708-050	20160708-051
				20160708-052

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Arlington School Dist #3 / Atten: Kevin Hunking
P.O. Box 10 1200 Main St
Arlington, OR 97812

07/26/2016

ARLSCH

PO#:

Collection Information

Date: 07/01/2016
Time: 0700
By: Mark
Lab #: 20160708-043
Location: SWDF

Lab Receipt Information

07/08/2016
1410
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0121		0.001	mg/l	0.020	07/22/2016	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Arlington School Dist #3 / Atten: Kevin Hunking
P.O. Box 10 1200 Main St
Arlington, OR 97812

07/26/2016

ARLSCH

PO#:

Collection Information

Date: 07/01/2016
Time: 0705
By: Mark
Lab #: 20160708-044
Location: Room 1

Lab Receipt Information

07/08/2016
1410
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0660		0.001	mg/l	0.020	07/22/2016	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Arlington School Dist #3 / Atten: Kevin Hunking
P.O. Box 10 1200 Main St
Arlington, OR 97812

07/26/2016

ARLSCH

PO#:

Collection Information

Date: 07/01/2016
Time: 0710
By: Mark
Lab #: 20160708-045
Location: Room 3

Lab Receipt Information

07/08/2016
1410
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0276		0.001	mg/l	0.020	07/22/2016	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____



TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Arlington School Dist #3 / Atten: Kevin Hunking
P.O. Box 10 1200 Main St
Arlington, OR 97812

07/26/2016

ARLSCH

PO#:

Collection Information

Date: 07/01/2016
Time: 0715
By: Mark
Lab #: 20160708-046
Location: Room 6

Lab Receipt Information

07/08/2016
1410
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0148		0.001	mg/l	0.020	07/22/2016	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"


* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Arlington School Dist #3 / Atten: Kevin Hunking
P.O. Box 10 1200 Main St
Arlington, OR 97812

07/26/2016

ARLSCH

PO#:

Collection Information

Date: 07/01/2016
Time: 0720
By: Mark
Lab #: 20160708-047
Location: staff room

Lab Receipt Information

07/08/2016
1410
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0462		0.001	mg/l	0.020	07/22/2016	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Arlington School Dist #3 / Atten: Kevin Hunking
P.O. Box 10 1200 Main St
Arlington, OR 97812

07/26/2016

ARLSCH

PO#:

Collection Information

Date: 07/01/2016
Time: 0725
By: Mark
Lab #: 20160708-048
Location: central drinking fountain

Lab Receipt Information

07/08/2016
1410
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	0.0011		0.001	mg/l	0.020	07/22/2016	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Arlington School Dist #3 / Atten: Kevin Hunking
P.O. Box 10 1200 Main St
Arlington, OR 97812

07/26/2016

ARLSCH

PO#:

Collection Information

Date: 07/01/2016
Time: 0730
By: Mark
Lab #: 20160708-049
Location: kitchen sink

Lab Receipt Information

07/08/2016
1410
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0020		0.001	mg/l	0.020	07/22/2016	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Arlington School Dist #3 / Atten: Kevin Hunking
P.O. Box 10 1200 Main St
Arlington, OR 97812

07/26/2016

ARLSCH

PO#:

Collection Information

Date: 07/01/2016
Time: 0735
By: Mark
Lab #: 20160708-050
Location: W.D.F.

Lab Receipt Information

07/08/2016
1410
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	Tech
							Limit	Date Time	
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	07/22/2016	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Arlington School Dist #3 / Atten: Kevin Hunking
P.O. Box 10 1200 Main St
Arlington, OR 97812

07/26/2016

ARLSCH

PO#:

Collection Information

Date: 07/01/2016
Time: 0750
By: Mark
Lab #: 20160708-051
Location: AHS E

Lab Receipt Information

07/08/2016
1410
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	07/22/2016	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"


* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Arlington School Dist #3 / Atten: Kevin Hunking
P.O. Box 10 1200 Main St
Arlington, OR 97812

07/26/2016

ARLSCH

PO#:

Collection Information

Date: 07/01/2016
Time: 0755
By: Mark
Lab #: 20160708-052
Location: AHS W

Lab Receipt Information

07/08/2016
1410
RD

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	07/22/2016	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

Customer