

## ADDENDUM NO. 2

The following information is being offered to the Bidders for the Marysville School District #25 02-2020  
Installation of Fire Alarm/Evac System – 2 Way Communication System Bid:

Project location,

Sunnyside Elementary, Kellogg Marsh Elementary, ECEAP Preschool

Scope: Provide all equipment and labor for a new Addressable Fire Alarm system with voice evac that meets or exceeds current WA adopted RCW/IFC/NFPA/NEC standards. Provide new Addressable smoke/heat/CO detectors and addressable pull stations where required throughout the building. Provide new addressable Fire Alarm/Emergency Voice system and 2-way communication system to all schools including the portables. Install an AES wireless Radio for monitoring of the fire alarm system. Provide ADA compliant ceiling and wall speaker/strobes. Provide weatherproof speaker/strobes on the exterior of the buildings including portables. All detection throughout the schools will be brought up to current code requirements, including supervision of existing fire protection systems (i.e. fire sprinklers and kitchen hoods). 2-way communication will bring the school up to current code requirement. This scope includes all manual alarms, smoke detectors, heat detectors, CO detectors and voice evacuation. The 2-way communication will include a main communication call center and remote call boxes. All Fire Alarm/2-way communication cabling will be installed open air and in Emt conduit where necessary. Contractor will design/submittal/plan review and approval from Marysville Fire Department plan review. The contractor is responsible for the final inspection with the Fire Marshal.

Contractor must comply with intents and affidavit for Prevailing wage.

- Board action May 18<sup>th</sup>, 2020
- Award letter May 19<sup>th</sup>, 2020
- Projected start Date June 1<sup>st</sup>, 2020
- Completion Date, all locations, August 28<sup>th</sup>, 2020