

ADDENDUM NO. 3

The following information is being offered to the Bidders for the Marysville School District #25 02-2020
Fire Alarm/Evac System – 2 Way Communication System:

- 1) The Bid due date has been extended to Tuesday, May 12, 2020. All bid are due by 10AM.
- 2) Board Action/Recommendation Monday, June 1, 2020
- 3) Award Letter June 3, 2020
- 4) Estimated start date: Monday, June 15, 2020 or after
- 5) Substantial project completion date: August 28, 2020
- 6) Any work to be performed after September 8, 2020 will be performed after the normal school day ends, 4:30 PM or on weekends.
- 7) The buildings are to remain under fire protection at all times.
- 8) Are fire alarm as-built drawings available? No, bidder can supply
- 9) Are scaled architectural drawings available? Yes, for review purposes only by appointment.
- 10) Are Mechanical drawings available? No
- 11) Kellogg Marsh Elementary stage area is protected with Sprinkler? Yes
- 12) Sunnyside Elementary portable single sprinkler head in vestibule is off of domestic and not required to turned-in to a sprinkler riser? Yes, this is not required
- 13) Sunnyside Elementary hood suppression system is abandoned and stays as is? Yes, abandoned, okay per Fire Marshall.
- 14) Valuation of this project? Unknown
- 15) Due to COVID 19 can the bid deposit be waived? Yes
- 16) Can a copy of the last annual fire alarm inspection report be made available for each school?
Yes, email Purchasing@MSD25.org your request.
- 17) Will the District be providing CAD background for each project to winning contractor? No
- 18) What is the IFC edition this project is considered under? 2015 or 2018 edition? 2015

- 19) Please provide IFC/IBC/WA State amendment and/or Marysville Municipal Code section of the code describing intent and requirements of 2-way communication (IE: IFC 2015, section 1009.8)? See attached IFC and IBC Sections 1009, they have the 2-way communication system requirements. The IFC copies include the WA amendments, but we don't have the IBC WA amendments. The following link maybe helpful and documents
<https://app.leg.wa.gov/WAC/default.aspx?cite=51-54A-0907>
- 20) CO detectors code referenced or exact location requirements/quantities? Work with Marysville Fire Marshall and attached documents.
- 21) IFC 2015 edition 907.2.3 as well as WA-State emergency section reads "when automatic sprinklers systems or smoke detectors are installed." Please describe the intent on all detection throughout the schools will be brought up to current code under scope of work. Work with Marysville Fire Marshall and attached documents.