

April 1, 2020

Mr. Joshua Brumagin
Westfield Academy and Central School District
Director of Facilities
203 East Main Street
Westfield, New York 14787

Re: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Brumagin:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Westfield CSD, including:

- Westfield Academy and Central School Building
- Wayside Building
- Bus Garage

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on February 18, 2020. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, fourteen (14) sources of potable water in District buildings have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Westfield Central School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

Westfield Central School District

Prepared by:



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Conditions as of February 18, 2020

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Westfield Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Westfield Academy and Central School Building
- Wayside Building
- Bus Garage

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets in Westfield Central School Buildings. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***‘3Ts for Reducing Lead in Drinking Water in Schools’***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb	Number of Samples at or Below the NYS Action level of 15 ppb	Number of Samples Above the NYS Action Level of 15 ppb
Westfield Academy	2/18/2020	196	183	13	N/A	N/A
Wayside Building	2/18/2020	6	5	1	N/A	N/A
Bus Garage	2/18/2020	2	2	0	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Westfield Academy

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
114.1-9	Soup Hose	S	15.5
114.1-35	Rm 136	S	1330
*114.1-39	Women's Room	S	Not Analyzed
114.1-42	Rm 137	S	17.7
114.1-44	District Office Restroom	S	21.6
114.1-46	Locker room	S	15.3
114.1-85	Rm 224	S	32.6
114.1-85A	Rm 224	S	52.0
114.1-115	Rm 206	S	31.2
114.1-116	Rm 206	B	53.2
114.1-137	Rm 101	S	26.6
114.1-139	Rm 102	S	27.0
114.1-146	Rm 106	S	64.0
114.1-148	Rm 106	S	56.4
*114.1-193	Girls Lockers Room – Office Lav.	S	Not Analyzed

Wayside Building

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
114.2-2	Garage Bubbler	B	103

*Sample was damaged in transit and was empty upon receipt by the lab. This location should be re-sampled and sent to the lab for analysis.

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6978004 Location:Water Fountain Result(ppb):<1.00
Client No.:114.1-3 * Sample acidified to pH <2.

Lab No.:6978005 Location:Water Fountain Result(ppb):<1.00
Client No.:114.1-4 * Sample acidified to pH <2.

Lab No.:6978006 Location:Kitchen Sink Near Ice Maker Result(ppb):1.40
Client No.:114.1-5 * Sample acidified to pH <2.

Lab No.:6978007 Location:Ice Maker Result(ppb):<1.00
Client No.:114.1-6 * Sample acidified to pH <2.

Lab No.:6978008 Location:Sink Near Stove Result(ppb):<1.00
Client No.:114.1-7 * Sample acidified to pH <2.

Lab No.:6978009 Location:Sink Near Stove Result(ppb):4.60
Client No.:114.1-8 * Sample acidified to pH <2.


Lab No.:6978010 Location:Soup Hose Result(ppb):15.5
Client No.:114.1-9 * Sample acidified to pH <2.


Lab No.:6978011 Location:Kitchen Men's Room Result(ppb):1.60
Client No.:114.1-10 * Sample acidified to pH <2.

Lab No.:6978012 Location:Kitchen Women's Room Result(ppb):3.40
Client No.:114.1-11 * Sample acidified to pH <2.

Lab No.:6978013 Location:Restroom Result(ppb):1.60
Client No.:114.1-12 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 02/28/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6978014 **Location:**Drinking Fountain **Result(ppb):**<1.00
Client No.:114.1-13 * Sample acidified to pH <2.

Lab No.:6978015 **Location:**Room 164 **Result(ppb):**2.40
Client No.:114.1-14 * Sample acidified to pH <2.

Lab No.:6978016 **Location:**Water Fountain **Result(ppb):**<1.00
Client No.:114.1-15 * Sample acidified to pH <2.

Lab No.:6978017 **Location:**Water Fountain **Result(ppb):**<1.00
Client No.:114.1-16 * Sample acidified to pH <2.

Lab No.:6978018 **Location:**Sink **Result(ppb):**2.50
Client No.:114.1-17 * Sample acidified to pH <2.

Lab No.:6978019 **Location:**Room 170 Men's Room **Result(ppb):**3.70
Client No.:114.1-18 * Sample acidified to pH <2.


Lab No.:6978020 **Location:**Room 170 Men's Room **Result(ppb):**6.90
Client No.:114.1-19 * Sample acidified to pH <2.


Lab No.:6978021 **Location:**Room 170 Men's Room **Result(ppb):**2.90
Client No.:114.1-20 * Sample acidified to pH <2.

Lab No.:6978022 **Location:**Room 171 Women's Room **Result(ppb):**2.70
Client No.:114.1-21 * Sample acidified to pH <2.

Lab No.:6978023 **Location:**Room 171 Women's Room **Result(ppb):**<1.00
Client No.:114.1-22 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 02/28/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6978024 **Location:**Room 171 Women's Room **Result(ppb):**2.80
Client No.:114.1-23 * Sample acidified to pH <2.

Lab No.:6978025 **Location:**Drinking Fountain **Result(ppb):**<1.00
Client No.:114.1-24 * Sample acidified to pH <2.

Lab No.:6978026 **Location:**Drinking Fountain **Result(ppb):**<1.00
Client No.:114.1-25 * Sample acidified to pH <2.

Lab No.:6978027 **Location:**Drinking Fountain **Result(ppb):**<1.00
Client No.:114.1-26 * Sample acidified to pH <2.

Lab No.:6978028 **Location:**Restroom **Result(ppb):**2.50
Client No.:114.1-27 * Sample acidified to pH <2.

Lab No.:6978029 **Location:**Library **Result(ppb):**4.10
Client No.:114.1-28 * Sample acidified to pH <2.


Lab No.:6978030 **Location:**Boy's Restroom **Result(ppb):**<1.00
Client No.:114.1-30 * Sample acidified to pH <2.


Lab No.:6978031 **Location:**Boy's Restroom **Result(ppb):**<1.00
Client No.:114.1-31 * Sample acidified to pH <2.

Lab No.:6978032 **Location:**Drinking Fountain **Result(ppb):**<1.00
Client No.:114.1-32 * Sample acidified to pH <2.

Lab No.:6978033 **Location:**Girl's Bathroom **Result(ppb):**<1.00
Client No.:114.1-33 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 02/28/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978034 Location: Girl's Bathroom Result(ppb): <1.00
Client No.: 114.1-34 * Sample acidified to pH <2.

Lab No.: 6978035 Location: Room 136 Result(ppb): 1330
Client No.: 114.1-35 * Sample acidified to pH <2.

Lab No.: 6978036 Location: Room 136 Result(ppb): 7.20
Client No.: 114.1-36 * Sample acidified to pH <2.

Lab No.: 6978037 Location: Outside 136 Result(ppb): <1.00
Client No.: 114.1-37 * Sample acidified to pH <2.

Lab No.: 6978038 Location: Women's Room Result(ppb): 6.20
Client No.: 114.1-38 * Sample acidified to pH <2.

Lab No.: 6978039 Location: Women's Room Result(ppb): Sample Not Analyzed
Client No.: 114.1-39 * Sample acidified to pH <2.
Bottle Received Empty


Lab No.: 6978040 Location: Restroom Result(ppb): 10.1
Client No.: 114.1-40 * Sample acidified to pH <2.


Lab No.: 6978041 Location: Room 137 Result(ppb): 9.10
Client No.: 114.1-41 * Sample acidified to pH <2.

Lab No.: 6978042 Location: Room 137 Result(ppb): 17.7
Client No.: 114.1-42 * Sample acidified to pH <2.

Lab No.: 6978043 Location: Room 138 Result(ppb): 6.50
Client No.: 114.1-43 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 02/28/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6978044
Client No.:114.1-44

Location:District Office Restroom
* Sample acidified to pH <2.

Result(ppb):21.6

Lab No.:6978045
Client No.:114.1-45

Location:District Office
* Sample acidified to pH <2.

Result(ppb):<1.00

Lab No.:6978046
Client No.:114.1-46

Location:Locker Room
* Sample acidified to pH <2.

Result(ppb):15.3

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 2/26/2020

Date Analyzed: 02/28/2020

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978047 Location: Drinking Fountain Result(ppb): <1.00
Client No.: 114.1-47 * Sample acidified to pH <2.

Lab No.: 6978048 Location: Locker Room Result(ppb): 1.10
Client No.: 114.1-48 * Sample acidified to pH <2.

Lab No.: 6978049 Location: Locker Room Result(ppb): 2.80
Client No.: 114.1-49 * Sample acidified to pH <2.

Lab No.: 6978050 Location: Locker Room Result(ppb): 1.20
Client No.: 114.1-50 * Sample acidified to pH <2.

Lab No.: 6978051 Location: Gym Office Result(ppb): 2.60
Client No.: 114.1-51 * Sample acidified to pH <2.

Lab No.: 6978052 Location: Gym Office Result(ppb): <1.00
Client No.: 114.1-52 * Sample acidified to pH <2.


Lab No.: 6978053 Location: Gym Office Restroom Result(ppb): 3.30
Client No.: 114.1-53 * Sample acidified to pH <2.


Lab No.: 6978054 Location: Locker Room Result(ppb): 4.10
Client No.: 114.1-54 * Sample acidified to pH <2.

Lab No.: 6978055 Location: Room 179 Result(ppb): <1.00
Client No.: 114.1-55 * Sample acidified to pH <2.

Lab No.: 6978056 Location: Room 179 Result(ppb): 2.80
Client No.: 114.1-56 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 02/29/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978057 Location: Room 180 Result(ppb): <1.00
Client No.: 114.1-57 * Sample acidified to pH <2.

Lab No.: 6978058 Location: Room 180 Result(ppb): 5.30
Client No.: 114.1-58 * Sample acidified to pH <2.

Lab No.: 6978059 Location: Men's Room Result(ppb): <1.00
Client No.: 114.1-59 * Sample acidified to pH <2.

Lab No.: 6978060 Location: Room 184 Women's Room Result(ppb): <1.00
Client No.: 114.1-60 * Sample acidified to pH <2.

Lab No.: 6978061 Location: Outside Room 183 Result(ppb): <1.00
Client No.: 114.1-61 * Sample acidified to pH <2.

Lab No.: 6978062 Location: Weight Room Result(ppb): 2.90
Client No.: 114.1-62 * Sample acidified to pH <2.


Lab No.: 6978063 Location: Weight Room Result(ppb): 1.00
Client No.: 114.1-63 * Sample acidified to pH <2.


Lab No.: 6978064 Location: Weight Room Result(ppb): 5.80
Client No.: 114.1-64 * Sample acidified to pH <2.

Lab No.: 6978065 Location: Weight Room Result(ppb): 1.80
Client No.: 114.1-65 * Sample acidified to pH <2.

Lab No.: 6978066 Location: Room 187 Result(ppb): <1.00
Client No.: 114.1-66 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 02/29/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978067 Location: Room 187 Result(ppb): 1.20
Client No.: 114.1-67 * Sample acidified to pH <2.

Lab No.: 6978068 Location: Room 187 Result(ppb): 1.40
Client No.: 114.1-68 * Sample acidified to pH <2.

Lab No.: 6978069 Location: Room 187 Result(ppb): <1.00
Client No.: 114.1-69 * Sample acidified to pH <2.

Lab No.: 6978070 Location: Room 196 Result(ppb): <1.00
Client No.: 114.1-70 * Sample acidified to pH <2.

Lab No.: 6978071 Location: Room 196 Result(ppb): <1.00
Client No.: 114.1-71 * Sample acidified to pH <2.

Lab No.: 6978072 Location: Room 194 Result(ppb): <1.00
Client No.: 114.1-72 * Sample acidified to pH <2.


Lab No.: 6978073 Location: Room 194 Result(ppb): <1.00
Client No.: 114.1-73 * Sample acidified to pH <2.


Lab No.: 6978074 Location: Room 190 Result(ppb): <1.00
Client No.: 114.1-74 * Sample acidified to pH <2.

Lab No.: 6978075 Location: Room 190 Result(ppb): <1.00
Client No.: 114.1-75 * Sample acidified to pH <2.

Lab No.: 6978076 Location: Room 236 Result(ppb): 1.40
Client No.: 114.1-76 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 02/29/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978077 Location: Room 226 Result(ppb): 6.50
Client No.: 114.1-81 * Sample acidified to pH <2.

Lab No.: 6978078 Location: Room 226 Result(ppb): 3.50
Client No.: 114.1-82 * Sample acidified to pH <2.

Lab No.: 6978079 Location: Room 226 Result(ppb): 2.30
Client No.: 114.1-83 * Sample acidified to pH <2.

Lab No.: 6978080 Location: Room 226 Result(ppb): 2.30
Client No.: 114.1-84 * Sample acidified to pH <2.

Lab No.: 6978081 Location: Room 224 Result(ppb): 32.6
Client No.: 114.1-85 * Sample acidified to pH <2.

Lab No.: 6978082 Location: Room 224 Result(ppb): 52.0
Client No.: 114.1-85A * Sample acidified to pH <2.


Lab No.: 6978083 Location: Water Fountain Result(ppb): <1.00
Client No.: 114.1-86 * Sample acidified to pH <2.


Lab No.: 6978084 Location: Room 216 Result(ppb): 14.9
Client No.: 114.1-87 * Sample acidified to pH <2.

Lab No.: 6978085 Location: Room 216 Result(ppb): 8.20
Client No.: 114.1-88 * Sample acidified to pH <2.

Lab No.: 6978086 Location: Room 215 Result(ppb): 3.70
Client No.: 114.1-89 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 02/29/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708


LEAD WATER SAMPLE ANALYSIS SUMMARY


Lab No.:6978087
Client No.:114.1-90

Location:Room 215
* Sample acidified to pH <2.

Result(ppb):8.90

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 02/29/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978088	Location: Faculty Restroom	Result(ppb): 2.70
Client No.: 114.1-93	* Sample acidified to pH <2.	

Lab No.: 6978089	Location: Room 240	Result(ppb): <1.00
Client No.: 114.1-93	* Sample acidified to pH <2.	

Lab No.: 6978090	Location: Room 201	Result(ppb): 6.00
Client No.: 114.1-103	* Sample acidified to pH <2.	

Lab No.: 6978091	Location: Room 201	Result(ppb): 1.20
Client No.: 114.1-104	* Sample acidified to pH <2.	

Lab No.: 6978092	Location: Room 201	Result(ppb): 3.80
Client No.: 114.1-105	* Sample acidified to pH <2.	

Lab No.: 6978093	Location: Room 202	Result(ppb): 1.90
Client No.: 114.1-106	* Sample acidified to pH <2.	


Lab No.: 6978094	Location: Room 202	Result(ppb): 3.30
Client No.: 114.1-107	* Sample acidified to pH <2.	


Lab No.: 6978095	Location: Room 202	Result(ppb): 11.8
Client No.: 114.1-108	* Sample acidified to pH <2.	

Lab No.: 6978096	Location: Room 203	Result(ppb): 5.10
Client No.: 114.1-109	* Sample acidified to pH <2.	

Lab No.: 6978097	Location: Room 203	Result(ppb): 2.90
Client No.: 114.1-110	* Sample acidified to pH <2.	

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/02/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978098 Location: Room 203 Result(ppb): 4.30
Client No.: 114.1-111 * Sample acidified to pH <2.

Lab No.: 6978099 Location: Room 204 Result(ppb): 6.20
Client No.: 114.1-112 * Sample acidified to pH <2.

Lab No.: 6978100 Location: Room 204 Result(ppb): 7.20
Client No.: 114.1-113 * Sample acidified to pH <2.

Lab No.: 6978101 Location: Room 204 Result(ppb): 3.80
Client No.: 114.1-114 * Sample acidified to pH <2.

Lab No.: 6978102 Location: Room 206 Result(ppb): 31.2
Client No.: 114.1-115 * Sample acidified to pH <2.

Lab No.: 6978103 Location: Room 206 Result(ppb): 53.2
Client No.: 114.1-116 * Sample acidified to pH <2.


Lab No.: 6978104 Location: Room 205 Result(ppb): 6.50
Client No.: 114.1-117 * Sample acidified to pH <2.


Lab No.: 6978105 Location: Room 205 Result(ppb): 8.80
Client No.: 114.1-118 * Sample acidified to pH <2.

Lab No.: 6978106 Location: Outside Room 205 Result(ppb): 3.50
Client No.: 114.1-119 * Sample acidified to pH <2.

Lab No.: 6978107 Location: Speech Bathroom Result(ppb): 4.30
Client No.: 114.1-120 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/02/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978108 Location: Bathroom Result(ppb): 1.70
Client No.: 114.1-121 * Sample acidified to pH <2.

Lab No.: 6978109 Location: Room 208 Result(ppb): 3.20
Client No.: 114.1-122 * Sample acidified to pH <2.

Lab No.: 6978110 Location: Room 207 Result(ppb): 5.60
Client No.: 114.1-124 * Sample acidified to pH <2.

Lab No.: 6978111 Location: Room 207 Result(ppb): 5.40
Client No.: 114.1-125 * Sample acidified to pH <2.

Lab No.: 6978112 Location: Room 210 Result(ppb): 4.80
Client No.: 114.1-126 * Sample acidified to pH <2.

Lab No.: 6978113 Location: Room 210 Result(ppb): 5.80
Client No.: 114.1-127 * Sample acidified to pH <2.


Lab No.: 6978114 Location: Room 209 Result(ppb): 4.00
Client No.: 114.1-128 * Sample acidified to pH <2.


Lab No.: 6978115 Location: Room 209 Result(ppb): 5.80
Client No.: 114.1-129 * Sample acidified to pH <2.

Lab No.: 6978116 Location: Room 212 Result(ppb): 8.30
Client No.: 114.1-130 * Sample acidified to pH <2.

Lab No.: 6978117 Location: Room 212 Result(ppb): 2.80
Client No.: 114.1-131 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/02/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978118 Location: Room 211 Result(ppb): 4.00
Client No.: 114.1-132 * Sample acidified to pH <2.

Lab No.: 6978119 Location: Room 211 Result(ppb): 5.00
Client No.: 114.1-133 * Sample acidified to pH <2.

Lab No.: 6978120 Location: Room 213 Result(ppb): 12.8
Client No.: 114.1-134 * Sample acidified to pH <2.

Lab No.: 6978121 Location: Room 213 Result(ppb): <1.00
Client No.: 114.1-135 * Sample acidified to pH <2.

Lab No.: 6978122 Location: Room 101 Result(ppb): 5.90
Client No.: 114.1-136 * Sample acidified to pH <2.

Lab No.: 6978123 Location: Room 101 Result(ppb): 26.6
Client No.: 114.1-137 * Sample acidified to pH <2.


Lab No.: 6978124 Location: Room 102 Result(ppb): 4.70
Client No.: 114.1-138 * Sample acidified to pH <2.


Lab No.: 6978125 Location: Room 104 Result(ppb): 2.10
Client No.: 114.1-140 * Sample acidified to pH <2.

Lab No.: 6978126 Location: Room 102 Result(ppb): 27.0
Client No.: 114.1-139 * Sample acidified to pH <2.

Lab No.: 6978127 Location: Room 104 Result(ppb): 1.80
Client No.: 114.1-141 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/02/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978128 Location: Room 104 Result(ppb): 14.4
Client No.: 114.1-142 * Sample acidified to pH <2.

Lab No.: 6978129 Location: Room 105 Result(ppb): 6.40
Client No.: 114.1-143 * Sample acidified to pH <2.

Lab No.: 6978130 Location: Room 105 Result(ppb): 4.10
Client No.: 114.1-144 * Sample acidified to pH <2.

Lab No.: 6978131 Location: Room 105 Result(ppb): 7.20
Client No.: 114.1-145 * Sample acidified to pH <2.

Lab No.: 6978132 Location: Room 106 Result(ppb): 64.0
Client No.: 114.1-146 * Sample acidified to pH <2.

Lab No.: 6978133 Location: Room 106 Result(ppb): 1.30
Client No.: 114.1-147 * Sample acidified to pH <2.


Lab No.: 6978134 Location: Room 106 Result(ppb): 56.4
Client No.: 114.1-148 * Sample acidified to pH <2.


Lab No.: 6978135 Location: Room 107 Result(ppb): 4.60
Client No.: 114.1-149 * Sample acidified to pH <2.

Lab No.: 6978136 Location: Room 107 Result(ppb): <1.00
Client No.: 114.1-150 * Sample acidified to pH <2.

Lab No.: 6978137 Location: Room 107 Result(ppb): 6.50
Client No.: 114.1-151 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/02/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978138 Location: Room 108 Result(ppb): 6.50
Client No.: 114.1-152 * Sample acidified to pH <2.

Lab No.: 6978139 Location: Room 108 Result(ppb): 3.50
Client No.: 114.1-153 * Sample acidified to pH <2.

Lab No.: 6978140 Location: Room 108 Result(ppb): 2.20
Client No.: 114.1-154 * Sample acidified to pH <2.

Lab No.: 6978141 Location: Room 109 Result(ppb): 14.3
Client No.: 114.1-155 * Sample acidified to pH <2.

Lab No.: 6978142 Location: Room 109 Result(ppb): 3.30
Client No.: 114.1-156 * Sample acidified to pH <2.

Lab No.: 6978143 Location: Room 109 Result(ppb): 3.90
Client No.: 114.1-157 * Sample acidified to pH <2.


Lab No.: 6978144 Location: Room 110 Result(ppb): 6.30
Client No.: 114.1-158 * Sample acidified to pH <2.


Lab No.: 6978145 Location: Room 110 Result(ppb): 2.20
Client No.: 114.1-159 * Sample acidified to pH <2.

Lab No.: 6978146 Location: Room 110 Result(ppb): 4.40
Client No.: 114.1-160 * Sample acidified to pH <2.

Lab No.: 6978147 Location: Room 111 Result(ppb): 12.7
Client No.: 114.1-161 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/02/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978148 Location: Room 111 Result(ppb): 2.80
Client No.: 114.1-162 * Sample acidified to pH <2.

Lab No.: 6978149 Location: Room 111 Result(ppb): 4.00
Client No.: 114.1-163 * Sample acidified to pH <2.

Lab No.: 6978150 Location: Room 112 Result(ppb): 2.20
Client No.: 114.1-164 * Sample acidified to pH <2.

Lab No.: 6978151 Location: Room 112 Result(ppb): 1.60
Client No.: 114.1-165 * Sample acidified to pH <2.

Lab No.: 6978152 Location: Room 112 Result(ppb): 1.60
Client No.: 114.1-166 * Sample acidified to pH <2.

Lab No.: 6978153 Location: Room 113 Result(ppb): 6.10
Client No.: 114.1-167 * Sample acidified to pH <2.


Lab No.: 6978154 Location: Room 113 Result(ppb): 1.50
Client No.: 114.1-168 * Sample acidified to pH <2.


Lab No.: 6978155 Location: Room 113 Result(ppb): 2.40
Client No.: 114.1-169 * Sample acidified to pH <2.

Lab No.: 6978156 Location: Room 114 Result(ppb): 3.30
Client No.: 114.1-170 * Sample acidified to pH <2.

Lab No.: 6978157 Location: Room 114 Result(ppb): 3.30
Client No.: 114.1-171 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/02/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6978158 Location:Room 114 Result(ppb):11.8
Client No.:114.1-172 * Sample acidified to pH <2.

Lab No.:6978159 Location:Room 115 Result(ppb):2.00
Client No.:114.1-173 * Sample acidified to pH <2.

Lab No.:6978160 Location:Room 115 Result(ppb):2.00
Client No.:114.1-174 * Sample acidified to pH <2.

Lab No.:6978161 Location:Room 115 Result(ppb):2.60
Client No.:114.1-175 * Sample acidified to pH <2.

Lab No.:6978162 Location:Room 116 Result(ppb):2.60
Client No.:114.1-176 * Sample acidified to pH <2.

Lab No.:6978163 Location:Room 116 Result(ppb):1.10
Client No.:114.1-177 * Sample acidified to pH <2.


Lab No.:6978164 Location:Room 116 Result(ppb):12.6
Client No.:114.1-178 * Sample acidified to pH <2.


Lab No.:6978165 Location:Room 118b Result(ppb):2.00
Client No.:114.1-179 * Sample acidified to pH <2.

Lab No.:6978166 Location:Room 118 Result(ppb):3.30
Client No.:114.1-180 * Sample acidified to pH <2.

Lab No.:6978167 Location:Room 118 Result(ppb):6.20
Client No.:114.1-181 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/02/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708


LEAD WATER SAMPLE ANALYSIS SUMMARY


Lab No.:6978168
Client No.:114.1-182

Location:Room 118
* Sample acidified to pH <2.

Result(ppb):2.50

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/02/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978169	Location: Nurse Office	Result(ppb): 3.70
Client No.: 114.1-183	* Sample acidified to pH <2.	

Lab No.: 6978170	Location: Nurse Office	Result(ppb): 1.60
Client No.: 114.1-184	* Sample acidified to pH <2.	

Lab No.: 6978171	Location: Nurse Office	Result(ppb): 3.10
Client No.: 114.1-185	* Sample acidified to pH <2.	

Lab No.: 6978172	Location: Drinking Fountain	Result(ppb): <1.00
Client No.: 114.1-186	* Sample acidified to pH <2.	

Lab No.: 6978173	Location: Elementary Office	Result(ppb): 2.90
Client No.: 114.1-187	* Sample acidified to pH <2.	

Lab No.: 6978174	Location: Elementary Office	Result(ppb): 1.40
Client No.: 114.1-188	* Sample acidified to pH <2.	


Lab No.: 6978175	Location: Elementary Office	Result(ppb): 1.10
Client No.: 114.1-189	* Sample acidified to pH <2.	


Lab No.: 6978176	Location: Men's Room	Result(ppb): 2.80
Client No.: 114.1-190	* Sample acidified to pH <2.	

Lab No.: 6978177	Location: Women's Room	Result(ppb): 2.50
Client No.: 114.1-191	* Sample acidified to pH <2.	

Lab No.: 6978178	Location: Room 122	Result(ppb): 1.90
Client No.: 114.1-192	* Sample acidified to pH <2.	

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/03/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978179	Location: Girl's Locker Room	Result(ppb): Sample Not Received
Client No.: 114.1-193	* Sample acidified to pH <2.	

Lab No.: 6978180	Location: Girl's Locker Room	Result(ppb): <1.00
Client No.: 114.1-195	* Sample acidified to pH <2.	

Lab No.: 6978181	Location: Girl's Locker Room	Result(ppb): 1.10
Client No.: 114.1-196	* Sample acidified to pH <2.	

Lab No.: 6978182	Location: Girl's Locker Room	Result(ppb): 1.30
Client No.: 114.1-197	* Sample acidified to pH <2.	

Lab No.: 6978183	Location: Additional Sample Received	Result(ppb): <1.00
Client No.: 114.1-198	* Sample acidified to pH <2.	


Lab No.: 6978184	Location: Elem. Gym Corridor; Additional Sample	Result(ppb): <1.00
Client No.: 114.1-199	Received * Sample acidified to pH <2.	


Lab No.: 6978185	Location: Across From 212; Additional Sample Received	Result(ppb): <1.00
Client No.: 114.1-200	* Sample acidified to pH <2.	

Lab No.: 6978186	Location: Corr. 200A Boy's Lav; Additional Sample	Result(ppb): <1.00
Client No.: 114.1-201	Received * Sample acidified to pH <2.	

Lab No.: 6978187	Location: Corr. 200A Boy's Lav; Additional Sample	Result(ppb): <1.00
Client No.: 114.1-202	Received * Sample acidified to pH <2.	

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/03/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978188
Client No.: 114.1-203
Location: Corr. 200A Boy's Lav; Additional Sample Received
* Sample acidified to pH <2. **Result(ppb):** <1.00

Lab No.: 6978189
Client No.: 114.1-204
Location: Corr. 200A Girl's Lav; Additional Sample Received
* Sample acidified to pH <2. **Result(ppb):** <1.00

Lab No.: 6978190
Client No.: 114.1-205
Location: Corr. 200A Girl's Lav; Additional Sample Received
* Sample acidified to pH <2. **Result(ppb):** <1.00

Lab No.: 6978191
Client No.: 114.1-206
Location: Corr. 200A Girl's Lav; Additional Sample Received
* Sample acidified to pH <2. **Result(ppb):** 1.30


Lab No.: 6978192
Client No.: 114.1-207
Location: Corr. 237 Boy's Lav; Additional Sample Received
* Sample acidified to pH <2. **Result(ppb):** 1.60


Lab No.: 6978193
Client No.: 114.1-208
Location: Corr. 237 Boy's Lav; Additional Sample Received
* Sample acidified to pH <2. **Result(ppb):** 1.50

Lab No.: 6978194
Client No.: 114.1-209
Location: Corr. 237 Boy's Lav; Additional Sample Received
* Sample acidified to pH <2. **Result(ppb):** 1.40

Lab No.: 6978195
Client No.: 114.1-210
Location: Corr. 237; Additional Sample Received
* Sample acidified to pH <2. **Result(ppb):** 1.30

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/03/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6978196 Location: Corr. 237 Girl's Lav; Additional Sample Result(ppb): 3.90
Client No.: 114.1-211 Received
* Sample acidified to pH <2.


Lab No.: 6978197 Location: Corr. 237 Girl's Lav; Additional Sample Result(ppb): 1.60
Client No.: 114.1-212 Received
* Sample acidified to pH <2.


Lab No.: 6978198 Location: Corr. 237 Girl's Lav; Additional Sample Result(ppb): 3.00
Client No.: 114.1-213 Received
* Sample acidified to pH <2.

Lab No.: 6978199 Location: Additional Sample Received Result(ppb): 4.50
Client No.: 114.1-92 * Sample acidified to pH <2.

Lab No.: 6978200 Location: Additional Sample Received Result(ppb): 7.20
Client No.: 114.1-194 * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/26/2020
Date Analyzed: 03/03/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

Appendix to Analytical Report:

Customer Contact: Lab Results Final
Analysis: AAS-GF - ASTM D3559-08D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: ?wchampion@iatl.com
iATL Account Representative: Shirley Clark
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B

- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 3/3/2020
Report No.: 610401 - Lead Water
Project: Westfield CSD; Westfield Academy and
Central School
Project No.: 2020L-114

Client: STO708

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 2/28/2020
Report No.: 610400 - Lead Water
Project: Westfield CSD; Wayside Bldg
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6977998
Client No.:114.2-2

Location:Garage Bubbler
* Sample acidified to pH <2.

Result(ppb):103

Lab No.:6977999
Client No.:114.2-3

Location:Garbage Sink
* Sample acidified to pH <2.

Result(ppb):12.6

Lab No.:6978000
Client No.:114.2-4

Location:Sink
* Sample acidified to pH <2.

Result(ppb):2.20

Lab No.:6978001
Client No.:114.2-5

Location:Bubbler
* Sample acidified to pH <2.

Result(ppb):5.40

Lab No.:6978002
Client No.:114.2-6

Location:Boy's Room
* Sample acidified to pH <2.

Result(ppb):9.50

Lab No.:6978003
Client No.:114.2-7

Location:Girl's Room
* Sample acidified to pH <2.

Result(ppb):6.00

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 2/26/2020

Date Analyzed: 02/28/2020

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 2/28/2020
Report No.: 610400 - Lead Water
Project: Westfield CSD; Wayside Bldg
Project No.: 2020L-114

Appendix to Analytical Report:

Customer Contact: Lab Results Final
Analysis: AAS-GF - ASTM D3559-08D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: ?wchampion@iatl.com
iATL Account Representative: Shirley Clark
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B

- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 2/28/2020
Report No.: 610400 - Lead Water
Project: Westfield CSD; Wayside Bldg
Project No.: 2020L-114

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 2/28/2020
Report No.: 610399 - Lead Water
Project: Westfield CSD; Bus Garage
Project No.: 2020L-114

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6977996
Client No.:114.3-3

Location: Women's Room
* Sample acidified to pH <2.

Result(ppb):6.50

Lab No.:6977997
Client No.:114.3-4

Location: Men's Room
* Sample acidified to pH <2.

Result(ppb):1.20

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 2/26/2020

Date Analyzed: 02/28/2020

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 2/28/2020
Report No.: 610399 - Lead Water
Project: Westfield CSD; Bus Garage
Project No.: 2020L-114

Appendix to Analytical Report:

Customer Contact: Lab Results Final
Analysis: AAS-GF - ASTM D3559-08D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: ?wchampion@iatl.com
iATL Account Representative: Shirley Clark
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B

- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 2/28/2020
Report No.: 610399 - Lead Water
Project: Westfield CSD; Bus Garage
Project No.: 2020L-114

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2020
Issued April 01, 2019

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FRANK E. EHRENFELD III
INTERNATIONAL ASBESTOS TESTING LABS
9000 COMMERCE PARKWAY SUITE B
MOUNT LAUREL, NJ 08054

NY Lab Id No: 11021

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved subcategories and/or analytes are listed below:*

Metals I

Lead, Total ASTM D3559-90, 96, 03 & 08 (D)

Miscellaneous

Asbestos EPA 100.1
 EPA 100.2

NEW YORK STATE Department
of Health

Serial No.: 59524

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

1.6 Chains of Custody



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) iATL

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-3	Water fountain	Wf	7:00	Lzwsr_1c	6978004	
114.1-4	water fountain	WFB	7:02	Lzs8ws_1f	6978005	
114.1-5	Kitchen sink near ice maker	S	7:04	0	6978006	
114.1-6	ice maker	IM	7:06	0	6978007	
114.1-7	Sink near stove	S	7:08	0	6978008	
114.1-8	Sink near stove	S	7:10	0	6978009	
114.1-9	Soup hose	S	7:12	0	6978010	
114.1-10	Kitchen men's room	S	7:14	0	6978011	
114.1-11	Kitchen women's room	S	7:16	0	6978012	
114.1-12	Restroom	S	7:18	0	6978013	
114.1-13	drinking fountain	DF	7:20	Elkay eswa8_1m	6978014	
114.1-14	Rm 164	S	7:22	0	6978015	
114.1-15	water fountain	wf	7:24	Pbrpb-302	6978016	
114.1-16	water fountain	wf	7:26	Fprpb-302	6978017	
114.1-17	Sink	S	7:28	0	6978018	
114.1-18	Rm 170 men's room	S	7:30	0	6978019	

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

ehenderson@stohlenv.com

Sampled By: E. Henderson Jr. Print Name

Stohl Env: Eric Henderson Jr.

Date: 2/18/2020

Relinquished By: E. Henderson Jr. Print Name

Stohl Env: Eric Henderson Jr.

Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): EW 3/4/20 Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

*both labeled -4; #5 assigned randoms
*rec'd 1/2 full

RECEIVED
FEB 20 2020
iATL



Chain of Custody Document

Submitted to: (Lab Name) iATL

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-19	Rm 170 men's room	S	7:32	0	697-1020	
114.1-20	Rm 170 men's room	S	7:34	0	697-1021	
114.1-21	Rm 171 women's room	S	7:36	0	697-1022	
114.1-22	Rm 171 women's room	S	7:38	0	697-1023	
114.1-23	Rm 171 women's room	S	7:40	0	697-1024	
114.1-24	drinking fountain	DF	7:42	flf140r-002	697-1025	
114.1-25	drinking fountain	DF	7:44	Plf8shp-100	697-1026	
114.1-26	drinking fountain	DF	7:46	Cannot read	697-1027	
114.1-27	Restroom	S	7:48	0	697-1028	
114.1-28	Library	S	7:50	0	697-1029	
114.1-30	Boys restroom	S	7:54	0	697-1030	
114.1-31	Boys restroom	S	7:56	0	697-1031	
114.1-32	drinking fountain	DF	7:58	eswa8_1L	697-1032	
114.1-33	Girls bathroom	S	8:00	0	697-1033	
114.1-34	Girls bathroom	S	8:02	0	697-1034	
114.1-35	Rm 136	S	8:04	0	697-1035	
114.1-36	Rm 136	S	8:06	0	697-1036	

Notes:

Acid.

Please e-mail lab results to labs@stohlenv.com

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 2/18/2020

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) iATL

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-37	outside 136	DF	8:08	Lzwssm_1a	69.1037	
114.1-38	Women's room	S	8:10	0	69.1038	
114.1-39	Women's room	S	8:12	0	69.1039	
114.1-40	Restroom	S	8:14	0	69.1040	
114.1-41	rm 137	S	8:16	0	69.1041	
114.1-42	rm 137	S	8:18	0	69.1042	
114.1-43	rm 138	S	8:20	0	69.1043	
114.1-44	District office restroom	S	8:22	0	69.1044	
114.1-45	District office	S	8:24	0	69.1045	
114.1-46	Locker room	S	8:26	0	69.1046	
114.1-47	drinking fountain	DF	8:28	Lzwssm_1a	69.1047	
114.1-48	Locker room	S	8:30	0	69.1048	
114.1-49	Locker room	S	8:32	0	69.1049	
114.1-50	Locker room	S	8:34	0	69.1050	
114.1-51	gym office	S	8:36	0	69.1051	
114.1-52	gym office	lm	8:38	0	69.1052	
114.1-53	gym office restroom	S	8:40	0	69.1053	
114.1-54	Locker room	S	8:42	0	69.1054	

Notes:

Acid

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 2/18/2020

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

Acid empty
Acid full



Chain of Custody Document

Submitted to: (Lab Name) iATL

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
☎ (716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-55	Rm 179	S	8:44	0	609-1055	
114.1-56	Rm 179	S	8:46	0	609-1056	
114.1-57	Rm 180	S	8:48	0	609-1057	
114.1-58	Rm 180	S	8:50	0	609-1058	
114.1-59	Men's room	S	8:52	0	609-1059	
114.1-60	rm 184 women's room	S	8:54	0	609-1060	
114.1-61	outside rm 183	DF	8:56	Lisea8-1c	609-1061	
114.1-62	weight room	S	8:58	0	609-1062	
114.1-63	weight room	S	9:00	0	609-1063	
114.1-64	weight room	S	9:02	0	609-1064	
114.1-65	weight room	S	9:04	0	609-1065	
114.1-66	rm 187	S	9:06	0	609-1066	
114.1-67	rm 187	S	9:08	0	609-1067	
114.1-68	rm 187	S	9:10	0	609-1068	
114.1-69	rm 187	S	9:12	0	609-1069	
114.1-70	Rm 196	S	9:14	0	609-1070	
114.1-71	Rm 196	S	9:16	0	609-1071	
114.1-72	Rm 194	S	9:18	0	609-1072	

Notes:

Acid.

Please e-mail lab results to labs@stohlenv.com

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 2/18/2020

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) iATL

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8992
www.stohlenvironmental.com

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-73	Rm 194	S	9:20	0	6973073	
114.1-74	Rm 190	S	9:22	0	6973074	
114.1-75	Rm 190	S	9:24	0	6973075	
114.1-76	Rm 236	S	9:26	0	6973076	
				0		
				0		
				0		
114.1-81	Rm 226	S	9:36	0	6973077	
114.1-82	Rm 226	S	9:38	0	6973078	
114.1-83	Rm 226	S	9:40	0	6973079	
114.1-84	Rm 226	S	9:42	0		
114.1-85	Rm 224	S	9:44	0	6973080	
114.1-85A	Rm 224	S	9:44	0	6973081	
114.1-86	Water fountain	DF	9:46	lzwssm_1a	6973082	
114.1-87	Rm 216	S	9:48	0	6973083	
114.1-88	Rm 216	B	9:50	0	6973084	
114.1-89	Rm 215	S	9:52	0	6973085	
114.1-90	Rm 215	B	9:54	0	6973086	

Notes:

Acid. 2/26/20 21:55
Please e-mail lab results to labs@stohlenv.com

Sampled By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/18/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) iATL

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-91	faculty restroom	S	9:56	0	697-1088	
114.1-92	Library	S	9:58	0		
114.1-93	Rm 240	S	10:00	0	697-1089	
				0		
				0		
				0		
				0		
				0		
				0		
				0		
				0		
				0		
114.1-103	Rm 201	S	10:20	0	697-1090	
114.1-104	Rm 201	B	10:22	0	697-1091	
114.1-105	Rm 201	S	10:24	0	697-1092	
114.1-106	Rm 202	S	10:26	0	697-1093	
114.1-107	Rm 202	B	10:28	0	697-1094	
114.1-108	Rm 202	S	10:30	0	697-1095	

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/18/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) iATL

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
☎ (716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-109	Rm 203	S	10:32	0	6971109	
114.1-110	Rm 203	B	10:34	0	6971110	
114.1-111	Rm 203	S	10:36	0	6971111	
114.1-112	Rm 204	S	10:38	0	6971112	
114.1-113	Rm 204	B	10:40	0	6971113	
114.1-114	Rm 204	S	10:42	0	6971114	
114.1-115	Rm 206	S	10:44	0	6971115	
114.1-116	Rm 206	B	10:46	0	6971116	
114.1-117	rm 205	S	10:48	0	6971117	
114.1-118	rm 205	B	10:50	0	6971118	
114.1-119	outside room 205	DF	10:52	Edfp114c	6971119	
114.1-120	speech bathroom	S	10:54	0	6971120	
114.1-121	Bathroom	S	10:56	0	6971121	
114.1-122	Rm 208	S	10:58	0	6971122	
				0		
114.1-124	rm 207	S	11:02	0	6971124	
114.1-125	rm 207	B	11:04	0	6971125	
114.1-126	Rm 210	S	11:06	0	6971126	

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 2/18/2020

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) iATL

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-127	Rm 210	B	11:08	0	6973127	
114.1-128	Rm 209	S	11:10	0	6973128	
114.1-129	Rm 209	B	11:12	0	6973129	
114.1-130	Rm 212	S	11:14	0	6973130	
114.1-131	Rm 212	B	11:16	0	6973131	
114.1-132	Rm 211	S	11:18	0	6973132	
114.1-133	Rm 211	B	11:20	0	6973133	
114.1-134	Rm 213	S	11:22	0	6973134	
114.1-135	Rm 213	B	11:24	0	6973135	
114.1-136	Rm 101	S	11:26	0	6973136	
114.1-137	Rm 101	S	11:28	0	6973137	
114.1-138	Rm 102	S	11:30	0	6973138	
114.1-140	Rm 104	B	11:34	0	6973140	
114.1-139	Rm 102	S	11:32	0	6973139	
114.1-141	Rm 104	S	11:36	0	6973141	
114.1-142	Rm 104	S	11:38	0	6973142	
114.1-143	Rm 105	S	11:40	0	6973143	
114.1-144	Rm 105	B	11:42	Eswa8_1l	6973144	

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/18/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) iATL

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLEDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2020L-114

Client: Westfield CSD Contact: Josh Brumagin

Building: Westfield Academy and Central School Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-145	Rm 105	S	11:44	0	699.1-145	
114.1-146	Rm 106	S	11:46	0	699.1-146	
114.1-147	Rm 106	B	11:48	0	699.1-147	
114.1-148	Rm 106	S	11:50	0	699.1-148	
114.1-149	Rm 107	S	11:52	0	699.1-149	
114.1-150	Rm 107	B	11:54	0	699.1-150	
114.1-151	Rm 107	S	11:56	0	699.1-151	
114.1-152	Rm 108	B	11:58	0	699.1-152	
114.1-153	Rm 108	S	12:00	0	699.1-153	
114.1-154	Rm 108	S	12:02	0	699.1-154	
114.1-155	Rm 109	S	12:04	0	699.1-155	
114.1-156	Rm 109	B	12:06	0	699.1-156	
114.1-157	Rm 109	S	12:08	0	699.1-157	
114.1-158	Rm 110	S	12:10	0	699.1-158	
114.1-159	Rm 110	B	12:12	0	699.1-159	
114.1-160	Rm 110	S	12:14	0	699.1-160	
114.1-161	Rm 111	S	12:16	0	699.1-161	
114.1-162	Rm 111	B	12:18	0	699.1-162	

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/18/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) iATL

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLEDALE PKWY. BUFFALO, NEW YORK 14219
☎ (716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-163	Rm 111	S	12:20	0	59-1-43	
114.1-164	Rm 112	S	12:22	0	59-1-50	
114.1-165	Rm 112	B	12:24	0	59-1-51	
114.1-166	Rm 112	S	12:26	0	59-1-52	
114.1-167	Rm 113	S	12:28	0	59-1-53	
114.1-168	Rm 113	B	12:30	0	59-1-54	
114.1-169	Rm 113	S	12:32	0	59-1-55	
114.1-170	Rm 114	S	12:34	0	59-1-56	
114.1-171	Rm 114	B	12:36	0	59-1-57	
114.1-172	Rm 114	S	12:38	0	59-1-58	
114.1-173	Rm 115	S	12:40	0	59-1-59	
114.1-174	Rm 115	B	12:42	0	59-1-60	
114.1-175	Rm 115	S	12:44	0	59-1-61	
114.1-176	Rm 116	S	12:46	0	59-1-62	
114.1-177	Rm 116	B	12:48	0	59-1-63	
114.1-178	Rm 116	S	12:50	0	59-1-64	
114.1-179	Rm 118b	S	12:52	0	59-1-65	
114.1-180	Rm 118	S	12:54	0	59-1-66	

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/18/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) iATL

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.1-181	Rm 118	B	12:56	0	6973167	
114.1-182	Rm 118	S	12:58	0	6973168	
114.1-183	Nurse office	S	13:00	0	6973169	
114.1-184	Nurse office	S	13:02	0	6973170	
114.1-185	Nurse office	S	13:04	0	6973171	
114.1-186	Drinking fountain	DF	13:06	Eswa8_1l	6973172	
114.1-187	Elementary office	S	13:08	0	6973173	
114.1-188	Elementary office	S	13:10	0	6973174	
114.1-189	Elementary office	S	13:12	0	6973175	
114.1-190	mens room	S	13:14	0	6973176	
114.1-191	Women's room	S	13:16	0	6973177	
114.1-192	Rm122	S	13:18	0	6973178	
* 114.1-193	Girls locker room	S	13:20	0	6973179	
114.1-194	Rm122	S	13:22	0		
114.1-195	Girls locker room	S	13:24	0	6973180	
114.1-196	Girls locker room	S	13:26	0	6973181	
114.1-197	Girls locker room	S	13:28	0	6973182	

Notes:

Please e-mail lab results to labs@stohlenv.com

iATL 6978179

*Sample not rec'd

Sampled By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/18/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Submitted to: (Lab Name) iATL

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Josh Brumagin

Building: Westfield Academy and Central School

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9	X
---	---

Turnaround

5 Days

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Print Name: Stohl Env: Date:

Relinquished By: _____ Print Name _____ Stohl Env: _____ Date: _____

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): C2/28/20 Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: QA/QC InterLAB Use: Date: Time:



3860 California Road, Orchard Park, New York 14127

PHONE (716) 312-0070 FAX (716) 312-8092

WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) _____ iATL

STOHL Job # 2020L-114

Client: Westfield CSD

Contact: Lou Golando

Building: Wayside Building

Location: Westfield, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9	X
---	---

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
114.2-2	Garage Bubbler	B	12:39	0	6977998	
114.2-3	Garage sink	S	12:24	0	6977999	
114.2-4	Sink	S	12:31	0	6978000	
114.2-5	Bubbler	B	12:31	0	6978001	
114.2-6	Boy room	S	12:32	0	6978002	
114.2-7	Girls Room	S	12:36	0	6978003	
AUG.	2/26/20	21:30	src			

Notes:

Please e-mail lab results to labs@stohlen.com

☒ If checked, also e-mail results to: ehenderson@stohlenv.com

Sampled By: E. + A. O. Print Name

Stohl Env: Eric Henderson Jr. Date: 2/18/2020

Relinquished By: E. H. O. Print Name

Stohl Env: Eric Henderson Jr. Date: 2/20/2020

Received (Name / Lab):

Date: _____ Time: _____

Sample Login (Name / Lab):

Date: _____ Time: 3:45 PM

Analysis (Name / Lab): 62/28/20

Date: _____ Time: _____

QA/QC Review (Name / Lab): _____

Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____

Date: _____

Page 1 of 1

Time: _____
Time: _____
Time: _____
Time: _____

INTL-Ly

