

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092902

Sutherlin School 130 531 E. Central Ave Sutherlin, OR 97479	Project: General Client Contact: Rick Holder	Date Reported: 10/05/16 Date Sampled: 09/22/16 10:10 Date Received: 09/29/16 09:00 Sampled By:
---	---	---

Sample Location: W-16

URC Sample #: 6092902-01

Matrix: Drinking Water

Metals


Analyte	Method Code	Result	Units	MRL	MCL	Prepared	Analyzed	Analyst	Qualifier
Copper	EPA 200.8	0.124	mg/L	0.010	1.3	10/03/16	10/03/16	DJP	
Lead	EPA 200.8 1030	ND	mg/L	0.002	0.02	10/03/16	10/03/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager

10/5/16



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092902

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager

1/7/96