

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081603

Sutherlin School 130 531 E. Central Ave Sutherlin, OR 97479	Project: General	Date Reported: 08/24/16 Date Received: 08/10/16 16:00 Sampled By: Sutherlin School 130
	Client Contact: Rick Holder	

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6081603-01	Sample Location: JH/Kitchen 1									
	Lead	1030	0.003	mg/L	0.002	0.02	08/08/16 15:50	08/17/16	DJP	
	Copper		0.235	mg/L	0.010	1.3	08/08/16 15:50	08/17/16	DJP	
6081603-02	Sample Location: JH/Kitchen 2									
	Lead	1030	0.003	mg/L	0.002	0.02	08/08/16 15:50	08/17/16	DJP	
	Copper		0.277	mg/L	0.010	1.3	08/08/16 15:50	08/17/16	DJP	
6081603-03	Sample Location: JH/Kitchen Bath									
	Lead	1030	0.003	mg/L	0.002	0.02	08/08/16 15:56	08/17/16	DJP	
	Copper		0.356	mg/L	0.010	1.3	08/08/16 15:56	08/17/16	DJP	
6081603-04	Sample Location: JH/R 11-1									
	Lead	1030	ND	mg/L	0.002	0.02	08/08/16 15:50	08/17/16	DJP	
	Copper		0.237	mg/L	0.010	1.3	08/08/16 15:50	08/17/16	DJP	
6081603-05	Sample Location: JH/Activity Boy Bath									
	Lead	1030	0.002	mg/L	0.002	0.02	08/08/16 15:55	08/17/16	DJP	
	Copper		0.767	mg/L	0.010	1.3	08/08/16 15:55	08/17/16	DJP	
6081603-06	Sample Location: JH/Activity Girls Bath									
	Lead	1030	ND	mg/L	0.002	0.02	08/08/16 15:50	08/17/16	DJP	
	Copper		0.824	mg/L	0.010	1.3	08/08/16 15:50	08/17/16	DJP	
6081603-07	Sample Location: JH/R 11-2									
	Lead	1030	0.002	mg/L	0.002	0.02	08/08/16 15:50	08/17/16	DJP	
	Copper		0.133	mg/L	0.010	1.3	08/08/16 15:50	08/17/16	DJP	
6081603-08	Sample Location: JH/R 12-1									
	Lead	1030	ND	mg/L	0.002	0.02	08/08/16 15:30	08/17/16	DJP	
	Copper		0.114	mg/L	0.010	1.3	08/08/16 15:30	08/17/16	DJP	
6081603-09	Sample Location: JH/Gym Boys Bath									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081603

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.002	mg/L	0.002	0.02	08/09/16 06:15	08/17/16	DJP	
Copper			0.066	mg/L	0.010	1.3	08/09/16 06:15	08/17/16	DJP	
6081603-10	Sample Location: JH/Gym Girls Bath									
Lead		1030	0.002	mg/L	0.002	0.02	08/09/16 06:15	08/17/16	DJP	
Copper			0.068	mg/L	0.010	1.3	08/09/16 06:15	08/17/16	DJP	
6081603-11	Sample Location: HS/Office Boys									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 07:44	08/17/16	DJP	
Copper			0.035	mg/L	0.010	1.3	08/09/16 07:44	08/17/16	DJP	
6081603-12	Sample Location: HS/Activity Girls									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 07:48	08/17/16	DJP	
Copper			0.079	mg/L	0.010	1.3	08/09/16 07:48	08/17/16	DJP	
6081603-13	Sample Location: HS/Girls Locker									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 06:43	08/17/16	DJP	
Copper			0.430	mg/L	0.010	1.3	08/09/16 06:43	08/17/16	DJP	
6081603-14	Sample Location: HS/R 21 T1									
Lead		1030	0.003	mg/L	0.002	0.02	08/09/16 08:50	08/17/16	DJP	
Copper			0.602	mg/L	0.010	1.3	08/09/16 08:50	08/17/16	DJP	
6081603-15	Sample Location: HS/R 22 3									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 08:21	08/17/16	DJP	
Copper			0.637	mg/L	0.010	1.3	08/09/16 08:21	08/17/16	DJP	
6081603-16	Sample Location: HS/R 24									
Lead		1030	0.003	mg/L	0.002	0.02	08/09/16 08:45	08/17/16	DJP	
Copper			0.989	mg/L	0.010	1.3	08/09/16 08:45	08/18/16	DJP	
6081603-17	Sample Location: HS/Boys Locker									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 06:40	08/17/16	DJP	
Copper			0.631	mg/L	0.010	1.3	08/09/16 06:40	08/17/16	DJP	
6081603-18	Sample Location: HS/Wood Shop									
Lead		1030	0.020	mg/L	0.002	0.02	08/09/16 09:05	08/18/16	DJP	CON-1
Copper			ND	mg/L	0.010	1.3	08/09/16 09:05	08/18/16	DJP	
6081603-19	Sample Location: HS/Band									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081603

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.003	mg/L	0.002	0.02	08/09/16 06:55	08/17/16	DJP	
Copper			0.215	mg/L	0.010	1.3	08/09/16 06:55	08/17/16	DJP	
6081603-20	Sample Location: HS/R 20 T									
Lead		1030	0.006	mg/L	0.002	0.02	08/09/16 08:00	08/17/16	DJP	
Copper			0.556	mg/L	0.010	1.3	08/09/16 08:00	08/17/16	DJP	
6081603-21	Sample Location: HS/R 23 T Sink									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 08:44	08/17/16	DJP	
Copper			0.588	mg/L	0.010	1.3	08/09/16 08:44	08/17/16	DJP	
6081603-22	Sample Location: HS/Choir Girls									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 07:05	08/17/16	DJP	
Copper			0.101	mg/L	0.010	1.3	08/09/16 07:05	08/17/16	DJP	
6081603-23	Sample Location: HS/R 15 Girls 2									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 07:20	08/17/16	DJP	
Copper			0.044	mg/L	0.010	1.3	08/09/16 07:20	08/17/16	DJP	
6081603-24	Sample Location: HS/Metal Shop									
Lead		1030	0.002	mg/L	0.002	0.02	08/09/16 09:10	08/17/16	DJP	
Copper			0.024	mg/L	0.010	1.3	08/09/16 09:10	08/17/16	DJP	
6081603-25	Sample Location: HS/Staff Men									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 08:46	08/17/16	DJP	
Copper			0.573	mg/L	0.010	1.3	08/09/16 08:46	08/17/16	DJP	
6081603-26	Sample Location: HS/R 23									
Lead		1030	0.005	mg/L	0.002	0.02	08/09/16 08:40	08/17/16	DJP	
Copper			0.672	mg/L	0.010	1.3	08/09/16 08:40	08/17/16	DJP	
6081603-27	Sample Location: HS/R 20 L									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 08:55	08/17/16	DJP	
Copper			0.340	mg/L	0.010	1.3	08/09/16 08:55	08/17/16	DJP	
6081603-28	Sample Location: HS/Girls Lobby									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 08:50	08/17/16	DJP	
Copper			0.047	mg/L	0.010	1.3	08/09/16 08:50	08/17/16	DJP	
6081603-29	Sample Location: HS/Choir Boys									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081603

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 07:25	08/17/16	DJP	
Copper			0.058	mg/L	0.010	1.3	08/09/16 07:25	08/17/16	DJP	
6081603-30	Sample Location: HS/Library									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 07:33	08/17/16	DJP	
Copper			0.931	mg/L	0.010	1.3	08/09/16 07:33	08/18/16	DJP	
6081603-31	Sample Location: HS/R 21 R									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 08:55	08/17/16	DJP	
Copper			0.268	mg/L	0.010	1.3	08/09/16 08:55	08/17/16	DJP	
6081603-32	Sample Location: HS/Staff Room									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 07:40	08/17/16	DJP	
Copper			0.151	mg/L	0.010	1.3	08/09/16 07:40	08/17/16	DJP	
6081603-33	Sample Location: HS/R 15 Boys 3									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 08:21	08/17/16	DJP	
Copper			0.042	mg/L	0.010	1.3	08/09/16 08:21	08/17/16	DJP	
6081603-34	Sample Location: HS/R 15 1									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 08:20	08/17/16	DJP	
Copper			0.020	mg/L	0.010	1.3	08/09/16 08:20	08/17/16	DJP	
6081603-35	Sample Location: HS/R 22 4									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 08:21	08/17/16	DJP	
Copper			0.686	mg/L	0.010	1.3	08/09/16 08:21	08/17/16	DJP	
6081603-36	Sample Location: HS/Office Storage									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 07:40	08/17/16	DJP	
Copper			0.649	mg/L	0.010	1.3	08/09/16 07:40	08/17/16	DJP	
6081603-37	Sample Location: HS/Ceramic									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 09:05	08/17/16	DJP	
Copper			ND	mg/L	0.010	1.3	08/09/16 09:05	08/17/16	DJP	
6081603-38	Sample Location: HS/Lobby Boys									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 06:48	08/17/16	DJP	
Copper			0.030	mg/L	0.010	1.3	08/09/16 06:48	08/17/16	DJP	
6081603-39	Sample Location: HS/Staff Women									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081603

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.002	mg/L	0.002	0.02	08/09/16 08:45	08/17/16	DJP	
Copper			0.656	mg/L	0.010	1.3	08/09/16 08:45	08/17/16	DJP	
6081603-40	Sample Location: HS/Activity Boys									
Lead		1030	ND	mg/L	0.002	0.02	08/09/16 07:45	08/17/16	DJP	
Copper			0.107	mg/L	0.010	1.3	08/09/16 07:45	08/17/16	DJP	
6081603-41	Sample Location: HS/Office Girls									
Lead		1030	0.003	mg/L	0.002	0.02	08/09/16 07:41	08/17/16	DJP	
Copper			0.053	mg/L	0.010	1.3	08/09/16 07:41	08/17/16	DJP	
6081603-42	Sample Location: JH/R 12-2									
Lead		1030	ND	mg/L	0.002	0.02	08/08/16 15:30	08/17/16	DJP	
Copper			0.108	mg/L	0.010	1.3	08/08/16 15:30	08/17/16	DJP	
6081603-43	Sample Location: JH/R 12-3									
Lead		1030	ND	mg/L	0.002	0.02	08/08/16 15:30	08/17/16	DJP	
Copper			0.087	mg/L	0.010	1.3	08/08/16 15:30	08/17/16	DJP	
6081603-44	Sample Location: JH/R 12-4									
Lead		1030	ND	mg/L	0.002	0.02	08/08/16 15:30	08/17/16	DJP	
Copper			0.073	mg/L	0.010	1.3	08/08/16 15:30	08/17/16	DJP	
6081603-45	Sample Location: JH/R 12-5									
Lead		1030	ND	mg/L	0.002	0.02	08/08/16 15:30	08/17/16	DJP	
Copper			0.079	mg/L	0.010	1.3	08/08/16 15:30	08/17/16	DJP	
6081603-46	Sample Location: JH/R 12-6									
Lead		1030	ND	mg/L	0.002	0.02	08/08/16 15:30	08/17/16	DJP	
Copper			0.116	mg/L	0.010	1.3	08/08/16 15:30	08/17/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081603

Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager