

**EMSL Analytical, Inc.**

307 West 38th Street, New York, NY 10018
 Phone/Fax: (212) 290-0051 / (212) 290-0058
<http://www.EMSL.com> manhattanlab@emsl.com

EMSL Order: 031806623
 CustomerID: AHER50
 CustomerPO: 18-3032
 ProjectID:

Attn: **Eric Clarkson**
Ahera Consultants, Inc.
PO Box 385
Oceanville, NJ 08231-0385

Phone: (609) 652-1833
 Fax: (609) 652-1140
 Received: 03/24/18 2:21 AM
 Analysis Date: 3/24/2018
 Collected: 3/23/2018

Project: 18-3032/ INDIANA AVENUE SCHOOL NO. 18/ 256 INDIANA AVENUE/ ISELIN NJ/ 08830

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥ 0.5μ < 5	≥ 5μ		(S/mm ²)	(S/cc)
IAS-01 031806623-0001	SMALL KITCHEN AND 1965 HALLWAY TENT	1350.00	0.0640	0	None Detected			0.0045	<16.00	<0.0045
IAS-02 031806623-0002	SMALL KITCHEN AND 1965 HALLWAY TENT	1350.00	0.0640	0	None Detected			0.0045	<16.00	<0.0045
IAS-03 031806623-0003	1965 HALLWAY TENT	1350.00	0.0640	0	None Detected			0.0045	<16.00	<0.0045
IAS-04 031806623-0004	1965 HALLWAY TENT	1350.00	0.0640	0	None Detected			0.0045	<16.00	<0.0045
IAS-05 031806623-0005	1965 HALLWAY TENT	1350.00	0.0640	0	None Detected			0.0045	<16.00	<0.0045

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm3 and structures/mm2 are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. New York, NY NVLAP Lab Code 101048-9, AIHA-LAP, LLC--IHLAP Accredited #102581, NYS ELAP 11506, NJ NY022, CT PH-0170, MA AA000170

Report Amended: 03/26/2018 08:49:04 Replaces the Inital Report 03/24/2018 06:35:16. Reason Code: Client-Change to Location



EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018
Phone/Fax: (212) 290-0051 / (212) 290-0058
<http://www.EMSL.com> manhattanlab@emsl.com

EMSL Order: 031806623
CustomerID: AHER50
CustomerPO: 18-3032
ProjectID:

Attn: **Eric Clarkson**
Ahera Consultants, Inc.
PO Box 385
Oceanville, NJ 08231-0385

Phone: (609) 652-1833
Fax: (609) 652-1140
Received: 03/24/18 2:21 AM
Analysis Date: 3/24/2018
Collected: 3/23/2018

Project: 18-3032/ INDIANA AVENUE SCHOOL NO. 18/ 256 INDIANA AVENUE/ ISELIN NJ/ 08830

The samples in this report were submitted to EMSL for analysis by Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E. The reference number for these samples is the EMSL Order ID above. Please use this reference number when calling about these samples.

Report Comments:

Sample Receipt Date: 3/24/2018 Sample Receipt Time: 2:21 AM
Analysis Completed Date: 3/24/2018 Analysis Completed Time: 6:15 AM

Analyst(s):

Muhsin Parson TEM AHERA (5)

Samples reviewed and approved by:

James Hall, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm3 and structures/mm2 are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.
Samples analyzed by EMSL Analytical, Inc. New York, NY NVLAP Lab Code 101048-9, AIHA-LAP, LLC--IHLAP Accredited #102581, NYS ELAP 11506, NJ NY022, CT PH-0170, MA AA000170

Report Amended: 03/26/2018 08:49:04 Replaces the Inital Report 03/24/2018 06:35:16. Reason Code: Client-Change to Location