

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-5974

<http://www.EMSL.com>cinnaslab@EMSL.com

EMSL Order: 041808349

CustomerID: AHER50

CustomerPO:

ProjectID:

Attn: **Eric Clarkson**
Ahera Consultants, Inc.
PO Box 385
Oceanville, NJ 08231-0385

Phone: (609) 652-1833
 Fax: (609) 652-1140
 Received: 03/21/18 10:10 AM
 Analysis Date: 3/22/2018
 Collected: 3/20/2018

Project: 18-3032 / Indiana School No. 18

Test Report: Qualitative Asbestos Analysis by Transmission Electron Microscopy (TEM) and Filtration Technique

Sample	Description	TEM Result	Notes
IAS-02 041808349-0001	Classroom 5 - Book Wipe Sample	Chrysotile	
IAS-02A 041808349-0002	Classroom 5 - Book Wipe Sample	None Detected	
IAS-02B 041808349-0003	Classroom 5 - Book Wipe Sample	Chrysotile	Less than 4 asbestos fibers found

Analyst(s)

Sandy Burany, Ph.D (3)

Benjamin Ellis, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This is a qualitative screen only. There is a chance for false negatives with this method. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ

Initial report from 03/22/2018 15:24:37

**EMSL Analytical, Inc.**

307 West 38th Street, New York, NY 10018

Phone/Fax: (212) 290-0051 / (212) 290-0058

<http://www.EMSL.com>manhattanlab@emsl.com

EMSL Order:	031806792
CustomerID:	AHER50
CustomerPO:	18-3032
ProjectID:	Woodbridge Schoo

Attn: **John Smoyer**
Ahera Consultants, Inc.
PO Box 385
Oceanville, NJ 08231-0385

Phone: (609) 652-1833
 Fax: (609) 652-1140
 Received: 03/26/18 9:55 PM
 Analysis Date: 3/27/2018
 Collected: 3/26/2018

Project: 18-3032/ WOODBRIDGE SCHOOL #18/ 256 INDIANA AVENUE/ ISELIN NJ/ 08830

Test Report: Qualitative Asbestos Analysis by Transmission Electron Microscopy (TEM) and Filtration Technique

Sample	Description	TEM Result	Notes
18-3032-01 031806792-0001	M OFFICE COUNTER	None Detected	
18-3032-02 031806792-0002	CLRM #1 1/2 ROUND	None Detected	
18-3032-03 031806792-0003	CLRM #2 1/2 ROUND	None Detected	
18-3032-04 031806792-0004	CLRM #3 1/2 ROUND	None Detected	
18-3032-05 031806792-0005	CLRM #4 1/2 ROUND	None Detected	
18-3032-06 031806792-0006	CLRM #5 1/2 ROUND	None Detected	
18-3032-07 031806792-0007	CLRM #6 1/2 ROUND	None Detected	
18-3032-08 031806792-0008	CLRM #7 SUPPLY STATION ADJ WHITE BOARD	None Detected	
18-3032-09 031806792-0009	CLRM #8 1/2 ROUND	None Detected	
18-3032-10 031806792-0010	CLRM #9 1/2 ROUND	None Detected	

Analyst(s) _____

Bob Georgans (17)

Evie Sioukri (19)

James Hall, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This is a qualitative screen only. There is a chance for false negatives with this method. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. New York, NY

Initial report from 03/27/2018 20:59:11

**EMSL Analytical, Inc.**

307 West 38th Street, New York, NY 10018

Phone/Fax: (212) 290-0051 / (212) 290-0058

<http://www.EMSL.com>manhattanlab@emsl.com

EMSL Order:	031806792
CustomerID:	AHER50
CustomerPO:	18-3032
ProjectID:	Woodbridge Schoo

Attn: **John Smoyer**
Ahera Consultants, Inc.
PO Box 385
Oceanville, NJ 08231-0385


Phone: (609) 652-1833
 Fax: (609) 652-1140
 Received: 03/26/18 9:55 PM
 Analysis Date: 3/27/2018
 Collected: 3/26/2018

Project: 18-3032/ WOODBRIDGE SCHOOL #18/ 256 INDIANA AVENUE/ ISELIN NJ/ 08830

Test Report:Qualitative Asbestos Analysis by Transmission Electron Microscopy (TEM) and Filtration Technique

Sample	Description	TEM Result	Notes
18-3032-11 031806792-0011	CLRM #10 1/2 ROUND	None Detected	
18-3032-12 031806792-0012	CLRM #11 1/2 ROUND	None Detected	
18-3032-13 031806792-0013	CLRM #12 1/2 ROUND	None Detected	
18-3032-14 031806792-0014	CLRM #13 1/2 ROUND	None Detected	
18-3032-15 031806792-0015	CLRM #14 COMMON DESK RIGHT CENTER	Anthophyllite Chrysotile	
18-3032-16 031806792-0016	CLRM #15 1/2 ROUND	None Detected	
18-3032-17 031806792-0017	CLRM #17 1/2 ROUND	None Detected	
18-3032-18 031806792-0018	CLRM #18 1/2 ROUND	None Detected	
18-3032-19 031806792-0019	CLRM #19 1/2 ROUND	None Detected	
18-3032-20 031806792-0020	CLRM #20 1/2 ROUND	None Detected	

Analyst(s)
 Bob Georgans (17)
 Evie Sioukri (19)


 James Hall, Laboratory Manager
 or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This is a qualitative screen only. There is a chance for false negatives with this method. Samples received in good condition unless otherwise noted.
 Samples analyzed by EMSL Analytical, Inc. New York, NY

Initial report from 03/27/2018 20:59:11

**EMSL Analytical, Inc.**

307 West 38th Street, New York, NY 10018

Phone/Fax: (212) 290-0051 / (212) 290-0058

<http://www.EMSL.com>manhattanlab@emsl.com

EMSL Order:	031806792
CustomerID:	AHER50
CustomerPO:	18-3032
ProjectID:	Woodbridge Schoo

Attn: **John Smoyer**
Ahera Consultants, Inc.
PO Box 385
Oceanville, NJ 08231-0385

Phone: (609) 652-1833
 Fax: (609) 652-1140
 Received: 03/26/18 9:55 PM
 Analysis Date: 3/27/2018
 Collected: 3/26/2018


Project: 18-3032/ WOODBRIDGE SCHOOL #18/ 256 INDIANA AVENUE/ ISELIN NJ/ 08830

Test Report: Qualitative Asbestos Analysis by Transmission Electron Microscopy (TEM) and Filtration Technique

Sample	Description	TEM Result	Notes
18-3032-21 031806792-0021	CLRM #21 RIGHT BOOKCASE OF UNIT VENT	None Detected	
18-3032-22 031806792-0022	CLRM #22 RIGHT BOOKCASE OF UNIT VENT	Chrysotile	
18-3032-23 031806792-0023	CLRM #23 1/2 ROUND	None Detected	
18-3032-24 031806792-0024	CLRM #24 1/2 ROUND	None Detected	
18-3032-25 031806792-0025	CLRM #25 1/2 ROUND	None Detected	
18-3032-26 031806792-0026	CLRM #26 1/2 ROUND	Anthophyllite	
18-3032-27 031806792-0027	CLRM #27 1/2 ROUND	None Detected	
18-3032-28 031806792-0028	CLRM #28 1/2 ROUND	None Detected	
18-3032-29 031806792-0029	CLRM #29 1/2 ROUND	None Detected	
18-3032-30 031806792-0030	CLRM #30 1/2 ROUND	None Detected	

Analyst(s)

 Bob Georgans (17)
 Evie Sioukri (19)



 James Hall, Laboratory Manager
 or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This is a qualitative screen only. There is a chance for false negatives with this method. Samples received in good condition unless otherwise noted.
 Samples analyzed by EMSL Analytical, Inc. New York, NY

Initial report from 03/27/2018 20:59:11

**EMSL Analytical, Inc.**

307 West 38th Street, New York, NY 10018

Phone/Fax: (212) 290-0051 / (212) 290-0058

<http://www.EMSL.com>manhattanlab@emsl.com

EMSL Order:	031806792
CustomerID:	AHER50
CustomerPO:	18-3032
ProjectID:	Woodbridge Schoo

Attn: **John Smoyer**
Ahera Consultants, Inc.
PO Box 385
Oceanville, NJ 08231-0385

Phone: (609) 652-1833
 Fax: (609) 652-1140
 Received: 03/26/18 9:55 PM
 Analysis Date: 3/27/2018
 Collected: 3/26/2018

Project: 18-3032/ WOODBRIDGE SCHOOL #18/ 256 INDIANA AVENUE/ ISELIN NJ/ 08830

Test Report:Qualitative Asbestos Analysis by Transmission Electron Microscopy (TEM) and Filtration Technique

Sample	Description	TEM Result	Notes
18-3032-31 031806792-0031	CLRM #31 RIGHT BOOKCASE OF UNIT VENT	None Detected	
18-3032-32 031806792-0032	KITCHEN/ COPY RM TOP OF SMALL FRIDGE	None Detected	
18-3032-33 031806792-0033	NURSE SUITE REFRIGERATOR (SMALL)	None Detected	
18-3032-34 031806792-0034	FACULTY ROOM - RIGHT BOOKCASE OF UNIT VENT	None Detected	
18-3032-35 031806792-0035	MEDIA CENTER - PROPORTION WALL COMMON TABLE	Chrysotile	
18-3032-36 031806792-0036	ESL WITHIN MEDIA CENTRAL TABLE	None Detected	

Analyst(s)

Bob Georgans (17)

Evie Sioukri (19)

James Hall, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This is a qualitative screen only. There is a chance for false negatives with this method. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. New York, NY

Initial report from 03/27/2018 20:59:11