



# EMSL Analytical, Inc.

307 West 38th Street New York, NY 10018

Tel/Fax: (212) 290-0051 /

<http://www.EMSL.com> / [manhattanlab@emsl.com](mailto:manhattanlab@emsl.com)

EMSL Order: 031809767

Customer ID: AHER50

Customer PO:

Project ID:

**Attention:** Eric Clarkson  
Ahera Consultants, Inc.  
PO Box 385  
Oceanville, NJ 08231-0385

**Phone:** (609) 652-1833

**Fax:** (609) 652-1140

**Received Date:** 04/25/2018 19:54 PM

**Analysis Date:** 04/26/2018

**Collected Date:** 04/25/2018

**Project:** 18-3032/ INDIANA AVENUE SCHOOL/ 256 INDIANA AVENUE/ ISELIN, NJ 08830

## Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm <sup>2</sup> )	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm <sup>2</sup> )	(S/cc)
IAS-01 031809767-0001	CLASSROOM 9	1350.00	0.0635	0	None Detected	0	0	0.0045	<16.00	<0.0045
IAS-02 031809767-0002	CLASSROOM 9	1350.00	0.0635	0	None Detected	0	0	0.0045	<16.00	<0.0045
IAS-03 031809767-0003	CLASSROOM 9	1350.00	0.0635	0	None Detected	0	0	0.0045	<16.00	<0.0045

Analyst(s)

Muhsin Parson (3)

James Hall, Laboratory Manager  
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm<sup>3</sup> and structures/mm<sup>2</sup> are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. New York, NY NVLAP Lab Code 101048-9, AIHA-LAP, LLC--IHLAP Accredited #102581, NYS ELAP 11506, NJ NY022, CT PH-0170, MA AA000170

Initial report from: 04/26/2018 01:34 AM