

IAQ Investigation Log

Test ID:	Indiana Avenue School No. 18	MAIN OFFICE
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	1	
Test Abbreviation:	Test 001	
Start Date:	10/30/18	
Start Time:	15:07:35	
Duration (dd:hh:mm:ss):	0:00:02:00	
Log Interval (mm:ss):	0:01	
Number of points:	5	
Notes:	Test 001	



Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	533	73.2	26	0
	Minimum:	525	73.2	25.2	0
	Time of Minimum:	15:09:35	15:08:06	15:09:35	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	546	73.2	27.2	0
	Time of Maximum:	15:08:43	15:07:36	15:08:43	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	5/10/18			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	15:07:36	529	73.2	25.4	0
10/30/18	15:08:06	535	73.2	26	0
10/30/18	15:08:19	531	73.2	26.4	0
10/30/18	15:08:43	546	73.2	27.2	0
10/30/18	15:09:35	525	73.2	25.2	0

IAQ Investigation Log

Test ID:	Indiana Avenue School No. 18	PRINCIPAL'S OFFICE (OLD)
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	2	
Test Abbreviation:	Test 002	
Start Date:	43403	
Start Time:	3:38:45 PM	
Duration (dd:hh:mm:ss):	0:00:02:31	
Log Interval (mm:ss):	0.000694444	
Number of points:	5	
Notes:	Test 002	



Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	500	73.4	26.1	0
	Minimum:	479	73	25.3	0
	Time of Minimum:	15:39:47	15:41:16	15:38:46	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	538	73.8	27	0
	Time of Maximum:	15:41:16	15:38:46	15:41:16	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	5/10/18			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	15:38:46	521	73.8	25.3	0
10/30/18	15:39:47	479	73.5	25.6	0
10/30/18	15:40:03	482	73.4	25.8	0
10/30/18	15:41:03	480	73.3	26.6	0
10/30/18	15:41:16	538	73	27	0

IAQ Investigation Log

Test ID:	Indiana Avenue School No. 18	FACULTY ROOM
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	3	
Test Abbreviation:	Test 003	
Start Date:	10/30/18	
Start Time:	15:45:23	
Duration (dd:hh:mm:ss):	0:00:00:41	
Log Interval (mm:ss):	0:01	
Number of points:	5	
Notes:	Test 003	



Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	455	75.1	22.1	0
	Minimum:	435	74.2	21	0
	Time of Minimum:	15:45:45	15:45:24	15:46:04	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	474	75.9	24.4	0
	Time of Maximum:	15:45:24	15:46:04	15:45:24	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	5/10/18			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	15:45:24	474	74.2	24.4	0
10/30/18	15:45:34	469	74.6	22.3	0
10/30/18	15:45:45	435	75.4	21.7	0
10/30/18	15:45:55	440	75.6	21.3	0
10/30/18	15:46:04	459	75.9	21	0

IAQ Investigation Log

Test ID:	Indiana Avenue School No. 18	MEDIA CENTER
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	4	
Test Abbreviation:	Test 004	
Start Date:	10/30/18	
Start Time:	15:48:13	
Duration (dd:hh:mm:ss):	0:00:01:08	
Log Interval (mm:ss):	0:01	
Number of points:	5	
Notes:	Test 004	



Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	570	72.7	32.7	0
	Minimum:	562	72.3	32	0
	Time of Minimum:	15:48:34	15:49:07	15:48:14	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	585	73.4	33.2	0
	Time of Maximum:	15:48:48	15:48:14	15:48:48	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	5/10/18			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	15:48:14	565	73.4	32	0
10/30/18	15:48:34	562	73	32.8	0
10/30/18	15:48:48	585	72.5	33.2	0
10/30/18	15:49:07	571	72.3	32.6	0
10/30/18	15:49:21	566	72.3	32.7	0

IAQ Investigation Log

Test ID:	Indiana Avenue School No. 18	MEDIA CENTER HVAC CLOSET
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	5	
Test Abbreviation:	Test 005	
Start Date:	10/30/18	
Start Time:	15:54:08	
Duration (dd:hh:mm:ss):	0:00:00:39	
Log Interval (mm:ss):	0:01	
Number of points:	5	
Notes:	Test 005	



Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	589	73.3	32.8	0
	Minimum:	565	73	32.7	0
	Time of Minimum:	15:54:09	15:54:09	15:54:09	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	611	73.4	32.9	0
	Time of Maximum:	15:54:39	15:54:39	15:54:30	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	5/10/18			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	15:54:09	565	73	32.7	0
10/30/18	15:54:21	565	73.2	32.7	0
10/30/18	15:54:30	608	73.3	32.9	0
10/30/18	15:54:39	611	73.4	32.9	0
10/30/18	15:54:47	598	73.3	32.7	0

IAQ Investigation Log

Test ID:	Indiana Avenue School No. 18	COURTYARD STORAGE
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	6	
Test Abbreviation:	Test 006	
Start Date:	10/30/18	
Start Time:	16:15:08	
Duration (dd:hh:mm:ss):	0:00:00:56	
Log Interval (mm:ss):	0:01	
Number of points:	5	
Notes:	Test 006	



Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	550	72.5	48.8	0
	Minimum:	440	72.4	48.3	0
	Time of Minimum:	16:15:09	16:15:19	16:15:19	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	833	72.6	49.3	0
	Time of Maximum:	16:16:04	16:16:04	16:16:04	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	5/10/18			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	16:15:09	440	72.4	49.2	0
10/30/18	16:15:19	465	72.4	48.3	0
10/30/18	16:15:34	454	72.4	48.3	0
10/30/18	16:15:47	558	72.5	48.8	0
10/30/18	16:16:04	833	72.6	49.3	0

IAQ Investigation Log

Test ID:	Indiana Avenue School No. 18	NURSES OFFICE
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	7	
Test Abbreviation:	Test 007	
Start Date:	10/30/18	
Start Time:	16:24:09	
Duration (dd:hh:mm:ss):	0:00:00:42	
Log Interval (mm:ss):	0:01	
Number of points:	5	
Notes:	Test 007	



Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	460	76.8	22	0
	Minimum:	450	76.3	21.6	0
	Time of Minimum:	16:24:18	16:24:10	16:24:37	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	475	77.3	22.8	0
	Time of Maximum:	16:24:37	16:24:51	16:24:10	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	5/10/18			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	16:24:10	454	76.3	22.8	0
10/30/18	16:24:18	450	76.4	22	0
10/30/18	16:24:26	460	76.8	21.9	0
10/30/18	16:24:37	475	77.2	21.6	0
10/30/18	16:24:51	459	77.3	21.6	0

IAQ Investigation Log

Test ID:	Indiana Avenue School No. 18	PTO CLOSET
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	8	
Test Abbreviation:	Test 008	
Start Date:	10/30/18	
Start Time:	16:37:54	
Duration (dd:hh:mm:ss):	0:00:01:09	
Log Interval (mm:ss):	0:01	
Number of points:	5	
Notes:	Test 008	



Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	1081	75.2	37.7	0
	Minimum:	1046	75.2	36.4	0
	Time of Minimum:	16:37:55	16:38:55	16:39:03	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	1110	75.3	38.6	0
	Time of Maximum:	16:38:08	16:38:08	16:38:08	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	5/10/18			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	16:37:55	1046	75.2	38.1	0
10/30/18	16:38:08	1110	75.3	38.6	0
10/30/18	16:38:46	1086	75.3	37.8	0
10/30/18	16:38:55	1088	75.2	37.4	0
10/30/18	16:39:03	1075	75.3	36.4	0

IAQ Investigation Log

Test ID:	Indiana Avenue School No. 18	CHARTWELLS FOOD PREP ROOM
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	9	
Test Abbreviation:	Test 009	
Start Date:	10/30/18	
Start Time:	16:51:39	
Duration (dd:hh:mm:ss):	0:00:00:40	
Log Interval (mm:ss):	0:01	
Number of points:	5	
Notes:	Test 009	



Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	997	74.4	33	0
	Minimum:	967	74.4	32.4	0
	Time of Minimum:	16:52:19	16:52:10	16:51:40	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	1052	74.5	33.6	0
	Time of Maximum:	16:51:40	16:51:40	16:52:01	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	1/0/00			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	16:51:40	1052	74.5	32.4	0
10/30/18	16:51:50	983	74.4	32.9	0
10/30/18	16:52:01	1004	74.5	33.6	0
10/30/18	16:52:10	977	74.4	33.5	0
10/30/18	16:52:19	967	74.4	32.8	0

IAQ Investigation Log

Test ID:	SCHOOL	MULTI-PURPOSE ROM
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	10	
Test Abbreviation:	Test 010	
Start Date:	10/30/18	
Start Time:	17:05:08	
Duration (dd:hh:mm:ss):	0:00:02:21	
Log Interval (mm:ss):	0:01	
Number of points:	5	
Notes:	Test 010	




Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	879	74.8	30	0
	Minimum:	864	74.8	29.8	0
	Time of Minimum:	17:06:23	17:06:23	17:05:09	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	905	74.8	30.3	0
	Time of Maximum:	17:06:56	17:05:33	17:07:29	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	5/10/18			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	17:05:09	874	74.8	29.8	0
10/30/18	17:05:33	867	74.8	29.9	0
10/30/18	17:06:23	864	74.8	29.9	0
10/30/18	17:06:56	905	74.8	30.2	0
10/30/18	17:07:29	886	74.8	30.3	0

IAQ Investigation Log

Test ID:	Indiana Avenue School No. 18	OUTSIDE CONTROL SAMPLE
Model Number:	7545	
Serial Number:	T75451819008	
Test ID:	11	
Test Abbreviation:	Test 011	
Start Date:	10/30/18	
Start Time:	17:19:49	
Duration (dd:hh:mm:ss):	0:00:01:41	
Log Interval (mm:ss):	0:01	
Number of points:	5	
Notes:	Test 011	

Statistics	Channel:	CO2 - Carbon Dioxide	T - Temperature	H - Humidity	CO - Carbon Monoxide
	Units:	ppm	deg F	%rh	ppm
	Average:	437	54.2	40.8	0
	Minimum:	433	52.7	40.1	0
	Time of Minimum:	17:21:30	17:21:30	17:20:15	0:00:00
	Date of Minimum:	10/30/18	10/30/18	10/30/18	1/0/00
	Maximum:	444	56	42.1	0
	Time of Maximum:	17:20:15	17:19:50	17:21:30	0:00:00
	Date of Maximum:	10/30/18	10/30/18	10/30/18	1/0/00

Calibration	Meter:	5/10/18			
Calibration	Sensor:	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
	Cal. Date	5/10/18	5/10/18	5/10/18	5/10/18

Date	Time	CO2 - Carbon Dioxide	T-Temperature	H-Humidity	CO - Carbon Monoxide
MM/DD/YYYY	hh:mm:ss	ppm	deg F	%rh	ppm
10/30/18	17:19:50	441	56	40.2	0
10/30/18	17:20:15	444	54.7	40.1	0
10/30/18	17:20:28	436	54.2	40.6	0
10/30/18	17:20:46	434	53.5	40.8	0
10/30/18	17:21:30	433	52.7	42.1	0