

**Lead Sampling of Drinking Water**  
**Creekside Early Learning Center**  
**Shadow Hills Elementary & Mountain View**  
**Learning Academy**

Water System Name: Padre Dam Municipal Water District

Water System Number: 3710037

School Name: Creekside Early Learning Center

School Address: 8818 Harbison Canyon Road

Meeting Date: 8/4/17

**Sample No. 1 - Creekside**

Name of Building: Health Office

Location Description: Health Office sink

Type of Outlet: Sink

Sample I.D. 3710037-ABI-A

(circle sample type)       **Initial**       1<sup>st</sup> Follow-up       2<sup>nd</sup> Follow-up

Post-corrective action

Date & Time Last Used: 9/12 1:30PM

Date Sample Collected: 9/13

Time Sample Collected: 6:25AM

Name of Sample Collector: Joe Guzzino

(circle collector type) Water System Operator Water System Representative  
Contractor

Lead Concentration (ppb): ND

**Sample No. 2 - Creekside**

Name of Building: Lunch Area

Location Description: Lunch Area

Type of Outlet: Drinking fountain (middle fountain)

Sample I.D. 3710037-ABI-B

(circle sample type) Initial 1<sup>st</sup> Follow-up 2<sup>nd</sup> Follow-up  
Post-corrective action

Date & Time Last Used: 9/12 3:15pm

Date Sample Collected: 9/13

Time Sample Collected: 6:30am

Name of Sample Collector: Joe Guzzino

(circle collector type) Water System Operator Water System Representative  
Contractor

Lead Concentration (ppb): ND

**Sample No. 3 - Creekside**

Name of Building: Cafeteria

Location Description: Cafeteria sink

Type of Outlet: Sink

Sample I.D. 3710037-ABI-C

(circle sample type)       Initial      1<sup>st</sup> Follow-up      2<sup>nd</sup> Follow-up  
Post-corrective action

Date & Time Last Used: 9/12 1:23pm

Date Sample Collected: 9/13

Time Sample Collected: 6:35am

Name of Sample Collector: Joe Guzzino

(circle collector type)       Water System Operator      Water System Representative  
Contractor

Lead Concentration (ppb): ND

**Sample No. 4 - Creekside**

Name of Building: Restrooms

Location Description: Across from building #10

Type of Outlet: Drinking fountain (right fixture, middle fountain)

Sample I.D. 3710037-ABI-D

(circle sample type)       Initial      1<sup>st</sup> Follow-up      2<sup>nd</sup> Follow-up  
Post-corrective action

Date & Time Last Used: 9/12 3:10pm

Date Sample Collected: 9/13

Time Sample Collected: 6:40am

Name of Sample Collector: Joe Guzzino

(circle collector type)       Water System Operator      Water System Representative  
Contractor

Lead Concentration (ppb): ND

**Sample No. 5 - Creekside**

Name of Building: Restrooms

Location Description: Across from building #13

Type of Outlet: Drinking fountain (right fixture, middle fountain)

Sample I.D. 3710037-ABI-E

(circle sample type)      Initial      1<sup>st</sup> Follow-up      2<sup>nd</sup> Follow-up

Post-corrective action

Date & Time Last Used: 9/12

Date Sample Collected: 9/13

Time Sample Collected: 6:45am

Name of Sample Collector: Joe Guzzino

(circle collector type)      Water System Operator      Water System Representative

Contractor

Lead Concentration (ppb): ND

**Sample No. 6 – Shadow Hills/Mountain View**

Name of Building: Cafeteria

Location Description: Cafeteria sink

Type of Outlet: Sink

Sample I.D. 3710037-ABH-A

(circle sample type)      Initial      1<sup>st</sup> Follow-up      2<sup>nd</sup> Follow-up

Post-corrective action

Date & Time Last Used: 9/12 12:56PM

Date Sample Collected: 9/13

Time Sample Collected: 6:50AM

Name of Sample Collector: Joe Guzzino

(circle collector type) Water System Operator Water System Representative  
Contractor

Lead Concentration (ppb): ND

**Sample No. 7 – Shadow Hills/Mountain View**

Name of Building: Cafeteria

Location Description: Drinking fountain outside cafeteria

Type of Outlet: Drinking fountain (left fixture)

Sample I.D. 3710037-ABH-B

(circle sample type) Initial 1<sup>st</sup> Follow-up 2<sup>nd</sup> Follow-up  
Post-corrective action

Date & Time Last Used: 9/12 1:00pm

Date Sample Collected: 9/13

Time Sample Collected: 6:55am

Name of Sample Collector: Joe Guzzino

(circle collector type) Water System Operator Water System Representative  
Contractor

Lead Concentration (ppb): 5.66

**Sample No. 8 – Shadow Hills/Mountain View**

Name of Building: Building #23

Location Description: Restrooms

Type of Outlet: Drinking fountain (left fixture)

Sample I.D. 3710037-ABH-C

(circle sample type)      Initial      1<sup>st</sup> Follow-up      2<sup>nd</sup> Follow-up  
Post-corrective action

Date & Time Last Used: 9/12 3:15pm

Date Sample Collected: 9/13

Time Sample Collected: 7:00am

Name of Sample Collector: Joe Guzzino

(circle collector type)      Water System Operator      Water System Representative  
Contractor

Lead Concentration (ppb): ND

**Sample No. 9 – Shadow Hills/Mountain View**

Name of Building: Building #15

Location Description: Restrooms

Type of Outlet: Drinking fountain

Sample I.D. 3710037-ABH-D

(circle sample type)      Initial      1<sup>st</sup> Follow-up      2<sup>nd</sup> Follow-up  
Post-corrective action

Date & Time Last Used: 9/12 3:10pm

Date Sample Collected: 9/13

Time Sample Collected: 7:05am

Name of Sample Collector: Joe Guzzino

(circle collector type)      Water System Operator      Water System Representative  
Contractor

Lead Concentration (ppb): ND

**Sample No. 10 – Shadow Hills/Mountain View**

Name of Building: Health Office

Location Description: Health Office

Type of Outlet: Sink

Sample I.D. 3710037-ABH-E

(circle sample type)       Initial       1<sup>st</sup> Follow-up       2<sup>nd</sup> Follow-up

Post-corrective action

Date & Time Last Used: 9/12 10:50pm

Date Sample Collected: 9/13

Time Sample Collected: 7:10am

Name of Sample Collector: Joe Guzzino

(circle collector type)       Water System Operator       Water System Representative

Contractor

Lead Concentration (ppb): ND



26 September 2017

Padre Dam MWD  
Attn: Joe Guzzino  
PO Box 719003  
Santee, California 92072-9003

EMA Log #: 17I0433

**Project Name: Lead Sampling in Schools**  
**Project Desc./#: PS 3710037**

Enclosed are the results of analyses for samples received by the laboratory on 09/14/17 09:55. Samples were analyzed pursuant to client request utilizing EPA or other ELAP approved methodologies. I certify that this data is in compliance both technically and for completeness.

A handwritten signature in black ink, appearing to read 'Dan Verdon', is written over a light gray grid background.

**Dan Verdon**  
**Laboratory Director**

CA ELAP Certification #: 2564



Client Name: Padre Dam MWD  
Project Name: Lead Sampling in Schools

EMA Log #: 17I0433

### ANALYTICAL REPORT FOR SAMPLES

| Sample ID     | Laboratory ID | Matrix         | Date Sampled   | Date Received  |
|---------------|---------------|----------------|----------------|----------------|
| 3710037-ABI-A | 17I0433-01    | Drinking Water | 09/13/17 06:25 | 09/14/17 09:55 |
| 3710037-ABI-B | 17I0433-02    | Drinking Water | 09/13/17 06:30 | 09/14/17 09:55 |
| 3710037-ABI-C | 17I0433-03    | Drinking Water | 09/13/17 06:35 | 09/14/17 09:55 |
| 3710037-ABI-D | 17I0433-04    | Drinking Water | 09/13/17 06:40 | 09/14/17 09:55 |
| 3710037-ABI-E | 17I0433-05    | Drinking Water | 09/13/17 06:45 | 09/14/17 09:55 |
| 3710037-ABH-A | 17I0433-06    | Drinking Water | 09/13/17 06:50 | 09/14/17 09:55 |
| 3710037-ABH-B | 17I0433-07    | Drinking Water | 09/13/17 06:55 | 09/14/17 09:55 |
| 3710037-ABH-C | 17I0433-08    | Drinking Water | 09/13/17 07:00 | 09/14/17 09:55 |
| 3710037-ABH-D | 17I0433-09    | Drinking Water | 09/13/17 07:05 | 09/14/17 09:55 |
| 3710037-ABH-E | 17I0433-10    | Drinking Water | 09/13/17 07:10 | 09/14/17 09:55 |

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Client Name: Padre Dam MWD  
Project Name: Lead Sampling in Schools

EMA Log #: 17I0433

### Total Metals by EPA 200 Series Methods

| Analyte   | Result | Reporting Limit | Units | Dilution | Batch   | Prepared | Analyzed | Method    | Notes |
|---|--------|-----------------|-------|----------|---------|----------|----------|-----------|-------|
| <b>3710037-ABI-A (17I0433-01) Drinking Water</b> <b>Sampled: 09/13/17 06:25</b> <b>Received: 09/14/17 09:55</b> |        |                 |       |          |         |          |          |           |       |
| Lead  | ND     | 5.00            | ug/l  | 1        | 7092203 | 09/22/17 | 09/22/17 | EPA 200.8 |       |
| <b>3710037-ABI-B (17I0433-02) Drinking Water</b> <b>Sampled: 09/13/17 06:30</b> <b>Received: 09/14/17 09:55</b> |        |                 |       |          |         |          |          |           |       |
| Lead  | ND     | 5.00            | ug/l  | 1        | 7092203 | 09/22/17 | 09/22/17 | EPA 200.8 |       |
| <b>3710037-ABI-C (17I0433-03) Drinking Water</b> <b>Sampled: 09/13/17 06:35</b> <b>Received: 09/14/17 09:55</b> |        |                 |       |          |         |          |          |           |       |
| Lead  | ND     | 5.00            | ug/l  | 1        | 7092203 | 09/22/17 | 09/22/17 | EPA 200.8 |       |
| <b>3710037-ABI-D (17I0433-04) Drinking Water</b> <b>Sampled: 09/13/17 06:40</b> <b>Received: 09/14/17 09:55</b> |        |                 |       |          |         |          |          |           |       |
| Lead  | ND     | 5.00            | ug/l  | 1        | 7092203 | 09/22/17 | 09/22/17 | EPA 200.8 |       |
| <b>3710037-ABI-E (17I0433-05) Drinking Water</b> <b>Sampled: 09/13/17 06:45</b> <b>Received: 09/14/17 09:55</b> |        |                 |       |          |         |          |          |           |       |
| Lead  | ND     | 5.00            | ug/l  | 1        | 7092203 | 09/22/17 | 09/22/17 | EPA 200.8 |       |
| <b>3710037-ABH-A (17I0433-06) Drinking Water</b> <b>Sampled: 09/13/17 06:50</b> <b>Received: 09/14/17 09:55</b> |        |                 |       |          |         |          |          |           |       |
| Lead  | ND     | 5.00            | ug/l  | 1        | 7092203 | 09/22/17 | 09/22/17 | EPA 200.8 |       |
| <b>3710037-ABH-B (17I0433-07) Drinking Water</b> <b>Sampled: 09/13/17 06:55</b> <b>Received: 09/14/17 09:55</b> |        |                 |       |          |         |          |          |           |       |
| Lead  | 5.66   | 5.00            | ug/l  | 1        | 7092203 | 09/22/17 | 09/22/17 | EPA 200.8 |       |
| <b>3710037-ABH-C (17I0433-08) Drinking Water</b> <b>Sampled: 09/13/17 07:00</b> <b>Received: 09/14/17 09:55</b> |        |                 |       |          |         |          |          |           |       |
| Lead  | ND     | 5.00            | ug/l  | 1        | 7092203 | 09/22/17 | 09/22/17 | EPA 200.8 |       |
| <b>3710037-ABH-D (17I0433-09) Drinking Water</b> <b>Sampled: 09/13/17 07:05</b> <b>Received: 09/14/17 09:55</b> |        |                 |       |          |         |          |          |           |       |
| Lead  | ND     | 5.00            | ug/l  | 1        | 7092203 | 09/22/17 | 09/22/17 | EPA 200.8 |       |

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Client Name: Padre Dam MWD  
Project Name: Lead Sampling in Schools

EMA Log #: 17I0433

### Total Metals by EPA 200 Series Methods

| Analyte   | Result | Reporting Limit | Units | Dilution | Batch   | Prepared | Analyzed | Method    | Notes |
|---|--------|-----------------|-------|----------|---------|----------|----------|-----------|-------|
| <b>3710037-ABH-E (17I0433-10) Drinking Water</b> <b>Sampled: 09/13/17 07:10</b> <b>Received: 09/14/17 09:55</b> |        |                 |       |          |         |          |          |           |       |
| Lead  | ND     | 5.00            | ug/l  | 1        | 7092203 | 09/22/17 | 09/22/17 | EPA 200.8 |       |

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

EnviroMatrix Analytical, Inc.

