

District Lead Testing Results - Collingswood Public Schools

Action Level is 15 µg/L

School	Location	Result µg/L	Action Level µg/L	Collect Date	Planned Remediation
Garfield	NURSE OFFICE SINK	8.01	15.00	1/24/2017	
Garfield	1ST FLOOR WATER FOUNTAIN	ND	15.00	1/24/2017	
Garfield	2ND TOILET ROOM SINK	1.01	15.00	1/24/2017	
Garfield	BOYS TOILET ROOM SINK	ND	15.00	1/24/2017	
Garfield	KITCHEN SINK	3.03	15.00	1/24/2017	
Garfield	STAFF LOUNGE SINK	4.46	15.00	1/24/2017	
Garfield	1ST FLOOR BATHROOM SINK	3.75	15.00	1/24/2017	
Garfield	BASEMENT WATER FOUNTAIN	ND	15.00	1/24/2017	
Garfield	GIRLS TOILET ROOM SINK	1.87	15.00	1/24/2017	
Garfield	2ND FLOOR WATER FOUNTAIN	ND	15.00	1/24/2017	
Garfield	BASEMENT WATER FOUNTAIN	2.18	15.00	11/23/2016	
Garfield	1ST FLOOR WATER FOUNTAIN	ND	15.00	12/20/2016	
Garfield	STAFF LOUNGE SINK	ND	15.00	12/20/2016	

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines

District Lead Testing Results - Collingswood Public Schools

Action Level is 15µg/L

School	Location	Result µg/L	Action Level µg/L	Collect Date	Planned Remediation
Mark Newbie	ROOM 113 SINK	2.35	15.00	1/23/2017	
Mark Newbie	1ST FLOOR WATER FOUNTAIN	ND	15.00	1/23/2017	
Mark Newbie	ROOM 112 SINK	8.15	15.00	1/23/2017	
Mark Newbie	ROOM 115 SINK	1.80	15.00	1/23/2017	
Mark Newbie	GIRLS ROOM SINK	2.51	15.00	1/23/2017	
Mark Newbie	TEACHERS LOUNGE SINK	2.24	15.00	1/23/2017	
Mark Newbie	NURSE SINK	3.91	15.00	1/23/2017	
Mark Newbie	MAIN ENTRANCE WATER FOUNTAIN	ND	15.00	1/23/2017	
Mark Newbie	MAIN OFFICE SINK	1.00	15.00	1/23/2017	
Mark Newbie	BOYS ROOM SINK	1.55	15.00	1/23/2017	
Mark Newbie	KITCHEN SINK SINGLE	3.25	15.00	1/23/2017	
Mark Newbie	ROOM B02 SINK	2.20	15.00	1/23/2017	
Mark Newbie	WATER FOUNTAIN OUTSIDE BOILER ROOM	ND	15.00	1/23/2017	
Mark Newbie	ROOM 106 SINK	1.88	15.00	1/23/2017	
Mark Newbie	ROOM 110 SINK	3.38	15.00	1/23/2017	
Mark Newbie	WATER FOUNTAIN OUTSIDE BOILER ROOM	2.33	15.00	11/23/2016	
Mark Newbie	1ST FLOOR WATER FOUNTAIN	ND	15.00	12/20/2016	
Mark Newbie	KITCHEN SINK DOUBLE	4.06	15.00	12/20/2016	

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines

District Lead Testing Results - Collingswood Public Schools

Action Level is 15µg/L

School	Location	Result µg/L	Action Level µg/L	Collect Date	Planned Remediation
Sharp	BASEMENT WATER FOUNTAIN	ND	15.00	1/27/2017	
Sharp	WATER FOUNTAIN OUTSIDE KITCHEN	ND	15.00	1/27/2017	
Sharp	WATER FOUNTAIN OUTSIDE 1ST GIRLS TOILET ROOM	62.30	15.00	1/27/2017	Conducted flush on 2/16/17
Sharp	WATER FOUNTAIN OUTSIDE 1ST GIRLS TOILET ROOM FLUSH	9.80	15.00	2/16/2017	REPLACE RELATED PLUMBING
Sharp	2ND FLOOR STAFF TOILET ROOM	5.12	15.00	1/27/2017	
Sharp	2ND FLOOR WATER FOUNTAIN	ND	15.00	1/27/2017	
Sharp	ART ROOM SINK	ND	15.00	1/27/2017	
Sharp	1ST FLOOR GIRLS TOILET ROOM SINK	1.93	15.00	1/27/2017	
Sharp	1ST FLOOR BOYS TOILET ROOM SINK	2.22	15.00	1/27/2017	
Sharp	NURSE OFFICE SINK	ND	15.00	1/27/2017	
Sharp	1ST FLOOR WATER FOUNTAIN	ND	15.00	1/27/2017	
Sharp	MAIN OFFICE SINK	1.57	15.00	1/27/2017	
Sharp	LIBRARY SINK	ND	15.00	1/27/2017	
Sharp	BASEMENT BOYS TOILET ROOM SINK	2.36	15.00	1/27/2017	
Sharp	KITCHEN SINK	1.56	15.00	1/27/2017	
Sharp	BASEMENT GIRLS TOILET ROOM SINK	1.92	15.00	1/27/2017	
Sharp	WATER FOUNTAIN IN BASEMENT BY BOILER ROOM	ND	15.00	11/23/2016	
Sharp	WATER FOUNTAIN IN BASEMENT BY BOILER ROOM	ND	15.00	12/20/2016	
Sharp	KITCHEN SINK	1.67	15.00	12/20/2016	

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines

District Lead Testing Results - Collingswood Public Schools

Action Level is 15µg/L

School	Location	Result µg/L	Action Level µg/L	Collect Date	Planned Remediation
Tatem	ROOM 101 SINK	9.93	15.00	1/26/2017	
Tatem	ROOM 120 SINK	2.89	15.00	1/26/2017	
Tatem	ROOM 121 SINK	4.37	15.00	1/26/2017	
Tatem	NURSES OFFICE SINK	ND	15.00	1/26/2017	
Tatem	ROOM 122 SINK	3.82	15.00	1/26/2017	
Tatem	ROOM 123 SINK	22.90	15.00	1/26/2017	Conducted flush on 2/16/17
Tatem	ROOM 123 FLUSH	8.39	15.00	2/16/2017	REPLACE RELATED PLUMBING
Tatem	LOWER LEVEL WATER FOUNTAIN BY TOILET ROOMS	ND	15.00	1/26/2017	
Tatem	LOWER LEVEL BOYS TOILET ROOM SINK	ND	15.00	1/26/2017	
Tatem	LOWER LEVEL GIRLS TOILET ROOM SINK	ND	15.00	1/26/2017	
Tatem	STAFF MENS TOILET ROOM SINK	ND	15.00	1/26/2017	
Tatem	STAFF WOMENS TOILET ROOM SINK	2.17	15.00	1/26/2017	
Tatem	STAFF LOUNGE SINK	1.81	15.00	1/26/2017	
Tatem	WATER FOUNTAIN BY ROOM 112	ND	15.00	1/26/2017	
Tatem	ROOM 112 SINK	3.53	15.00	1/26/2017	
Tatem	ART ROOM SINK	1.17	15.00	1/26/2017	
Tatem	WATER FOUNTAIN BY ROOM 104	ND	15.00	1/26/2017	
Tatem	ROOM 110 SINK	ND	15.00	1/26/2017	
Tatem	KITCHEN SINK	ND	15.00	1/26/2017	
Tatem	ROOM 103 SINK	1.85	15.00	1/26/2017	
Tatem	UPPER FLOOR BOYS TOILET ROOM SINK	1.33	15.00	1/26/2017	
Tatem	UPPER FLOOR GIRLS TOILET ROOM SINK	ND	15.00	1/26/2017	
Tatem	ROOM 102 SINK	2.10	15.00	1/26/2017	
Tatem	LOWER LEVEL WATER FOUNTAIN BY TOILET ROOMS	ND	15.00	11/23/2017	
Tatem	KITCHEN SINK	ND	15.00	12/20/2016	
Tatem	WATER FOUNTAIN LOWER FLOOR	ND	15.00	12/20/2016	

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines

District Lead Testing Results - Collingswood Public Schools

Action Level is 15µg/L

School	Location	Result µg/L	Action Level µg/L	Collect Date	Planned Remediation
Zane North	ROOM 110 SINK	5.80	15.00	1/24/2017	
Zane North	ROOM 111 SINK	5.40	15.00	1/24/2017	
Zane North	ROOM 109 SINK	1.95	15.00	1/24/2017	
Zane North	KITCHEN SINK	1.51	15.00	1/24/2017	
Zane North	ROOM 112 SINK	1.18	15.00	1/24/2017	
Zane North	ROOM 115 SINK	2.07	15.00	1/24/2017	
Zane North	ROOM 113 SINK	1.16	15.00	1/24/2017	
Zane North	ROOM 114 SINK	2.45	15.00	1/24/2017	
Zane North	STAFF MENS ROOM SINK	1.41	15.00	1/24/2017	
Zane North	STAFF LADIES SINK	4.12	15.00	1/24/2017	
Zane North	MAIN ENTRANCE WATER FOUNTAIN	ND	15.00	1/24/2017	
Zane North	ROOM 126 GIRLS TOILET ROOM SINK	7.18	15.00	1/24/2017	
Zane North	ROOM 126 WATER FOUNTAIN	3.27	15.00	1/24/2017	
Zane North	ROOM 126 BOYS TOILET ROOM SINK	3.96	15.00	1/24/2017	
Zane North	ROOM 125 BOYS TOILET ROOM SINK	3.61	15.00	1/24/2017	
Zane North	ROOM 125 WATER FOUNTAIN	9.30	15.00	1/24/2017	
Zane North	BOYS PUBLIC TOILET ROOM SINK	1.87	15.00	1/24/2017	
Zane North	WATER FOUNTAIN OUTSIDE ROOM 108	ND	15.00	1/24/2017	
Zane North	GIRLS PUBLIC TOILET ROOM SINK	2.70	15.00	1/24/2017	
Zane North	ROOM 123 WATER FOUNTAIN	1.55	15.00	1/24/2017	
Zane North	ROOM 124 BOYS TOILET ROOM SINK	8.62	15.00	1/24/2017	
Zane North	ROOM 123 BOYS TOILET ROOM SINK	6.71	15.00	1/24/2017	
Zane North	ROOM 124 GIRLS TOILET ROOM SINK	4.20	15.00	1/24/2017	
Zane North	ROOM 124 WATER FOUNTAIN	38.20	15.00	1/24/2017	Conducted flush on 2/16/17
Zane North	ROOM 124 WATER FOUNTAIN FLUSH	2.91	15.00	2/16/2017	REPLACE RELATED PLUMBING
Zane North	ROOM 123 GIRLS TOILET ROOM SINK	1.28	15.00	1/24/2017	
Zane North	ROOM 117 SINK	ND	15.00	1/24/2017	
Zane North	ROOM 120 SINK	1.32	15.00	1/24/2017	
Zane North	ROOM 125 GIRLS TOILET ROOM SINK	ND	15.00	1/24/2017	

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines

Zane North	BOARD OFFICE LADIES ROOM SINK	25.90	15.00	1/24/2017	Conducted flush on 2/16/17
Zane North	BOE LADIES ROOM SINK FLUSH	28.5	15.00	2/16/2017	REPLACE RELATED PLUMBING
Zane North	BOARD OFFICE KITCHEN SINK	1.44	15.00	1/24/2017	
Zane North	BOE MENS ROOM SINK	1.56	15.00	1/24/2017	
Zane North	BOILER ROOM SINK	ND	15.00	11/23/2016	
Zane North	KITCHEN SINK	ND	15.00	12/20/2016	
Zane North	ZANE NORTH W/F	2.14	15.00	12/20/2016	

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines

District Lead Testing Results - Collingswood Public Schools

Action Level is 15µg/L

School	Location	Result µg/L	Action Level µg/L	Collect Date	Planned Remediation
Middle School	1ST FLOOR WATER FOUNTAIN BY ROOM 104	1.12	15.00	2/1/2017	
Middle School	ROOM 111 SINK BY DOOR	ND	15.00	2/1/2017	
Middle School	ROOM 109 SINK	ND	15.00	2/1/2017	
Middle School	ROOM 111 FAR SINK	ND	15.00	2/1/2017	
Middle School	1ST FLOOR UNISEX TOILET ROOM	ND	15.00	2/1/2017	
Middle School	1ST FLOOR CUSTODIAL SINK BY ROOM 111	6.80	15.00	2/1/2017	
Middle School	WOOD SHOP SINK	ND	15.00	2/1/2017	
Middle School	1ST WATER FOUNTAIN BY ROOM 109	ND	15.00	2/1/2017	
Middle School	ROOM 112 SINK	1.39	15.00	2/1/2017	
Middle School	KITCHEN TOILET ROOM SINK	ND	15.00	2/1/2017	
Middle School	KITCHEN 3 BAY SINK	3.05	15.00	2/1/2017	
Middle School	1ST FLOOR BOYS TOILET ROOM SINK	1.47	15.00	2/1/2017	
Middle School	2ND FLOOR STAFF LOUNGE SINK	4.12	15.00	2/1/2017	
Middle School	1ST FLOOR GIRLS TOILET ROOM SINK	3.37	15.00	2/1/2017	
Middle School	KITCHEN 2 BAY SINK	1.33	15.00	2/1/2017	
Middle School	2ND FLOOR STAFF LOUNGE FILTERED WATER TAP	ND	15.00	2/1/2017	
Middle School	3RD FLOOR WATER FOUNTAIN BY ROOM 309	ND	15.00	2/2/2017	
Middle School	LAB SINK IN ROOM 304	ND	15.00	2/2/2017	
Middle School	ROOM 302 SINK	1.59	15.00	2/2/2017	
Middle School	2ND FLOOR CUSTODIAL CLOSET SINK	5.08	15.00	2/2/2017	
Middle School	WATER FOUNTAIN BY 209	ND	15.00	2/2/2017	
Middle School	3RD FLOOR BOYS TOILET ROOM SINK	1.27	15.00	2/2/2017	
Middle School	2ND FLOOR BOYS TOILET ROOM SINK	ND	15.00	2/2/2017	
Middle School	2ND FLOOR GIRLS TOILET ROOM SINK	1.97	15.00	2/2/2017	
Middle School	3RD FLOOR GIRLS TOILET ROOM SINK	1.06	15.00	2/2/2017	
Middle School	3RD FLOOR WATER FOUNTAIN BY ROOM 304	ND	15.00	2/2/2017	
Middle School	2ND FLOOR WATER FOUNTAIN BY ROOM 206	1.00	15.00	2/2/2017	
Middle School	2ND FLOOR WATER FOUNTAIN BY ROOM 203	ND	15.00	2/2/2017	

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines

Middle School	BOILER ROOM SINK	96.20	15.00	11/23/2016	"HANDWASH ONLY" Signage Required
Middle School	KITCHEN SINK	9.37	15.00	12/20/2016	
Middle School	1ST FLOOR WATER FOUNTAIN	ND	15.00	12/20/2016	

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines

District Lead Testing Results - Collingswood Public Schools

Action Level is 15µg/L

School	Location	Result µg/L	Action Level µg/L	Collect Date	Planned Remediation
Link	2ND FLOOR UNISEX TOILET ROOM BY WATER FOUNTAIN	ND	15.00	2/3/2017	
Link	2ND FLOOR UNISEX FAR TOILET ROOM SINK	1.00	15.00	2/3/2017	
Link	2ND FLOOR WATER FOUNTAIN	ND	15.00	2/3/2017	
Link	1ST FLOOR WATER FOUNTAIN	ND	15.00	2/3/2017	
Link	2ND FLOOR GIRLS PUBLIC TOILET ROOM SINK	ND	15.00	2/3/2017	
Link	2ND FLOOR BOYS PUBLIC TOILET ROOM SINK	ND	15.00	2/3/2017	
Link	NURSES OFFICE SINK	ND	15.00	2/3/2017	
Link	1ST FLOOR MENS TOILET ROOM SINK	ND	15.00	2/3/2017	
Link	1ST FLOOR WOMENS TOILET ROOM SINK	ND	15.00	2/3/2017	
Link	BEN MARK BOYS TOILET ROOM SINK	ND	15.00	2/3/2017	
Link	BEN MARK WATER FOUNTAIN	ND	15.00	2/3/2017	
Link	BEN MARK GIRLS TOILET ROOM SINK	ND	15.00	2/3/2017	
Link	ROOM 230 CLOSE SINK	1.17	15.00	2/3/2017	
Link	ROOM 239 FAR SINK	1.64	15.00	2/3/2017	
Link	ROOM 237 CLOSE SINK	1.22	15.00	2/3/2017	
Link	ROOM 237 FAR SINK	ND	15.00	2/3/2017	
Link	3RD FLOOR WATER FOUNTAIN	ND	15.00	2/3/2017	
Link	ROOM 324 SINK	ND	15.00	2/3/2017	
Link	LIBRARY BOYS TOILET ROOM SINK	ND	15.00	2/3/2017	
Link	LIBRARY GIRLS TOILET ROOM SINK	ND	15.00	2/3/2017	

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines

District Lead Testing Results - Collingswood Public Schools

Action Level is 15µg/L

School	Location	Result µg/L	Action Level µg/L	Collect Date	Planned Remediation
High School	ROOM 143 SINK	ND	15.00	2/6/2017	
High School	WATER FOUNTAIN BY IRVINE BOYS TOILET ROOM	ND	15.00	2/6/2017	
High School	IRVINE BOYS TOILET ROOM SINK	39.90	15.00	2/6/2017	Conducted flush on 2/16/17
High School	IRVINE BOYS TOILET ROOM SINK FLUSH**	8.51	15.00	2/16/2017	REPLACE RELATED PLUMBING
High School	ATHLETIC OFFICE SINK	18.50	15.00	2/6/2017	Conducted flush on 2/16/17
High School	ATHLETIC OFFICE SINK FLUSH**	2.39	15.00	2/16/2017	REPLACE RELATED PLUMBING
High School	WATER FOUNTAIN BY IRVINE GIRLS TOILET ROOM	1.63	15.00	2/6/2017	
High School	IRVINES GIRLS TOILET ROOM SINK	ND	15.00	2/6/2017	
High School	WATER FOUNTAIN BY ROOM 220	4.28	15.00	2/6/2017	
High School	ROOM 220 SINK	2.23	15.00	2/6/2017	
High School	GIRLS LOCKER ROOM TOILET ROOM SINK	ND	15.00	2/6/2017	
High School	GIRLS COACHES OFFICE SINK	4.24	15.00	2/6/2017	
High School	BOYS COACHES OFFICE SINK	1.42	15.00	2/6/2017	
High School	BOYS LOCKER ROOM TOILET ROOM SINK	ND	15.00	2/6/2017	
High School	ROOM 130 Science Sink	34.10	15.00	2/6/2017	HANDWASH ONLY SIGNAGE REQUIRED
High School	KITCHEN DISWASHER SINK	40.30	15.00	2/6/2017	Conducted flush on 2/16/17
High School	KITCHEN DISHWASHER SINK FLUSH**	ND	15.00	2/16/2017	REPLACE RELATED PLUMBING
High School	KITCHEN SINK BY ICE MAKER	14.60	15.00	2/6/2017	
High School	ROOM 123 SINK	8.65	15.00	2/6/2017	
High School	WATER FOUNTAIN BY SCHOOL STORE	ND	15.00	2/6/2017	
High School	KITCHEN HANDWASH SINK	2.33	15.00	2/6/2017	
High School	ROOM 122 SINK	2.93	15.00	2/6/2017	
High School	WATER FOUNTAIN BY GREENHOUSE DOOR	1.18	15.00	2/6/2017	
High School	KITCHEN 3 BAY SINK	1.88	15.00	2/6/2017	
High School	ROOM 124 SINK	15.20	15.00	2/6/2017	Conducted flush on 2/16/17
High School	ROOM 124 FLUSH**	ND	15.00	2/16/2017	HANDWASH ONLY SIGNAGE REQUIRED
High School	CAFÉ BOYS TOILET ROOM SINK	2.55	15.00	2/6/2017	
High School	CAFÉ GIRLS TOILET ROOM SINK	ND	15.00	2/6/2017	
High School	OLD B&G OFFICE SINK	47.30	15.00	11/23/2016	Conducted flush on 2/16/17

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines

High School	OLD B&G OFFICE SINK FLUSH**	2.14	15.00	2/16/2017	HANDWASH ONLY SIGNAGE REQUIRED
High School	MAINTENANCE CENTER WATER FOUNTAIN	3.96	15.00	11/23/2016	
High School	STAFF LOUNGE SINK	ND	15.00	2/13/2017	
High School	STAFF LOUNGE TOILET ROOM SINK	1.39	15.00	2/13/2017	
High School	MENS ROOM MAIN OFFICE SINK	2.71	15.00	2/13/2017	
High School	1ST FLOOR CENTER WATER FOUNTAIN	ND	15.00	2/13/2017	
High School	1ST FLOOR BOYS TOILET ROOM SINK	4.29	15.00	2/13/2017	
High School	1ST FLOOR GIRLS TOILET ROOM SINK	10.20	15.00	2/13/2017	
High School	ROOM 104 CLOSE SINK	3.29	15.00	2/13/2017	
High School	ROOM 104 FAR SINK	ND	15.00	2/13/2017	
High School	2ND FLOOR WATER FOUNTAIN	ND	15.00	2/13/2017	
High School	2ND FLOOR BOYS TOILET ROOM SINK	ND	15.00	2/13/2017	
High School	2ND FLOOR GIRLS TOILET ROOM SINK	ND	15.00	2/13/2017	
High School	ROOM 209 CLOSE SINK	3.16	15.00	2/13/2017	
High School	ROOM 209 FAR SINK	1.23	15.00	2/13/2017	
High School	3RD FLOOR WATER FOUNTAIN	ND	15.00	2/13/2017	
High School	3RD FLOOR BOYS TOILET ROOM SINK	5.04	15.00	2/13/2017	
High School	3RD FLOOR GIRLS TOILET ROOM SINK	15.30	15.00	2/13/2017	REPLACE RELATED PLUMBING
High School	ART ROOM SINK	ND	15.00	2/13/2017	
High School	3RD FLOOR HALL STAFF TOILET ROOM SINK	4.78	15.00	2/13/2017	

Legend: ND = Non Detected

** Retest (Flush Test) following NJDOE Guidelines