



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Albion Elementary School
20 School Street
Albion, ME 04910

Date Printed: 05/02/2022
Work Order #: 2203-03564
Client Job #: 827
Date Received: 03/25/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical, LLC: Accreditations: Massachusetts M-MA1118



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/02/2022
CLIENT NAME: Albion Elementary School

CLIENT ADDRESS: 20 School Street
Albion, ME 04910

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/25/2022 11:10AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 13° CELSIUS
CLIENT JOB #: 827

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-03564-001	Nurses room sink	I	OT	03/24/2022 05:30AM	6.3	ppb			DG-NH	04/30/2022 11:05PM
2203-03564-002	Drinking fountain near main office	I	DWF	03/24/2022 05:30AM	<1	ppb			DG-NH	04/30/2022 11:08PM
2203-03564-003	Boys bathroom main hallway sink #1	I	OT	03/24/2022 05:00AM	7.2	ppb			DG-NH	04/30/2022 11:12PM
2203-03564-004	Boys bathroom main hallway sink #2	I	OT	03/24/2022 05:00AM	5.5	ppb			DG-NH	04/30/2022 11:23PM
2203-03564-005	Girls bathroom main hallway sink #1	I	OT	03/24/2022 05:00AM	1.4	ppb			DG-NH	04/30/2022 11:27PM
2203-03564-006	Girls bathroom main hallway sink #2	I	OT	03/24/2022 05:00AM	6.6	ppb			DG-NH	04/30/2022 11:30PM
2203-03564-007	Kitchen faucet #1	I	KF	03/24/2022 05:45AM	3.5	ppb			DG-NH	04/30/2022 11:34PM
2203-03564-008	Kitchen faucet #2	I	KF	03/24/2022 05:45AM	3.8	ppb			DG-NH	04/30/2022 11:45PM
2203-03564-009	Kitchen faucet #3	I	KF	03/24/2022 05:45AM	7.2	ppb			DG-NH	04/30/2022 11:48PM
2203-03564-010	Kitchen faucet #4	I	KF	03/24/2022 05:45AM	5.1	ppb			DG-NH	04/30/2022 11:52PM
2203-03564-011	Kitchen handwashing sink	I	KF	03/24/2022 05:45AM	10.3	ppb			DG-NH	04/30/2022 11:56PM
2203-03564-012	Boys bathroom faucet near back of gym	I	OT	03/24/2022 05:30AM	8.5	ppb			DG-NH	05/01/2022 12:10AM
2203-03564-013	Girls bathroom faucet near back of gym	I	OT	03/24/2022 05:30AM	7.2	ppb			DG-NH	05/01/2022 12:14AM
2203-03564-014	Teachers room water cooler	I	DWF	03/24/2022 05:00AM	<1	ppb			DG-NH	05/01/2022 12:17AM
2203-03564-015	Room #13 bathroom sink #1	I	OT	03/24/2022 05:00AM	10.0	ppb			DG-NH	05/01/2022 12:21AM
2203-03564-016	Boys bathroom old wing sink #1	I	OT	03/24/2022 05:00AM	4.4	ppb			DG-NH	05/01/2022 12:24AM
2203-03564-017	Boys bathroom old wing sink #2	I	OT	03/24/2022 05:00AM	5.0	ppb			DG-NH	05/01/2022 12:28AM
2203-03564-018	Girls bathroom old wing sink #1	I	OT	03/24/2022 05:00AM	3.3	ppb			DG-NH	05/01/2022 12:39AM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/02/2022
CLIENT NAME: Albion Elementary School

CLIENT ADDRESS: 20 School Street
Albion, ME 04910

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 03/25/2022 11:10AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 13° CELSIUS
CLIENT JOB #: 827

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-03564-019	Girls bathroom old wing sink #2	I	OT	03/24/2022 05:00AM	6.1	ppb			DG-NH	05/01/2022 12:43AM
2203-03564-020	Room #13 bathroom sink #2	I	OT	03/24/2022 05:00AM	2.6	ppb			DG-NH	05/01/2022 12:53AM
2203-03564-021	Drinking fountain old wing hallway	I	DWF	03/24/2022 05:00AM	<1	ppb			DG-NH	05/01/2022 12:57AM
2203-03564-022	Room #1 sink	I	OT	03/24/2022 05:30AM	3.3	ppb			DG-NH	05/01/2022 01:01AM
2203-03564-023	Room #2 sink	I	OT	03/24/2022 05:30AM	6.8	ppb			DG-NH	05/01/2022 01:04AM
2203-03564-024	Room #3 sink	I	OT	03/24/2022 05:30AM	3.0	ppb			DG-NH	05/01/2022 01:08AM
2203-03564-025	Room #5 sink	I	OT	03/24/2022 05:30AM	5.7	ppb			DG-NH	05/01/2022 01:12AM
2203-03564-026	Room #6 sink	I	OT	03/24/2022 05:30AM	4.5	ppb			DG-NH	05/01/2022 01:15AM

Rebecca L. Labranche
Laboratory Director