



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

Clinton Elementary School  
75 Morrison Ave  
Clinton, ME 04927

Date Printed: 05/05/2022  
Work Order #: 2203-03726  
Client Job #: 829  
Date Received: 03/28/2022  
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20  
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;  
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507  
Nashoba Analytical, LLC: Accreditations: Massachusetts M-MA1118



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 05/05/2022  
**CLIENT NAME:** Clinton Elementary School

**CLIENT ADDRESS:** 75 Morrison Ave  
Clinton, ME 04927

**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

**DATE AND TIME RECEIVED:** 03/28/2022 09:30AM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 22° CELSIUS  
**CLIENT JOB #:** 829

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-03726-001	Kitchen hand washing sink #1	I	KF	03/25/2022 06:00AM	23.4	ppb			DG-NH	05/03/2022 08:44PM
2203-03726-002	Kitchen hand washing sink #2	I	KF	03/25/2022 06:00AM	1.0	ppb			DG-NH	05/03/2022 08:47PM
2203-03726-003	Kitchen food prep sink #1	I	KF	03/25/2022 06:00AM	1.8	ppb			DG-NH	05/03/2022 08:51PM
2203-03726-004	Kitchen food prep sink #2	I	KF	03/25/2022 06:00AM	<1	ppb			DG-NH	05/03/2022 08:54PM
2203-03726-005	Kitchen food prep sink #3	I	KF	03/25/2022 06:00AM	4.8	ppb			DG-NH	05/03/2022 09:05PM
2203-03726-006	Gym drinking fountain	I	DWF	03/25/2022 06:00AM	<1	ppb			DG-NH	05/03/2022 09:09PM
2203-03726-007	Gym boys bathroom sink	I	OT	03/25/2022 06:00AM	5.5	ppb			DG-NH	05/03/2022 09:13PM
2203-03726-008	Gym girls bathroom sink	I	OT	03/25/2022 06:00AM	8.3	ppb			DG-NH	05/03/2022 09:16PM
2203-03726-009	Upper wing hallway drinking fountain	I	DWF	03/25/2022 06:00AM	<1	ppb			DG-NH	05/03/2022 09:31PM
2203-03726-010	Nurses office sink	I	OT	03/25/2022 06:00AM	3.1	ppb			DG-NH	05/03/2022 09:34PM
2203-03726-011	Upper wing boys bathroom sink #1	I	OT	03/25/2022 06:00AM	2.1	ppb			DG-NH	05/03/2022 09:38PM
2203-03726-012	Upper wing boys bathroom sink #2	I	OT	03/25/2022 06:00AM	4.3	ppb			DG-NH	05/03/2022 09:42PM
2203-03726-013	Upper wing girls bathroom sink #1	I	OT	03/25/2022 06:00AM	3.9	ppb			DG-NH	05/03/2022 09:45PM
2203-03726-014	Upper wing girls bathroom sink #2	I	OT	03/25/2022 06:00AM	3.6	ppb			DG-NH	05/03/2022 09:49PM
2203-03726-015	Lower wing girls bathroom sink #1	I	OT	03/25/2022 06:00AM	1.3	ppb			DG-NH	05/03/2022 10:00PM
2203-03726-016	Lower wing girls bathroom sink #2	I	OT	03/25/2022 06:00AM	2.1	ppb			DG-NH	05/03/2022 10:03PM
2203-03726-017	Lower wing girls bathroom sink #3	I	OT	03/25/2022 06:00AM	1.8	ppb			DG-NH	05/03/2022 10:14PM
2203-03726-018	Lower wing boys bathroom sink #1	I	OT	03/25/2022 06:00AM	2.7	ppb			DG-NH	05/03/2022 10:18PM

Rebecca L. Labranche  
Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/05/2022  
CLIENT NAME: Clinton Elementary School

CLIENT ADDRESS: 75 Morrison Ave  
Clinton, ME 04927

METHOD: EPA 200.8  
EPA ACTION LEVEL: 15 ppb  
MAINE GUIDELINE: 4 ppb  
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 03/28/2022 09:30AM  
ANALYSIS PACKAGE: Maine Schools-Lead  
RECEIPT TEMPERATURE: 22° CELSIUS  
CLIENT JOB #: 829

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-03726-019	Lower wing boys bathroom sink #2	I	OT	03/25/2022 06:00AM	3.1	ppb			DG-NH	05/03/2022 10:21PM
2203-03726-020	Lower wing boys bathroom sink #3	I	OT	03/25/2022 06:00AM	3.6	ppb			DG-NH	05/03/2022 10:25PM
2203-03726-021	Lower wing hall drinking fountain #1	I	DWF	03/25/2022 06:30AM	146	ppb			DG-NH	05/04/2022 07:41PM
2203-03726-022	Lower wing hall drinking fountain #2	I	DWF	03/25/2022 06:30AM	55.3	ppb			DG-NH	05/04/2022 07:45PM
2203-03726-023	Room #126 sink	I	OT	03/25/2022 06:00AM	3.8	ppb			DG-NH	05/03/2022 10:29PM
2203-03726-024	Room #127 sink	I	OT	03/25/2022 06:00AM	1.9	ppb			DG-NH	05/03/2022 10:32PM
2203-03726-025	Room #128 sink	I	OT	03/25/2022 06:00AM	6.6	ppb			DG-NH	05/03/2022 10:36PM
2203-03726-026	Lower wing teachers room sink	I	OT	03/25/2022 06:00AM	2.3	ppb			DG-NH	05/03/2022 10:40PM
2203-03726-027	Room #131 bathroom sink	I	OT	03/25/2022 06:00AM	10.4	ppb			DG-NH	05/04/2022 07:49PM
2203-03726-028	Room #131 hand washing sink	I	OT	03/25/2022 06:00AM	11.2	ppb			DR-NH	05/04/2022 12:08AM
2203-03726-029	Room #131 water bubbler	I	DWF	03/25/2022 06:00AM	<1	ppb			DR-NH	05/04/2022 12:11AM

Rebecca L. Labranche  
Laboratory Director