



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Lawrence Jr High School
7 School Street
Fairfield, ME 04937

Date Printed: 05/09/2022
Work Order #: 2204-00168
Client Job #: 831
Date Received: 04/02/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:


- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical, LLC: Accreditations: Massachusetts M-MA1118



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/09/2022
CLIENT NAME: Lawrence Jr High School

CLIENT ADDRESS: 7 School Street
Fairfield, ME 04937


METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 04/02/2022 09:10AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 19° CELSIUS
CLIENT JOB #: 831

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2204-00168-001	Wood shop drinking fountain	I	DWF	04/01/2022 06:15AM	<1	ppb			DR-NH	05/06/2022 06:17PM
2204-00168-002	Cafeteria drinking fountain #1	I	DWF	04/01/2022 05:00AM	23.4	ppb			DR-NH	05/06/2022 06:32PM
2204-00168-003	Cafeteria drinking fountain #2	I	DWF	04/01/2022 05:45AM	<1	ppb			DR-NH	05/07/2022 10:56AM
2204-00168-004	Kitchen faucet #1	I	KF	04/01/2022 05:00AM	<1	ppb			DR-NH	05/07/2022 10:59AM
2204-00168-005	Kitchen faucet #2	I	KF	04/01/2022 05:00AM	<1	ppb			DR-NH	05/07/2022 11:02AM
2204-00168-006	Kitchen faucet #3	I	KF	04/01/2022 05:00AM	<1	ppb			DR-NH	05/07/2022 11:05AM
2204-00168-007	Loading dock ice maker	I	OT	04/01/2022 05:00AM	<1	ppb			DR-NH	05/07/2022 11:17AM
2204-00168-008	Nurses area bathroom sink #1	I	OT	04/01/2022 05:30AM	1.6	ppb			DR-NH	05/07/2022 11:20AM
2204-00168-009	Nurses area bathroom sink #2	I	OT	04/01/2022 05:30AM	1.0	ppb			DR-NH	05/07/2022 11:29AM
2204-00168-010	Room #115 sink	I	OT	04/01/2022 05:45AM	<1	ppb			DR-NH	05/07/2022 11:31AM
2204-00168-011	Main hallway drinking fountain	I	DWF	04/01/2022 06:30AM	3.4	ppb			DR-NH	05/07/2022 11:34AM
2204-00168-012	Gym lobby drinking fountain	I	DWF	04/01/2022 06:00AM	<1	ppb			DR-NH	05/06/2022 06:35PM
2204-00168-013	2nd floor hallway drinking fountain	I	DWF	04/01/2022 07:00AM	<1	ppb			DR-NH	05/07/2022 11:37AM
2204-00168-014	Williamson ctr drinking fountain 2nd fl	I	DWF	04/01/2022 06:30AM	<1	ppb			DR-NH	05/07/2022 11:40AM
2204-00168-015	Williamson ctr drinking fountain #1	I	DWF	04/01/2022 07:00AM	<1	ppb			DR-NH	05/07/2022 11:43AM
2204-00168-016	Williamson ctr drinking fountain #2	I	DWF	04/01/2022 07:00AM	122	ppb			DR-NH	05/07/2022 11:52AM
2204-00168-017	Room #100 bathroom sink	I	OT	04/01/2022 05:30AM	2.2	ppb			DR-NH	05/07/2022 11:55AM
2204-00168-018	Main hallway boys bathroom sink #1	I	OT	04/01/2022 05:45AM	<1	ppb			DR-NH	05/07/2022 11:58AM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/09/2022
CLIENT NAME: Lawrence Jr High School

CLIENT ADDRESS: 7 School Street
Fairfield, ME 04937

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 04/02/2022 09:10AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 19° CELSIUS
CLIENT JOB #: 831

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2204-00168-019	Main hallway boys bathroom sink #2	I	OT	04/01/2022 05:45AM	<1	ppb			DR-NH	05/07/2022 12:01PM
2204-00168-020	Main hallway girls bathroom sink #1	I	OT	04/01/2022 05:45AM	<1	ppb			DR-NH	05/07/2022 12:10PM
2204-00168-021	Main hallway girls bathroom sink #2	I	OT	04/01/2022 05:45AM	<1	ppb			DR-NH	05/07/2022 12:12PM
2204-00168-022	Room #105 sink #1	I	OT	04/01/2022 05:45AM	6.3	ppb			DR-NH	05/07/2022 12:15PM
2204-00168-023	Room #105 sink #2	I	OT	04/01/2022 05:45AM	5.0	ppb			DR-NH	05/07/2022 12:18PM
2204-00168-024	Boys locker room sink #1	I	OT	04/01/2022 06:00AM	6.6	ppb			DR-NH	05/07/2022 12:30PM
2204-00168-025	Boys locker room sink #2	I	OT	04/01/2022 06:00AM	5.2	ppb			DR-NH	05/07/2022 12:33PM
2204-00168-026	Girls locker room sink #1	I	OT	04/01/2022 06:00AM	2.4	ppb			DR-NH	05/07/2022 12:36PM
2204-00168-027	Girls locker room sink #2	I	OT	04/01/2022 06:00AM	<1	ppb			DR-NH	05/07/2022 12:39PM

Rebecca L. Labranche
Laboratory Director