



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Lawrence High School
9 School Street
Fairfield, ME 04937

Date Printed: 05/09/2022
Work Order #: 2204-00434
Client Job #: 830
Date Received: 04/05/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical, LLC: Accreditations: Massachusetts M-MA1118



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/09/2022
CLIENT NAME: Lawrence High School

CLIENT ADDRESS: 9 School Street
Fairfield, ME 04937


METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	⚠
Lead Above 15 ppb	✗

DATE AND TIME RECEIVED: 04/05/2022 10:55AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 14° CELSIUS
CLIENT JOB #: 830

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2204-00434-001	Drinking fountain near B1/B2	I	DWF	04/04/2022 05:30AM	58.5	ppb	✗		DR-NH	05/06/2022 06:43PM
2204-00434-002	Library sink faucet	I	OT	04/02/2022 07:00AM	13.0	ppb	⚠		DR-NH	05/07/2022 05:49PM
2204-00434-003	Kitchen dishwashing fixture #1	I	KF	04/02/2022 07:00AM	1.2	ppb			DR-NH	05/07/2022 06:04PM
2204-00434-004	Kitchen dishwashing fixture #2	I	KF	04/02/2022 07:00AM	1.2	ppb			DR-NH	05/07/2022 06:07PM
2204-00434-005	Girls locker room sink #1	I	OT	04/02/2022 07:00AM	3.0	ppb			DR-NH	05/07/2022 06:09PM
2204-00434-006	Girls locker room sink #2	I	OT	04/02/2022 07:00AM	2.0	ppb			DR-NH	05/07/2022 06:12PM
2204-00434-007	Coaches office on girls side sink	I	OT	04/02/2022 07:00AM	17.0	ppb	✗		DR-NH	05/07/2022 06:15PM
2204-00434-008	Trainers room ice maker	I	OT	04/02/2022 07:00AM	1.7	ppb			DR-NH	05/07/2022 06:18PM
2204-00434-009	Cafeteria drinking fountain #1	I	DWF	04/02/2022 07:00AM	<1	ppb			DR-NH	05/07/2022 06:21PM
2204-00434-010	Cafeteria drinking fountain #2	I	DWF	04/04/2022 05:30AM	3.9	ppb			DR-NH	05/06/2022 06:46PM
2204-00434-011	Coaches room boys side sink	I	OT	04/04/2022 07:00AM	8.6	ppb	⚠		DR-NH	05/07/2022 06:24PM
2204-00434-012	Boys locker room sink	I	OT	04/04/2022 07:00AM	<1	ppb			DR-NH	05/07/2022 06:36PM
2204-00434-013	Wood shop sink	I	OT	04/04/2022 08:00AM	25.9	ppb	✗		DR-NH	05/07/2022 06:39PM
2204-00434-014	Wood shop drinking fountain	I	DWF	04/04/2022 08:00AM	<1	ppb			DR-NH	05/07/2022 06:47PM
2204-00434-015	Metal shop drinking fountain	I	DWF	04/04/2022 08:00AM	<1	ppb			DR-NH	05/07/2022 06:50PM
2204-00434-016	Metal shop sink	I	OT	04/04/2022 08:00AM	21.8	ppb	✗		DR-NH	05/07/2022 06:53PM
2204-00434-017	Dean of students bathroom sink	I	OT	04/02/2022 08:00AM	1.7	ppb			DR-NH	05/07/2022 06:56PM
2204-00434-018	Girls bathroom main lobby sink	I	OT	04/02/2022 08:00AM	<1	ppb			DR-NH	05/07/2022 06:59PM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354

website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/09/2022
CLIENT NAME: Lawrence High School

CLIENT ADDRESS: 9 School Street
Fairfield, ME 04937

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	⚠
Lead Above 15 ppb	✗

DATE AND TIME RECEIVED: 04/05/2022 10:55AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 14° CELSIUS
CLIENT JOB #: 830

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2204-00434-019	Boys bathroom main lobby sink	I	OT	04/02/2022 08:00AM	<1	ppb			DR-NH	05/07/2022 07:02PM
2204-00434-020	Main Lobby drinking fountain	I	DWF	04/02/2022 08:00AM	<1	ppb			DR-NH	05/07/2022 07:11PM
2204-00434-021	Engli Wing Fountain	I	OT	04/02/2022 08:00AM	68.4	ppb		✗	DR-NH	05/07/2022 07:14PM
2204-00434-022	Health Center bathroom sink	I	OT	04/02/2022 09:00AM	1.5	ppb			DR-NH	05/07/2022 07:17PM
2204-00434-023	Health Center nurses station sink	I	OT	04/02/2022 09:00AM	2.6	ppb			DR-NH	05/06/2022 06:49PM
2204-00434-024	Health Center exam rm #1 sink	I	OT	04/02/2022 09:00AM	2.3	ppb			DR-NH	05/07/2022 07:20PM
2204-00434-025	Trainers Sink	I	OT	04/02/2022 09:00AM	13.4	ppb		⚠	DR-NH	05/06/2022 06:52PM
2204-00434-026	Nurses office sink #1	I	OT	04/02/2022 08:00AM	4.7	ppb		⚠	DR-NH	05/07/2022 07:28PM
2204-00434-027	Nurses office sink #2	I	OT	04/02/2022 08:00AM	3.7	ppb			DR-NH	05/07/2022 07:31PM
2204-00434-028	Isolation room sink	I	OT	04/02/2022 08:00AM	29.7	ppb		✗	DR-NH	05/07/2022 07:34PM
2204-00434-029	Main hallway drinking fountain Annex	I	DWF	04/02/2022 10:00AM	<1	ppb			DR-NH	05/07/2022 07:37PM
2204-00434-030	Teachers room sink across from C-5	I	OT	04/02/2022 10:00AM	47.8	ppb		✗	DR-NH	05/07/2022 07:49PM
2204-00434-031	Room C-2 sink	I	OT	04/02/2022 10:00AM	3.5	ppb			DR-NH	05/07/2022 07:52PM
2204-00434-032	Room C-2A sink	I	OT	04/02/2022 10:00AM	8.7	ppb		⚠	DR-NH	05/07/2022 07:55PM
2204-00434-033	Annex girls bathroom sink #1	I	OT	04/02/2022 10:00AM	1.9	ppb			DR-NH	05/07/2022 07:58PM
2204-00434-034	Annex girls bathroom sink #2	I	OT	04/02/2022 10:00AM	2.3	ppb			DR-NH	05/07/2022 08:01PM
2204-00434-035	Annex boys bathroom sink #1	I	OT	04/02/2022 10:00AM	10.9	ppb		⚠	DR-NH	05/07/2022 08:04PM
2204-00434-036	Annex boys bathroom sink #2	I	OT	04/02/2022 10:00AM	5.0	ppb		⚠	DR-NH	05/07/2022 08:12PM

Rebecca L. Labranche
Laboratory Director