

District Lead Testing Results - Oaklyn Public Schools

Action Level is 15µg/L

School	Location	Result µg/L	Action Level µg/L	Collect Date	Planned Remediation
Oaklyn	1ST FLOOR BOYS TOILET ROOM SINK	ND	15.00	1/30/2017	
Oaklyn	1ST FLOOR GIRLS TOILET ROOM SINK	ND	15.00	1/30/2017	
Oaklyn	WATER FOUNTAIN BY GYM	ND	15.00	1/30/2017	
Oaklyn	KITCHEN 3 BAY SINK	3.21	15.00	1/30/2017	
Oaklyn	WAER FOUNTAIN BY ROOM 167	ND	15.00	1/30/2017	
Oaklyn	KITCHEN SINK	7.71	15.00	1/30/2017	
Oaklyn	STAFF LOUNGE SINK	2.94	15.00	1/30/2017	
Oaklyn	DISHROOM SINK	62.70	15.00	1/30/2017	Conducted flush on 2/16/17
<b>Oaklyn**</b>	<b>DISHROOM SINK FLUSH</b>	<b>1.72</b>	15.00	<b>2/16/2017</b>	<b>Replace pre-rinse faucet</b>
Oaklyn	ROOM 103 SINK	1.50	15.00	1/30/2017	
Oaklyn	ROOM 105 SINK	1.35	15.00	1/30/2017	
Oaklyn	ROOM 106 SINK	3.79	15.00	1/30/2017	
Oaklyn	ROOM 102 SINK	3.65	15.00	1/30/2017	
Oaklyn	ROOM 104 SINK	17.00	15.00	1/30/2017	Conducted flush on 2/16/17
<b>Oaklyn**</b>	<b>ROOM 104 SINK FLUSH</b>	<b>1.31</b>	15.00	<b>2/16/2017</b>	<b>Replace faucet and local plumbing</b>
Oaklyn	ROOM 107 SINK	2.56	15.00	1/30/2017	
Oaklyn	ROOM 101 SINK	1.82	15.00	1/30/2017	
Oaklyn	WATER FOUNTAIN BY LIBRARY	ND	15.00	1/30/2017	
Oaklyn	ROOM 114 SINK	2.90	15.00	1/30/2017	
Oaklyn	WATER FOUNTAIN BY ROOM 103	6.02	15.00	1/30/2017	
Oaklyn	KITCHEN HAND WASH SINK	ND	15.00	1/30/2017	
Oaklyn	NURSE SINK	3.75	15.00	1/30/2017	
Oaklyn	ART ROOM SINK	1.26	15.00	1/31/2017	
Oaklyn	GIRLS LOCKERROOM OFFICE SINK	1.38	15.00	1/31/2017	
Oaklyn	BOYS LOCKERROOM OFFICE SINK	6.06	15.00	1/31/2017	
Oaklyn	MAIN OFFICE SINK	2.12	15.00	1/31/2017	
Oaklyn	COPY ROOM TOILET ROOM SINK	9.51	15.00	1/31/2017	
Oaklyn	PRINCIPALS OFFICE SINK	2.56	15.00	1/31/2017	

Legend: ND = Non Detected

\*\* Retest (Flush Test) following NJDOE Guidelines

Oaklyn	BOYS LOCKERROOM SINK	3.56	15.00	1/31/2017	
Oaklyn	WATER FOUNTAIN BY 202	ND	15.00	1/31/2017	
Oaklyn	OAKLYN	3.18	15.00	1/31/2017	
Oaklyn	WATER FOUNTAIN BY 206	ND	15.00	1/31/2017	
Oaklyn	WATER FOUNTAIN BY 234	ND	15.00	1/31/2017	
Oaklyn	2ND FLOOR GIRLS TOILET ROOM SINK BY STAIR "A"	2.20	15.00	1/31/2017	
Oaklyn	2ND FLOOR GIRLS TOILET ROOM SINK BY STAIR "D"	1.49	15.00	1/31/2017	
Oaklyn	WATER FOUNTAIN BY ROOM 230	ND	15.00	1/31/2017	
Oaklyn	2ND FLOOR BOYS TOILET ROOM BY STAIR "D"	3.28	15.00	1/31/2017	
Oaklyn	ROOM 221 SINK	2.83	15.00	1/31/2017	
Oaklyn	WATER FOUNTAIN BY ROOM 221	ND	15.00	1/31/2017	
Oaklyn	2ND FLOOR BOYS TOILET ROOM BY STAIR "A"	1.37	15.00	1/31/2017	
Oaklyn	HAND WASH SINK IN KITCHEN	22.60	15.00	11/23/2017	<b><i>"HAND WASH ONLY" Signage Required</i></b>
Oaklyn	WATER FOUNTAIN BY NURSE OFFICE	ND	15.00	12/20/2016	
Oaklyn	KITCHEN SINK	9.17	15.00	12/20/2016	

Legend: ND = Non Detected

\*\* Retest (Flush Test) following NJDOE Guidelines