

Imbler School District #11

P.O. Box 164
Imbler, Oregon 97841
541-534-5331 Fax 541-534-9560


Dear Imbler School Community,

This letter is to inform you of the results of the radon testing that was performed in all buildings of the district. As part of Oregon Health Authority's Healthy and Safe Schools Plan, all Oregon schools are required to test for radon by January 1, 2021. All Imbler School District buildings are safe, well below the maximum allowed levels.

You may have heard of radon, but are not sure of what it is or how it affects you. Radon is a naturally occurring gas, which can seep into buildings through the foundation and other openings. In the environment, radon poses little to no risk, but the build-up of radon in an enclosed building can pose serious health effects. Since it is invisible, has no odor, and has no taste, proper testing is the only way to identify radon.

The test results will be posted on the district website.

Thank you for your patience and cooperation. If you have any questions, please contact me at 208-566-0315 or via email at mike.campbell@imblersd.org.



Sincerely,

Mike Campbell, Imbler School District, Maintenance Supervisor

January 10, 2020

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
**IMBLER SCHOOL DISTRICT
AG SHOP**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9315459	CLASSROOM	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	0.7 ± 0.3	2020-01-10
9315456	COMPUTER	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315461	COMPUTER	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315454	COMPUTER	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315458	METAL SHOP	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315457	METAL SHOP	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315462	METAL SHOP	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315455	OFFICE	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	0.6 ± 0.3	2020-01-10
9315460	WOOD SHOP	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	0.6 ± 0.3	2020-01-10

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Radon test result report for:

**IMBLER SCHOOL DISTRICT
ELEMENTARY SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9315446	106	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	0.6 ± 0.3	2020-01-10
9315447	107	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	0.9 ± 0.3	2020-01-10
9315453	108	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	1.4 ± 0.3	2020-01-10
9315452	109	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	1.9 ± 0.3	2020-01-10
9315451	110	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	1.5 ± 0.3	2020-01-10
9315449	111	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	0.7 ± 0.3	2020-01-10
9315450	111	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	0.5 ± 0.3	2020-01-10
9315448	112	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315442	113	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	1.7 ± 0.3	2020-01-10
9315443	113	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	2.0 ± 0.3	2020-01-10
9315441	COUNSELOR OFFICE	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	0.9 ± 0.3	2020-01-10
9315434	LIBRARY	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315437	LIBRARY	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315433	LIBRARY	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315432	MULTIPURPOSE ROOM	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	1.4 ± 0.3	2020-01-10
9315426	MULTIPURPOSE ROOM	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	1.1 ± 0.3	2020-01-10
9315431	MULTIPURPOSE ROOM	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	0.9 ± 0.3	2020-01-10
9315445	NURSE ROOM	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	1.7 ± 0.3	2020-01-10
9315438	PRINCIPAL OFFICE	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	1.6 ± 0.3	2020-01-10
9315440	SECRETARY OFFICE	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	0.8 ± 0.3	2020-01-10
9315439	TEACHERS LOUNGE	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	1.7 ± 0.3	2020-01-10
9315444	TITLE 1	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10

Radon test result report for:

**IMBLER SCHOOL DISTRICT
HIGH SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9315341	1	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315353	10	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315354	10	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315352	10	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315351	2	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315338	3	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315350	3	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315349	4	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315337	5	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315345	6	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315362	7	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315344	8	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315355	9	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315342	CONCESSION	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315425	GYM	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315423	GYM	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315424	GYM	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315418	GYM	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315333	GYM 2	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	13.8 ± 0.8	2020-01-10
9315336	GYM 2	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	13.4 ± 0.8	2020-01-10
9315334	GYM 2	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	12.6 ± 0.8	2020-01-10
9315335	GYM 2	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	12.8 ± 0.8	2020-01-10
9315340	MAINTENANCE ROOM	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315343	OFFICE	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315346	PRINCIPALS OFFICE	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315348	SUPERINTENDENTS OFFICE	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315339	TEACHER LOUNGE	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10
9315347	TERESAS OFFICE	2020-01-06 @ 7:00 am	2020-01-09 @ 7:00 am	< 0.3	2020-01-10

January 10, 2020

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**IMBLER SCHOOL DISTRICT
MUSIC**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9315463	MUSIC	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315464	MUSIC	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10
9315465	MUSIC	2020-01-06 @ 8:00 am	2020-01-09 @ 8:00 am	< 0.3	2020-01-10

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498