

TABLE 1

Drinking Water Sampling for Lead Content
 Rome CCSD 2
 Rome Elementary School
 Sampled: August 25, 2017

Sample ID	Location	Water Source	Results (ppb)
01	Cafeteria (right)	Fountain	<1.0
01A	Cafeteria (right)	Fountain	<1.0
02	Kitchen	Sprayer	<1.0
02A	Kitchen	Sprayer	<1.0
03	Kitchen 3 Bay	Sink	1.1
03A	Kitchen 3 Bay	Sink	<1.0
04	Kitchen 2 Bay	Sink	<1.0
04A	Kitchen 2 Bay	Sink	<1.0
05	Kitchen	Hand Sink	1.3
05A	Kitchen	Hand Sink	<1.0
06	Shower Room Hall	Fountain	<1.0
06A	Shower Room Hall	Fountain	1.3
07	By Room 100 (left)	Fountain	<1.0
07A	By Room 100 (left)	Fountain	<1.0
08	By Room 100 (right)	Fountain	<1.0
08A	By Room 100 (right)	Fountain	<1.0
09	By Room 105 (left)	Fountain	<1.0
09A	By Room 105 (left)	Fountain	<1.0
10	By Room 105 (right)	Fountain	<1.0
10A	By Room 105 (right)	Fountain	<1.0
11	By Room 107 (left)	Fountain	<1.0
11A	By Room 107 (left)	Fountain	<1.0
12	By Room 107 (right)	Fountain	<1.0
12A	By Room 107 (right)	Fountain	<1.0
13	By Room 162 (right)	Fountain	<1.0
13A	By Room 162 (right)	Fountain	<1.0
14	Concession Stand	Hand Sink	<1.0
14A	Concession Stand	Hand Sink	<1.0
15	Concession Stand 3 Bay	Sink	3.5
15A	Concession Stand 3 Bay	Sink	<1.0
16	Concession Stand	Ice Maker	5.0
16A	Concession Stand	Ice Maker	<1.0
17	Cafeteria	Ice Maker	53.0
17A	Cafeteria	Ice Maker	28.4

A/B Samples were precautionary samples collected at 30 seconds following the "first draw" samples (A) and 3 minutes following the A sample (B).



Water sources in excess of 20 ppb. Recommendation is to remove from service immediately. Do not return to service until re-testing confirms mitigation was effective.



Water source is < 20 ppb, but still displays evidence of lead. Recommendation is to re-test source on an annual basis at a minimum

LIST OF POTABLE WATER SOURCES TO BE TESTED

QUANTITY	ITEM	LOACATION
2	WATER FOUNTAIN	NORTH CAFETERIA ENTRANCE
4	SINK FAUCET	KITCHEN
1	WATER FOUNTAIN	OUTSIDE OF THE BOY'S LOCKER ROOM
2	WATER FOUNTAIN	UPPER HALL - NEXT TO ESSER'S CLASSROOM
2	WTAER FOUNTAIN	UPPER HALL - NEXT TO THE COMPUTER LAB
2	WATER FOUNTAIN	LOWER HALL - BETWEEN DECKER AND CROUSE'S CLASSROOM
2	WATER FOUNTAIN	JR. HIGH - HALL BETWEEN THE BOY'S AND GIRLS RESTROOM