



State Water Resources Control Board

Division of Drinking Water

Lead and Copper Tap Sample Results Reporting Form

This form must be submitted by the public water system to the regulating entity (DDW District Office or County Agency) for each round of lead and copper sampling

Report Date: (mm/dd/yyyy)	8/11/2023
Water System Name:	South Fork Middle School
Water System Number:	1503368
Water System Type:	<input type="checkbox"/> Community <input checked="" type="checkbox"/> Non-Transient, Non Community
Monitoring Frequency:	<input type="checkbox"/> 6-month <input type="checkbox"/> Annual <input checked="" type="checkbox"/> Triennial
# of Samples Required:	5
# of Samples Reported:	5
	90th Percentile Level (mg/L)
Lead: <i>Action Level = 0.015 mg/L</i>	ND
Copper: <i>Action Level = 1.3 mg/L</i>	0.280

				Result	
	Sample Date	Sample Site Location/Address	Tier 1, 2, 3, or R	Lead (mg/L)	Copper (mg/L)
01	7/26/23	Faculty Restroom Sink / 6401 Fay Ranch Rd., Weldon		ND	0.009
02	7/26/23	School Office / Same as above		ND	0.340
03	7/26/23	Kitchen Food Sink / Same as above		ND	0.110
04	7/26/23	Drinking Fountain 100		ND	0.220
05	7/26/23	Drinking Fountain gym / Same as above		ND	0.130
06					
07					
08					
09					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

