

PART 3: SAMPLING & ANALYSIS WORKSHEET

Depew Bus Garage
5261 S. Transit Rd.
Depew, New York 14043
UNYSE Project: 16-0917JGB

Sample #	Room Name	Wall ID	Outlet #	Outlet Type	Lab ID	Result (mg/l)	Result (ppb)
B1	Bus Garage Work Area	A	B1	DF	001	ND	ND
B2	Bus Garage Drivers Lounge	D	B2	S	002	0.0014	1.40

Key:

Sample #: Sample ID

Wall ID: Unique wall location utilizing HUD identification protocol A, B, C or D

Outlet #: same as sample ID

Outlet Type: S-Sink, DF-Drinking Fountain, T-Trough Sink

ND-None Detected