

# PART 3: SAMPLING & ANALYSIS WORKSHEET

Depew High School  
5201 Transit Rd.  
Depew, New York 14043  
UNYSE Project: 16-0917JGA

Sample #	Room Name	Wall ID	Outlet #	Outlet Type	Lab ID	Result (mg/L)	Result (ppb)	Exceeds Limits
A1	Boys Locker Rm.	B1	A1	DF	001	0.00307	3.07	NO
A2	Boys Locker Rm.	B2	A2	DF	002	0.00337	3.37	NO
A3	Boys Locker Rm.	A2	A3	DF	003	ND	ND	ND
A4	Boys Locker Rm.	C	A4	T	004	0.00188	1.88	NO
A5	Coaches Rm.	D	A5	S	005	0.01420	14.20	NO
A6	Girls Locker Rm.	B1	A6	DF	006	0.00193	1.93	NO
A7	Girls Locker Rm.	B2	A7	DF	007	0.00233	2.33	NO
A8	Girls Locker Rm.	C	A8	T	008	0.00381	3.81	NO
A9	Girls Sm. Coaches Rm.	C	A9	S	009	0.00262	2.62	NO
A10	Rm. 158	B	A10	S	010	0.01370	13.70	NO
A11	Girls Lg. Gym Locker Rm.	C1	A11	DF	011	ND	ND	ND
A12	Girls Lg. Gym Locker Rm.	C2	A12	DF	012	ND	ND	ND
A13	Girls Lg. Gym Locker Rm.	D	A13	T	013	0.00265	2.65	NO
A14	Boys Lg. Gym Locker Rm.	B	A14	T	014	0.00108	1.08	NO
A15	Boys Lg. Gym Locker Rm.	C1	A15	DF	015	ND	ND	ND
A16	Boys Lg. Gym Locker Rm.	C2	A16	DF		0.01070	10.70	NO
A17	Boys Lg. Gym Coaches Rm	D	A17	S		ND	ND	ND
A18	Lg. Gym	D	A18	DF	018	0.00526	5.26	NO
A19	Music Hallway	D1	A19	DF	019	0.00217	2.17	NO
A20	Rm. 170	A	A20	S	020	0.00426	4.26	NO
A21	Music Hallway	D2	A21	DF	021	0.00152	1.52	NO
A22	Girls Lavatory Rm. 175	D	A22	S	022	0.00348	3.48	NO
A23	Boys Lavatory Rm. 176	B	A23	S	023	0.00436	4.36	NO
A24	At Rm. 184C	D	A24	DF	024	ND	ND	ND
A25	Rm. 102 Mens Lavatory	D	A25	S	025	0.00213	2.13	NO

ASBESTOS | LEAD | MOLD | HAZMAT

ENVIRONMENTAL CONSULTANTS

877 466 4429

346 AUSTIN STREET **BUFFALO** NEW YORK 14207 | 716 833 2929 FAX 716 833 9292  
4 COMMERCIAL STREET, LL **ROCHESTER** NEW YORK 14614 | 585 783 1465 FAX 585 783 1466

Sample #	Room Name	Wall ID	Outlet #	Outlet Type	Lab ID	Result (mg/L)	Result (ppb)	Exceeds Limits
A26	Rm. 103 Ladies Lavatory	A	A26	S	026	0.00427	4.27	NO
A27	Rm. 131 Mens Lavatory	A1	A27	S	027	ND	ND	ND
A28	Rm. 131 Mens Lavatory	A2	A28	S	028	0.00127	1.27	NO
A29	Rm. 131 Mens Lavatory	A3	A29	S	029	0.00142	1.42	NO
A30	Rm. 131 Mens Lavatory	A4	A30	S	030	0.00266	2.66	NO
A31	Rm. 131 Mens Lavatory	A5	A31	S	031	0.00440	4.40	NO
A32	Rm. 132A Nurses Rm.	C	A32	S	032	0.00172	1.72	NO
A33	Rm. 132B Nurses Rm.	A	A33	S	033	0.00309	3.09	NO
A34	Hallway 187 at Rm. 134	B	A34	DF	034	ND	ND	ND
A35	Rm. 134 Girls Lavatory	B	A35	S	035	0.00226	2.26	NO
A36	Rm. 134 Girls Lavatory	B	A36	S	036	0.00219	2.19	NO
A37	Rm. 134 Girls Lavatory	B	A37	S	037	0.00200	2.00	NO
A38	Rm. 134 Girls Lavatory	B	A38	S	038	0.00108	1.08	NO
A39	Rm. 134 Girls Lavatory	B	A39	S	039	ND	ND	ND
A40	Rm. 134 Girls Lavatory	B	A40	S	040	0.00114	1.14	NO
A41	Rm. 151 Faculty	B	A41	S	041	0.00347	3.47	NO
A42	Rm. 151 Faculty	B	A42	Ice Machine	042	0.00112	1.12	NO
A43	Rm. 135 Kitchen	D	A43	Ice Machine	043	0.00115	1.15	NO
A44	Rm. 135 Kitchen	D	A44	Dish Sink	044	0.00358	3.58	NO
A45	Rm. 135 Kitchen	center	A45	Steam Kettle	045	0.00578	5.78	NO
A46	Rm. 135 Kitchen	D	A46	Hand-washing Sink	046	0.02280	22.80	YES
A47	Rm. 135 Kitchen		A47	Prep Sink	047	0.08580	85.80	YES
A48	Rm. 135 Kitchen	A	A48	Utility Sink	048	0.01270	12.70	NO
A49	Rm. 135 Kitchen	B1	A49	Dish Sink	049	0.03370	33.70	YES
A50	Rm. 135 Kitchen	B2	A50	Dish Sink	050	0.08450	84.50	YES
A51	Rm. 135 Kitchen	C	A51	Sprayer	051	0.00494	4.94	NO
A52	Rm. 135 Kitchen	C	A52	Hose	052	0.00161	1.61	NO
A53	Rm. 152 Cafeteria	A1	A53	DF	053	ND	ND	ND
A54	Rm. 152 Cafeteria	A2	A54	DF	054	0.00147	1.47	NO
A55	Hallway 186 at Rm. 150	C2	A55	DF	055	0.00159	1.59	NO
A56	Rm. 147	D	A56	S	056	0.04560	45.60	YES

Sample #	Room Name	Wall ID	Outlet #	Outlet Type	Lab ID	Result (mg/L)	Result (ppb)	Exceeds Limits
A57	Rm. 146B Mens Lavatory	C	A57	S	057	0.00938	9.38	NO
A58	Rm. 146A Ladies Lavatory	A	A58	S	058	0.00349	3.49	NO
A59	Hallway 186 ar Rm. 146B	C1	A59	DF	059	ND	ND	ND
A60	Rm. 145 Girls Lavatory	B1	A60	S	060	ND	ND	ND
A61	Rm. 145 Girls Lavatory	B2	A61	S	061	0.00249	2.49	NO
A62	Rm. 143 Boys Lavatory	D	A62	S	062	0.00317	3.17	NO
A63	Rm. 120	D	A63	S	063	0.00141	1.41	NO
A64	Rm. 120	D	A64	S	064	0.00211	2.11	NO
A65	Rm. 121	A	A65	S	065	0.01680	16.80	YES
A66	Rm. 122	C	A66	S	066	0.01490	14.90	NO
A67	Hallway 185	B2	A67	DF	067	0.00334	3.34	NO
A68	Rm. 119	C	A68	S	068	0.00499	4.99	NO
A69	Rm. 116A	D	A69	S	069	0.06780	67.80	YES
A70	Rm. 114A	D	A70	S	070	0.11150	111.50	YES
A71	Hallway 185	B	A71	DF	071	0.00599	5.99	NO
A72	Rm. 127A Business Office	A	A72	S	072	0.00119	1.19	NO
A73	Rm. 128 Art	A1	A73	S	073	0.00137	1.37	NO
A74	Rm. 128 Art	A2	A74	S	074	0.00160	1.60	NO
A75	Rm. 128 Art	B	A75	S	075	0.00126	1.26	NO
A76	Rm. 110 Boys Lavatory	B1	A76	S	076	0.02430	24.30	YES
A77	Rm. 110 Boys Lavatory	B2	A77	S	077	0.00929	9.29	NO
A78	Rm. 110 Boys Lavatory	B3	A78	S	078	0.01740	17.40	YES
A79	Hallway 184B	A	A79	DF	079	0.00164	1.64	NO
A80	Rm. 108 Girls Lavatory	D1	A80	S	080	0.01100	11.00	NO
A81	Rm. 108 Girls Lavatory	D2	A81	S	081	0.00605	6.05	NO
A82	Rm. 108 Girls Lavatory	D3	A82	S	082	0.00680	6.80	NO
A83	Rm. 129 Art	A1	A83	S	083	0.00166	1.66	NO
A84	Rm. 129 Art	A2	A84	S	084	0.00119	1.19	NO
A85	Rm. 129 Art	B	A85	S	085	ND	ND	ND
A86	Hallway 268 at Rm. 206	A	A86	DF	086	0.01990	19.90	YES
A87	Rm. 209 Girls Lavatory	D	A87	S	087	0.00819	8.19	NO
A88	Rm. 209 Girls Lavatory	D	A88	S	088	0.00398	3.98	NO

Sample #	Room Name	Wall ID	Outlet #	Outlet Type	Lab ID	Result (mg/L)	Result (ppb)	Exceeds Limits
A89	Rm. 209 Girls Lavatory	D	A89	S	089	0.02300	23.00	YES
A90	Rm. 210 Boys Lavatory	B	A90	S	090	0.00213	2.13	NO
A91	Rm. 210 Boys Lavatory	B	A91	S	091	0.00642	6.42	NO
A92	Rm. 210 Boys Lavatory	B	A92	S	092	0.01410	14.10	NO
A93	Hallway 269	B	A93	DF	093	0.00521	5.21	NO
A94	Rm. 214A Science Lab/Chem Storage	D	A94	S	094	0.00887	8.87	NO
A95	Rm. 216A Science Lab Chem. Storage	D	A95	S	095	0.35800	358.00	YES
A96	Rm. 239 Boys Lavatory	D	A96	T	096	0.00671	6.71	NO
A97	Hallway 266 at Rm. 240	C	A97	DF	097	0.00333	3.33	NO
A98	Rm. 241 Girls Lavatory	B	A98	T	098	0.00465	4.65	NO
A99	Rm. 242B Mens Rm.	C	A99	S	099	0.00867	8.67	NO
A100	Rm. 242A Ladies Rm.	A	A100	S	100	0.00493	4.93	NO
A101	Hallway 266 at Rm. 246	C	A101	DF	101	0.00238	2.38	NO
A102	Rm. 229 Womens Lavatory	B1	A102	S	102	0.00772	7.72	NO
A103	Rm. 229 Womens Lavatory	B2	A103	S	103	0.02700	27.00	YES
A104	Rm. 228 Mens Lavatory	B	A104	S	104	0.00395	3.95	NO
A105	Hallway 270 at Rm. 226	B	A105	DF	105	0.00113	1.13	NO
A106	Hallway 271 at Rm. 252	D1	A106	DF	106	0.00492	4.92	NO
A107	Hallway 271 at Rm. 254	D2	A107	DF	107	0.00247	2.47	NO
A108	Rm. 256 Girls Lavatory	C1	A108	S	108	0.01790	17.90	YES
A109	Rm. 256 Girls Lavatory	C2	A109	S	109	0.01840	18.40	YES
A110	Rm. 256 Girls Lavatory	C3	A110	S	110	0.00644	6.44	NO
A111	Rm. 257 Mens Lavatory	A1	A111	S	111	0.01110	11.10	NO
A112	Rm. 257 Mens Lavatory	A2	A112	S	112	0.01680	16.80	YES
A113	Rm. 257 Mens Lavatory	A3	A113	S	113	0.01610	16.10	YES
A114	Rm. 261	D	A114	S	114	0.00713	7.13	NO
A115	Hallway 268 at Rm. 224	A	A115	DF	115	0.00177	1.77	NO

**Key:**

Sample #: Sample ID

Wall ID: Unique wall location utilizing HUD identification protocol A, B, C or D

Outlet #: same as sample ID

Outlet Type: S-Sink, DF-Drinking Fountain, T-Trough Sink

ND-None Detected