

PART 3: SAMPLING & ANALYSIS WORKSHEET

Depew Middle School
 5201 Transit Rd.
 Depew, New York 14043
 UNYSE Project: 160917-JGC

Sample #	Room Name	Wall ID	Outlet #	Outlet Type	Lab ID	Result (mg/L)	Results (ppb)	Exceeds Limit
C1	Hallway 318 at Rm. 302	C	C1	DF	001	0.00262	2.62	NO
C2	Rm. 302 Clinic	C2	C2	S	002	0.01660	16.60	YES
C3	Rm. 302 Clinic	C3	C3	S	003	0.01310	13.10	NO
C4	Rm. 314A Lavatory	D	C4	S	004	0.04880	48.80	YES
C5	Rm. 314C Lavatory	D	C5	S	005	0.02570	25.70	YES
C6	Hallway 318 at Rm. 318	B	C6	DF	006	0.00184	1.84	NO
C7	Rm. 312 Boys Lavatory	D	C7	S	007	0.00679	6.79	NO
C8	Rm. 305B	B	C8	S	008	0.03300	33.00	YES
C9	Rm. 305C	B	C9	S	009	0.03090	30.90	YES
C10	Rm. 306	C	C10	S	010	0.00310	3.10	NO
C11	Print Shop	C	C11	S	011	0.00254	2.54	NO
C12	Hallway 113 at Rm. 105	D	C12	DF	012	ND	ND	NO
C13	Rm. 106 Girls Lavatory	A1	C13	S	013	0.00706	7.06	NO
C14	Rm. 106 Girls Lavatory	A2	C14	S	014	0.00659	6.59	NO
C15	Rm. 110	A	C15	S	015	ND	ND	ND
C16	Rm. 111	D	C16	S	016	0.00490	4.90	NO
C17	Rm. 111	D	C17	DF	017	0.00601	6.01	NO
C18	Hallway 113 at Rm. 101	D	C18	DF	018	ND	ND	NO
C19	Rm. 114	A	C19	S	019	0.00781	7.81	NO
C20	Rm. 242A	C	C20	S	020	0.00401	4.01	NO
C21	Rm. 241A	A	C21	S	021	0.00317	3.17	NO
C22	Rm. 202	C	C22	S	022	0.00892	8.92	NO
C23	Rm. 245B Girls Phys Ed	C	C23	S	023	0.02600	26.00	YES
C24	Rm. 245 Girls Locker Rm.	D	C24	S	024	0.00121	1.21	NO
C25	Rm. 245 Girls Locker Rm.	B1	C25	DF	025	0.00219	2.19	NO

ASBESTOS | LEAD | MOLD | HAZMAT

ENVIRONMENTAL CONSULTANTS

877 466 4429

Sample #	Room Name	Wall ID	Outlet #	Outlet Type	Lab ID	Result (mg/L)	Results (ppb)	Exceeds Limit
C26	Rm. 245 Girls Locker Rm.	B2	C26	DF	026	0.00232	2.32	NO
C27	Rm. 244B Boys Phys Ed	C	C27	S	027	0.00464	4.64	NO
C28	Rm. 244 Boys Locker Rm.	B	C28	T	028	0.00490	4.90	NO
C29	Rm. 244 Boys Locker Rm.	D1	C29	S	029	0.00156	1.56	NO
C30	Rm. 244 Boys Locker Rm.	D2	C30	S	030	0.00185	1.85	NO
C31	Rm. 229 Boys Lavatory	D1	C31	S	031	0.00228	2.28	NO
C32	Rm. 229 Boys Lavatory	D2	C32	S	032	0.00327	3.27	NO
C33	Rm. 229 Boys Lavatory	D3	C33	S	033	0.00318	3.18	NO
C34	Rm. 236 Girls Lavatory	B1	C34	S	034	0.00686	6.86	NO
C35	Rm. 236 Girls Lavatory	B2	C35	S	035	0.00409	4.09	NO
C36	Rm. 236 Girls Lavatory	B3	C36	S	036	0.01220	12.20	NO
C37	Hallway 248A	D	C37	DF	037	0.00121	1.21	NO
C38	Rm. 226	B1	C38	S	038	0.00132	1.32	NO
C39	Rm. 226	B2	C39	S	039	0.00307	3.07	NO
C40	Rm. 226	B3	C40	S	040	0.00507	5.07	NO
C41	Rm. 240A	B	C41	S	041	0.00569	5.69	NO
C42	Hallway 248	A	C42	DF	042	0.00472	4.72	NO
C43	Rm. 204	C1	C43	S	043	ND	ND	NO
C44	Rm. 204	C2	C44	S	044	ND	ND	NO
C45	Rm. 204	A1	C45	S	045	ND	ND	NO
C46	Rm. 204	A2	C46	S	046	ND	ND	NO
C47	Rm. 222 Cafeteria	D	C47	DF	047	0.00341	3.41	NO
C48	Rm. 220 Kitchen	D	C48	Hand Sprayer	048	0.03500	35.00	YES
C49	Rm. 220 Kitchen	D	C49	Hose	049	ND	ND	NO
C50	Rm. 220 Kitchen	D1	C50	Dish Sink	050	0.01760	17.60	YES
C51	Rm. 220 Kitchen	D2	C51	Dish Sink	051	0.01680	16.80	YES
C52	Rm. 220 Kitchen	A	C52	Prep Sink	052	0.00549	5.49	NO
C53	Rm. 220 Kitchen	A	C53	Steamer	053	0.01870	18.70	YES
C54	Rm. 220 Kitchen	B	C54	Dish Sink	054	0.04730	47.30	YES
C55	Rm. 221	A	C55	S	055	0.01040	10.40	NO
C56	Rm. 204B	B	C56	S	056	0.00948	9.48	NO

ASBESTOS | LEAD | MOLD | HAZMAT

ENVIRONMENTAL CONSULTANTS

877 466 4429

346 AUSTIN STREET BUFFALO NEW YORK 14207 | 716 833 2929 FAX 716 833 9292

4 COMMERCIAL STREET, LL ROCHESTER NEW YORK 14614 | 585 783 1465 FAX 585 783 1466

Sample #	Room Name	Wall ID	Outlet #	Outlet Type	Lab ID	Result (mg/L)	Results (ppb)	Exceeds Limit
C57	Rm. 217 Boys Lavatory	D	C57	S	057	0.00361	3.61	NO
C58	Rm. 206 Girls Lavatory	B	C58	S	058	0.00477	4.77	NO
C59	Hallway 247 at Rm. 217	C	C59	DF	059	0.00157	1.57	NO
C60??	Rm. 213 Special Ed.	B	C60	S	060	ND	2nd floor	NO

Key:

Sample #: Sample ID

Wall ID: Unique wall location utilizing HUD identification protocol A, B, C or D

Outlet #: same as sample ID

Outlet Type: S –Sink, DF-Drinking Fountain, T-Trough Sink

ND-None Detected